



KEYED NOTES:

- ① NEW PANEL IS TO BE SILENT KNIGHT MODEL 5808 WHICH IS TO BE FURNISHED AS PART OF THE FIRE BOAT CREW QUARTERS PROJECT. THESE ADDITIONS AND MODIFICATIONS ARE TO BE FURNISHED BY THE CITY OF PORTLAND AND INSTALLED BY QUALIFIED PERSONNEL.
- ② INTENT IS TO REUSE EXSTING PANEL LOCATION AS A JUNCTION BOX FOR INCOMING EXISTING CABLES/WIRING.
- ③ INTENT IS TO REUSE EXISTING HORN/STROBES AND CONNECT TO NEW FIRE ALARM PANEL.
- ④ INTENT IS TO REUSE EXISTING PULL STATIONS AND REUSE EXISTING WIRING BACK TO FACP.
- ⑤ INTENT IS TO FURNISH NEW ELEVATOR 5-8 ZONE INTERFACE FOR CONNECTION OF EXISTING DEVICES BACK TO ELEVATOR CONTROL PANEL USING OUTPUT MODULES.

FIRE ALARM SYMBOLS

- [F] PULL STATION
- [S^{xx}] FIRE ALARM AUDIBLE/VISIBLE NOTIFICATION APPLIANCE (GENERAL EVACUATION)
- [S^{xx}] STROBE UNIT XX= CANDELA
- [H] MINI HORN UNIT
- [H] HEAT DETECTOR
- [TS] SPRINKLER TAMPER SWITCH
- [FS] SPRINKLER FLOW SWITCH
- [PS] SPRINKLER PRESSURE SWITCH
- [CM] CONTROL MODULE/RELAY
- [NAC] NOTIFICATION APPLIANCE CIRCUIT POWER UNIT
- [F] AES RADIO SYSTEM



1 EXISTING FIRE ALARM SYSTEM MODIFICATIONS

SCALE: N.T.S.

<p>SWIFTCURRENT Engineering Services 10 Forest Falls Dr. Unit 8b Yarmouth, ME 04096 Tel (207) 847-9280</p>	<p>PORTLAND FIRE BOAT PORTLAND, ME SCALE: AS NOTED DATE: 07-17-2013</p>
	<p>E1</p>