

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
CITY OF PORTLAND

Located at
54 COMMERCIAL ST

PERMIT ID: 2016-02018 ISSUE DATE: 09/12/2016 CBL: 444 A001001

has permission to **For the installation of a Non-Water Based Fire Suppression System (Range Guard Wet Chemical System) for the Maine State Pier (Waterfront Concerts).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02018	Date Applied For: 08/01/2016	CBL: 444 A001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Concert Venue - Maine State Pier		Proposed Project Description: For the installation of a Non-Water Based Fire Suppression System (Range Guard Wet Chemical System) for the Maine State Pier (Waterfront Concerts).		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 09/09/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This permit DOES NOT certify the legal use of the property or building. It only authorizes the installation of the fire suppression system.		
Dept: Fire		Status: Approved w/Conditions	Reviewer: Michael White	Approval Date: 09/02/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) All installations shall comply with NFPA 17A, NFPA 96, UL 300, as well as in accordance with the terms of appliance listings and manufacture instructions.		
		2) All installations shall comply with NFPA 17A, NFPA 96, UL 300, as well as in accordance with the terms of appliance listings and manufacture instructions. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.		
		3) All means of egress to remain accessible at all times.		
		4) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).		
		5) All construction shall comply with City Code, Chapter 10.		