The wall mounted mini-splits (3) are located inside of the bathrooms. roughly 6' off the ground.

The heat pump compressor is located to the rear of the bathroom container, and is temporarily bolted to a frame 2' above the pier in a serviceable but non-public area of the pier.

As it's a heat pump, there is no vent per-se.

Thank you!

- Jon