7/10/2014

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/12/14

Shuck's Maine Lobster

Maine State Pier
40 Commercial Street
Portland, Me. 04101

Phase One Project = Pre-occupancy

To construct a 1 hour fire rated demising wall and access doors

NFPA 101 - 2009 Code Analysis

Proposed tenant use = General Industrial Occupancy - Chapter 40

Fire Suppression System: Sprinklered

Means of Egress Limitations:		Actual egress dimensions prior to f
Common Path of Travel	100'	Open
Dead End limit	50'	Open
Travel Distance Limit	250'	80' between proposed new and e:
Minimum Egress		See plans - 2 each provided as part
Alarm System provided:	Yes	Yes - Tenant to provide dedicated
Electrical Connections		_Yes by city - Tenant to provide de
Emergency Lighting and Signage		Tenant to provide dedicated syste (Tenant to install temporary signag emergency lighting during constru
Rated wall construction		See plan CAN-01

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/12/14

full fit up:

xisting doors

t of Phase One construction

system prior to occupancy

edicated system prior to occupancy

m prior to occupancy
ge and
ction)