

Form # P01

ELECTRICAL PERMIT

City of Portland, Me.



**PLEASE NOTE IF YOU ARE
INSTALLING A FIRE
ALARM/SPRINKLER SYSTEM
A SEPERATE PERMIT IS
REQUIRED**

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations
in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
National Electrical Code and the following specifications:

Date 6/16/09
Permit # 2009 4351
CBL# 444 A 003

LOCATION: 40 Commercial Street 6-44 Commercial METER MAKE & # _____
CMP ACCOUNT # _____ OWNER General Services Administration
TENANT Customs and Border Protection PHONE # _____

A 003
JHJ

SCANNED

					TOTAL EACH FEE	
OUTLETS	Receptacles	Switches	Smoke Detector		.20	
FIXTURES	Incandescent	Fluorescent	Strips		.20	
SERVICES	Overhead	Underground	TTL AMPS <800		15.00	
	Overhead	Underground	TTL AMPS >800		25.00	
Temporary Service	Overhead	Underground	TTL AMPS		25.00	
METERS	(number of)				25.00	
MOTORS	(number of)				1.00	
RESID/COM	Electric units	<u>5</u>			2.00	
HEATING	oil/gas units	Interior	Exterior		5.00	<u>5</u>
	APPLIANCES	Ranges	Cook Tops	Wall Ovens	2.00	
	Insta-Hot	Water heaters	Fans		2.00	
	Dryers	Disposals	Dishwasher		2.00	
	Compactors	Spa	Washing Machine		2.00	
	Others (denote)				2.00	
MISC. (number of)	Air Cond/win				3.00	
	Air Cond/cent		Pools		10.00	
	HVAC	EMS	Thermostat		5.00	
	Signs				10.00	
	Alarms/res				5.00	
	Alarms/com				15.00	
	Heavy Duty(CRKT)	<u>5</u>			2.00	<u>10</u>
	Circus/Carnv				25.00	
	Alterations				5.00	
	Fire Repairs				15.00	
	E Lights				1.00	
	E Generators				20.00	
PANELS	Service	Remote	Main		4.00	
TRANSFORMER	0-25 Kva				5.00	
	25-200 Kva				8.00	
	Over 200 Kva				10.00	
TOTAL AMOUNT DUE						
MINIMUM FEE/COMMERCIAL 55.00					MINIMUM FEE	45.00
						<u>55</u>

DEPT. OF BUILDING INSPECTION
CITY OF PORTLAND, ME
JUN 22 2009
RECEIVED

CONTRACTORS NAME R.L. Todd & Son Inc. MASTER LIC. # MCG0017303
ADDRESS 414 Main St, Caribou, Me. 04736 LIMITED LIC. # _____
TELEPHONE 207-496-1671

SIGNATURE OF CONTRACTOR Timothy Todd

White Copy - Office • Yellow Copy - Applicant

06/23/09

- conduits in trenches okay
- EMT not allowed on extension of ground conductors per city ordinance

MS