


Note:
The heating hot water and chilled water systems shall be filled with a 40% propylene glycol (Dowfrost) and water solution. The propylene glycol shall contain long-life corrosion inhibitors.



7 Bennett Road
P.O. Box 272
Bangor, ME 04401
Tel: (207) 865-9415
Fax: (207) 865-1800
info@bennettengineering.com

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
PROJECT NUMBER 009215.00
PIN 009215.00

PROF. MANAGER PAUL POTILE
 DESIGN-DETAILED SMR
 CHECKED-REVIEWED SP DOEL
 DESIGN-2-DETAILED2 SMR
 DESIGN-3-DETAILED3 SP DOEL
 REVISIONS 1
 REVISIONS 2
 REVISIONS 3
 REVISIONS 4
 FIELD CHANGES

DATE 10/05/04
 BY SP DOEL
 DATE 10/05/04
 BY SP DOEL

DATE 10/15/04
 BY P. DOEL
 DATE 10/15/04
 BY P. DOEL

PROJ. MANAGER	PAUL POTILE	DATE
DESIGN-DETAILED	SMR	10/05/04
CHECKED-REVIEWED	SP DOEL	10/05/04
DESIGN-2-DETAILED2	SMR	10/05/04
DESIGN-3-DETAILED3	SP DOEL	10/05/04
REVISIONS 1		
REVISIONS 2		
REVISIONS 3		
REVISIONS 4		
FIELD CHANGES		

CITY OF PORTLAND
OCEAN GATEWAY PHASE 1
TERMINAL BUILDING
UPPER LEVEL HVAC PLAN

TERMINAL BUILDING UPPER LEVEL PLAN
SCALE: 1/8"=1'-0"

H101-T