

some BURN Duct cycle
Penthouse

INCUBATION ROOM
Unit Re Placement

Supply Duct

Steam Coil

A/C coil

Replace Existing Gas
Fired Furnace
York 100,000 BTU

Returns Duct

Supply Duct work to have 8 discharging air Grills
Return Duct to be along the wall 8' from floor
The A/C coils to be located on the lower roof.
CONDENSATE