Protection 1 Branch 11660

10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011

System Inputs	System Outputs																																				
	Control Unit Annunciation																Notification																		Safety Control		
	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator			Actuate Basment floor evacuation signals	Actuate 1st Floor Evacuation Signals	Actuate 2nd Floor Evacuation Signal	Actuate 3rd Floor Evacuation Signals	Actuate 4th Floor Evacuation Signals	Actuate 5th Floor Evacuation Signals				Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising	Transmit trouble signal to supervising station																	
System Pull Stations		X	X						X	X	X	X	X	X			X																				
System Smoke Detectors		X	X						X	X	X	X	X	X			X																				
System Heat Detectors		X	X						X	X	X	X	X	X			X																				
Sprinkler Water Flow		X	X																																		
Sprinkler Gate Valve Tamper					X	X												X																			
Sprinkler Air Pressure																																					
FACP AC Loss					X	X													X																		
FACP Low Battery					X	X													X																		
FACP Ground Fault					X	X													X																		
Phone Line #1 Fail					X	X													X																		
Phone Line #2 Fail					X	X													X																		
Burnham & Morrill																																					
1 Bean Pot Circle																																					
Portland, Maine 04103																																					