

City of Portland, Maine - Building or Use Permit Application
 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0145	ISSUE DATE PERMIT ISSUED	PBL: 317 B005001
Owner Name: Reynolds Marianne M	Owner Address: Po Box 99	Phone: FEB 18 2005
Business Name: Air Temp	Contractor Name: 11 Wallace Ave South Portland	Phone: 207 774 2500
Lessee/Buyer's Name:	Permit Type: HVAC	Zone: -D4

Past Use: Commercial	Proposed Use: Commercial/ Install a Bryant Direct vent natural gas heater	Permit Fee: \$129.00	Cost of Work: \$12,000.00	CEO District: 5
FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied Use Group: <input checked="" type="checkbox"/> <input type="checkbox"/>		Signature: <i>[Signature]</i> Date: <i>2/17/05</i> Type: <i>HVAC</i>		
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____				

Permit Taken By: ldobson	Date Applied For: 02/08/2005	Zoning Approval		
Proposed Project Description: Install a Bryant Direct vent natural gas heater	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	Date: <i>2/16/05</i> <i>[Signature]</i>

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT _____ ADDRESS _____ DATE _____ PHONE _____

RESPONSIBLE PERSON IN CHARGE OF WORK. TITLE _____ DATE _____ PHONE _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0145 Date Applied For: 02/08/2005 CBL: 317 B005001

Location of Construction: 375 Riverside St	Owner Name: Reynolds Marianne M	Owner Address: Po Box 99	Phone:
Business Name:	Contractor Name: Air Temp	Contractor Address: 11 Wallace Ave South Portland	Phone: (207) 774-2300
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Commercial/ Install a Bryant Direct vent natural gas heater	Proposed Project Description: Install a Bryant Direct vent natural gas heater
--	--

Dept: Zoning Status: Approved Reviewer: Jeanine Bourke Approval Date: 02/16/2005
Note: Ok to Issue:

Dept: Building Status: Approved Reviewer: Jeanine Bourke Approval Date: 02/17/2005
Note: 2/16/05 spoke w/Ron M. @ Patco for engineer statement for load on roof structurals. He will fax. 2/17 received fax, ok to issue Ok to Issue:

1) The installation must comply with the State of Maine Gas Regulations.

Dept: Fire Status: Approved Reviewer: Lt. MacDougal Approval Date: 02/16/2005
Note: Ok to Issue:



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

317 B.S.

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 375 Riverside Use of Building Retail Date 2/2/05
 Name and address of owner of appliance BZ Moose Harbor 375 Riverside
Portland, ME 04103
 Installer's name and address AIRTEMP 11 Wallace Ave.
S. Portland, ME 04106 Telephone 887-774-2300

Location of appliance:

- Basement Floor
 Attic Roof

Type of Fuel:

- Gas Oil Solid

Appliance Name: Bryant

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

Type of Chimney:

- Masonry Lined
 Factory built _____

Metal

Factory Built U.L. Listing # _____

Direct Vent

Type PVC

UL# _____

Type of Fuel Tank

- Oil NONE
 Gas Natural Gas

Size of Tank N/A

Number of Tanks N/A

Distance from Tank to Center of Flame N/A feet.

Cost of Work: \$ 12.00

Permit Fee: \$ _____

The Type of License of Installer:

- Master Plumber # _____
 Solid Fuel # _____
 Oil # _____
 Gas # PAT-1977
 Other _____

Approved

Fire: [Signature]


Ele.: _____

Bldg.: [Signature]

Signature of Installer [Signature]

Inspector's Signature _____

Date Approved _____





Fax Transmittal

To: Portland Cole Refinement Attn: Samie Bonke
 Date: 2/17/05 Fax: 874-8716
 From: Ron Whorries No. of pages: 2


(including cover sheet)

Message:

Samie,

Here is doc. For Big Moose

*Thanks
Ron*



Varco Pruden Buildings, Inc.
WISCONSIN SERVICE CENTER
ENGINEERING GROUP

Date: 02/16/2005

To: Jason Gartner w/ Patco Contracting

Copy:

Fax: number of pages 1

Copy fax:

From: Carl W. Walker, PE
WI Service Center

ph: 608-882-5001 ext. 415
fax: 608-882-2370
e-mail: cwalker@vp.com

SUBJECT: WI0401125

Hanging unit heaters

Please be advised the hanging of unit heaters on the above subject job will not affect the structural integrity of the purlins if the heater is attached in a manner to meet VP detail EN10A1.

If you have any further questions, please let us know.

