

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

PERMIT ISSUED	
Permit No: 05-1621	Issue Date: NOV 0 2005
City: ME	Zone: 072 A003001

Location of Construction: 601 Danforth St	Owner Name: Merrill Industries Inc	Owner Address: 601 Danforth St	Phone:
Business Name: Lessee/Buyer's Name	Contractor Name: Protoc, Inc.	Contractor Address: 216 Lafayette Road N Hampton	Phone: 6039644921
	Phone:	Permit Type: HVAC	Zone:

Past Use: Commercial	Proposed Use: Commercial/ install a Applied Air Direct Vent heating system	Permit Fee: \$66.00	Cost of Work: \$4,950.00	CEO District: 3
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	Type: HVAC

Proposed Project Description:
install a Applied Air Direct Vent heating system

Signature: *Wesley* Signature: *State Gas Regs*
 PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
 Action: Approved Approved w/Conditions Denied
 Signature: _____ Date: _____

Permit Taken By: *Idobson* Date Applied For: 11/04/2005

Zoning Approval

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p>Major <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>Date: _____</p>	<p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>	<p>Historic Preservation</p> <p><input type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>
---	--	--	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT _____ ADDRESS _____ DATE _____ PHONE _____

RESPONSIBLE PERSON IN CHARGE OF WORK TITLE _____ DATE _____ PHONE _____

ELECTRICAL PERMIT

City of Portland, Me.




To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 11/2/05
 Permit # 2005-5096
 CBL# 72A3

LOCATION: 601 DAWFORTH ST. METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER SPARGUE ENERGY
 TENANT SPARGUE ENERGY PHONE # 722-3254

		TOTAL EACH FEE	
OUTLETS	16 Receptacles	7 Switches	12 Smoke Detector
			20
FIXTURES	Incandescent	39 Fluorescent	Strips
			20
SERVICES	1 Overhead	Underground	TTL AMPS <800
		Underground	>800
Temporary Service	Overhead	Underground	TTL AMPS
			25.00
METERS	(number of)	(PLUMBING METERED)	25.00
MOTORS	12 (number of)		1.00
RESID/COM	Electric units	Interior	2.00
HEATING	1 oil/gas units	Exterior	1.00
APPLIANCES	Ranges	Wall Ovens	5.00
	Insta-Hot	Fans	2.00
	Dryers	Water heaters	2.00
	Compactors	Disposals	2.00
	Others (denote)	Spa	2.00
MISC. (number of)	Air Cond/win	Washing Machine	2.00
	Air Cond/cent	Pools	3.00
	HVAC	Thermostats	10.00
	Signs		5.00
	Alarms/res		10.00
	Alarms/com		5.00
	Heavy Duty(CRKT)		15.00
	Circus/Carnv		2.00
	Alterations		25.00
	Fire Repairs		5.00
	E Lights		15.00
	E Generators		1.00
			20.00
PANELS	1 Service	Remote	
TRANSFORMER	0-25 Kva	Main	4.00
	1 25-200 Kva		5.00
	Over 200 Kva		8.00
			10.00
	MINIMUM FEE/COMMERCIAL 45.00	TOTAL AMOUNT DUE	79.50
		MINIMUM FEE	35.00




CONTRACTORS NAME Milliken Bros, INC MASTER LIC. # 45600RD399
 ADDRESS 414 RIVERSIDE RD PORTLAND, ME LIMITED LIC. # _____
 TELEPHONE 757-6375

SIGNATURE OF CONTRACTOR _____
 White Copy - Office • Yellow Copy - Applicant



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 601 South Street

Name and address of owner of appliance METALL MAINE TRUMBER (SYSTEMS CORP)

601A WASHINGTON ST PORTLAND ME 04103

Installer's name and address HOPE INC

116 WASHINGTON LN WILHAMTON NH 03046 Telephone 603 964 9421

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Applied Air

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # DN1 3306
- Other _____

Approved

Fire: _____

Ele.: _____

Bldg.: _____

Signature of Installer _____

Type of Chimney:

- Masonry Lined
- Factory built _____

Metal

Factory Built U.L. Listing # _____

Direct Vent

Type 146A 430SS U.L.# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 9950.00

Permit Fee: \$ 75.00

Approved with Conditions

See attached letter or requirement

Inspector's Signature _____

Date Approved _____

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

PERMIT ISSUED	NOV 9 2005
	CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 601 Danforth Street Use of Building Paper Storage Date 11/3/05
 Name and address of owner of appliance MERRILL MAINE TERMINAL (SPRINKLE COMPANY)
601A DANFORTH ST. PORTLAND, ME 04103
 Installer's name and address 11071 INC,
216 CARRIETTE LN. WARRINGTON ME 04093 Telephone 603 964 9421

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Applied Air

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PVT 3306
- Other _____

Type of Chimney:

- Masonry Lined
- Factory built _____

- Metal

Factory Built U.L. Listing # _____

- Direct Vent

Type 1464 43055 U.L.# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet

Cost of Work: \$ 9950.00

Permit Fee: \$ 75.00

Approved

Approved with Conditions

See attached letter or requirement

Fire: _____

Ele.: _____

Bldg.: _____

Signature of Installer

Inspector's Signature

Date Approved

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No:	05-1621	Date Applied For:	11/04/2005	CBL:	072 A003001
------------	---------	-------------------	------------	------	-------------

Location of Construction:	601 Danforth St	Owner Name:	Merrill Industries Inc	Owner Address:	601 Danforth St	Phone:	
Business Name:		Contractor Name:	Protoc, Inc.	Contractor Address:	216 Lafayette Road N Hampton	Phone	(603) 964-9421
Lessee/Buyer's Name		Phone:		Permit Type:	HVAC		

Proposed Use:	Commercial/ install a Applied Air Direct Vent heating system	Proposed Project Description:	install a Applied Air Direct Vent heating system
---------------	--	-------------------------------	--

Dept: Zoning	Status: Not Applicable	Reviewer: Tammy Munson	Approval Date: 11/09/2005	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Dept: Building	Status: Approved with Conditions	Reviewer: Tammy Munson	Approval Date: 11/09/2005	Ok to Issue: <input checked="" type="checkbox"/>
Note:	1) The installation must comply with the State of Maine Gas Regulations.			
Dept: Fire	Status: Approved with Conditions	Reviewer: Cptn Greg Cass	Approval Date: 11/07/2005	Ok to Issue: <input checked="" type="checkbox"/>
Note:	1) Install to comply with NFPA 54			



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 Danforth St

Issued to Merrill Industries, Inc.

Date of Issue 13 October 1995

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 950865, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Marine Terminal

w/Storage Building

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

10-12-95

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

Check with the MS Dept

SLM/S



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601A Danforth St

Issued to Merrill Industries

Date of Issue 06 May 1997

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 970142, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Office Building

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

4/28/97 Tammy Munson
(Date) Inspector

[Signature]
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

[Handwritten initials]



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 Danforth St CBL 072 A003001

Issued to Merrill Industries Inc/Merrill Industries, Inc Date of Issue 11/26/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 02-0739, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Use Group S2
Type 2C 1999 BOCA

Limiting Conditions:

See Attached Permit Conditions
TEMP C/O Site work must be approved By Jay Reynolds on or prior to 6/1/03.

This certificate supersedes certificate issued

Approved:

11/26/02
(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

M.C.
PER
MJA
HM7



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 Danforth St

CBL 072 A003001

Issued to Merrill Industries Inc/Merrill Industries, Inc

Date of Issue 11/26/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 02-0739, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Use Group S2
Type 2C 1999 BOCA

Limiting Conditions:

See Attached Permit Conditions

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

~~12/10/02~~
12/16/02



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 DANFORTH ST CBL 072 A003001

Issued to MERRILL INDUSTRIES INC /Cianbro Corp. Date of Issue 11/23/2005

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 05-0630, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire RUBB Building 7

APPROVED OCCUPANCY

S2 Occupancy ONLY/Non--sprinkled
Type 2B Construction
2003 International Building Code

Limiting Conditions:

This structure is limited to S2 type occupancies as defined by the 2003 IBC. The ONLY exception is rolled newsprint stacked as prescribed by the Portland Fire Department. Temporary C/O Expires 6/1/06

This certificate supersedes
certificate issued

Approved:

11/23/05
(Date)

[Signature]
Inspector

[Signature] 11/23/05
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 601 DANFORTH ST

CBL 072 A003001

Issued to MERRILL INDUSTRIES INC /Cianbro Corp.

Date of Issue 01/25/2006

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 05-0630, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Rubb Building #7

APPROVED OCCUPANCY

S-2 Occupancy only
Type 2B
2003 IBC Code

Limiting Conditions:

none

This certificate supersedes
certificate issued

Approved:

1-25-06 *Kenneth Wing*
Inspector

(Date)

[Signature]
Inspector of Buildings

JLK
P.F.D. 1/27/06

2006 01/25-6/06

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

City of Portland, Maine
Inspections Division
Inspection Schedule by Date
Appointment Date Between 1/1/2003 And 12/15/2009

Time	Inspector	Type	Address	Contact	Census Parcel/AppID	Phone	Status:	Score:
Date 06/07/2004								
6:00 AM		Footings/Setbacks	601 DANFORTH ST		072 A003001			
Comments: Early A.M. If possible 772-3254 ext 113 Walter					AppID: 40677			
Outcome:								
6:00 AM		Inspection	601 Danforth St		072 A003001			
Comments: underground plumbing 799-2228 Tricia early a.m.					AppID: 20048193			
Outcome:								
Date 07/14/2005								
6:00 AM	Marland Wing	Inspection	601 DANFORTH ST		072 A003001			
Comments: Footing Inspection Bruce 939-2373					AppID: 50630			
Outcome:								
Date 07/26/2005								
6:00 AM	Marland Wing	Foundation/Backfill	601 DANFORTH ST		072 A003001			
Comments: 939-2373 Bruce					AppID: 50630			
Outcome:								
Date 08/03/2005								
6:00 AM	Tom Markley	Foundation/Backfill	601 DANFORTH ST		072 A003001			
Comments: Bruce 939-2373					AppID: 50630			
Outcome:								
Date 08/05/2005								
6:00 AM	Tom Markley	Foundation/Backfill	601 DANFORTH ST		072 A003001			
Comments:					AppID: 0			
Outcome:								
Date 08/12/2005								

City of Portland, Maine
Inspections Division
Inspection Schedule by Date

Appointment Date Between 1/1/2003 And 12/15/2009

Time	Inspector	Type		Address	Contact	Census Parcel/AppID	Phone	
6:00 AM	Tom Markley	Foundation/Backfill	Prmt	601 DANFORTH ST	Cianbro Corp.	072 A003001	(207) 773-5852	(207) 773-5852
Comments: go to trailer						AppID: 50630	Status:	Score:
Outcome:								
Date 08/19/2005								
6:00 AM	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001		
Comments:						AppID: 50630	Status:	Score:
Outcome:								
Date 08/24/2005								
6:00 AM	Tom Markley	Foundation/Backfill	Prmt	601 DANFORTH ST		072 A003001		
Comments: Bruce 9392373						AppID: 50630	Status:	Score:
Outcome:								
Date 08/26/2005								
6:00 AM	Marland Wing	Foundation/Backfill	Prmt	601 DANFORTH ST		072 A003001		
Comments: 939-2373 call Bruce						AppID: 50630	Status:	Score:
Outcome:								
Date 08/30/2005								
6:00 AM	Marland Wing	Foundation/Backfill	Prmt	601 DANFORTH ST		072 A003001		
Comments: anytime in AM						AppID: 50630	Status:	Score:
Outcome:								
Date 09/01/2005								
6:00 AM	Tom Markley	Foundation/Backfill	Prmt	601 DANFORTH ST	Cianbro Corp.	072 A003001	(207) 773-5852	(207) 773-5852
Comments:						AppID: 50630	Status:	Score:
Outcome:								
Date 09/09/2005								

City of Portland, Maine
Inspections Division
Inspection Schedule by Date

Appointment Date Between 1/1/2003 And 12/15/2009

Time	Inspector	Type		Address	Contact	Census Parcel/AppID	Phone		
6:00 AM	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments: Bruce 939-2373						AppID: 50630	Status:	Score:	
Outcome:									
6:00 AM	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments: Bruce 9392373 sometime in AM						AppID: 50630	Status:	Score:	
Outcome:									
Date 09/14/2005									
6:00 AM	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments:						AppID: 50630	Status:	Score:	
Outcome:									
Date 11/21/2005									
10:30 AM	Michael Collins	Certificate of Occupancy/Final	Prmt	601 DANFORTH ST	Cianbro Corp.	072 A003001	(207) 773-5852		
Comments: Pre C/O Please Call P.D. Merrill at 846-0100 for a time certian						AppID: 50630	Status:	Score:	
Outcome:									
10:30 AM	Peter Merrow	Certificate of Occupancy/Final	Prmt	601 DANFORTH ST	Cianbro Corp.	072 A003001	(207) 773-5852		
Comments: Pre C/O Please Call P.D. Merrill at 846-0100 for a time certian						AppID: 50630	Status:	Score:	
Outcome:									
10:30 AM	Jay Kelley	Certificate of Occupancy/Final	Prmt	601 DANFORTH ST	Cianbro Corp.	072 A003001	(207) 773-5852		
Comments: Pre C/O Please Call P.D. Merrill at 846-0100 for a time certian						AppID: 50630	Status:	Score:	
Outcome:									
Date 11/29/2005									
11:30 PM	Jeanie Bourke	Inspection	Complaint	601 DANFORTH ST		072 A003001			
Comments: Sound check at the Merrill Marine Terminal @ 11:30PM						AppID: 0	Status:	Score:	
Outcome:									
Date 01/05/2006									

City of Portland, Maine
Inspections Division
Inspection Schedule by Date

Appointment Date Between 1/1/2003 And 12/15/2009

Time	Inspector	Type		Address	Contact	Census Parcel/AppID	Phone		
	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments:	Follow up to see if Guards have been corrected (see letter in file)					AppID:	50630	Status:	Score:
Outcome:									
Date 01/19/2006									
9:30 AM	Michael Collins	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments:						AppID:	50630	Status:	Score:
Outcome:									
9:30 AM	Marland Wing	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments:						AppID:	50630	Status:	Score:
Outcome:									
9:30 AM	Jay Kelley	Inspection	Prmt	601 DANFORTH ST		072 A003001			
Comments:						AppID:	50630	Status:	Score:
Outcome:									
Date 03/07/2006									
8:30 PM	Jeanie Bourke	Inspection	Prmt	601 Danforth St		072 A003001			
Comments:	Sound check at PD Merrill Marine Terminal for train noise, also at top of Danforth St. At condos from 11pm - 1am					AppID:	0	Status:	Score:
Outcome:									
Date 03/08/2006									
6:00 AM	Jeanie Bourke	Certificate of Occupancy/Final	Prmt	601 DANFORTH ST		072 A003001			
Comments:	Final for additional Structural support 772-3254 ext 113 Walter					AppID:	60229	Status:	Score:
Outcome:									
Date 03/23/2007									
6:00 AM	Tom Markley	Pre-Demolition Inspection	Prmt	601 DANFORTH ST	Costello Dismantling Co., Inc.	072 A003001	(508) 946-0880	(508) 946-0880	
Comments:	Call Walter Watson @ 772-3254 ext 113					AppID:	70292	Status:	Score:
Outcome:									

Appointments Reported: 26

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND PERMIT ISSUED

Please Read Application And Notes, If Any, Attached


This is to certify that MERRILL INDUSTRIES INC
has permission to Add a newsprint warehouse,
AT 601 DANFORTH ST

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

OTHER REQUIRED APPROVALS
re Dept. Capital Construction 6-6-05
alth Dept.
Appeal Board
ther

Department Name



Permit Number: 25663005

CITY OF PORTLAND
insulated heated or reinforced concrete pad

072 A003001

inspection must be made by a licensed inspector in accordance with the provisions of the Statutes of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

Andrew Stokols
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

PERMIT ISSUED

Permit No: 05-0630
 Issue Date: JUN 21 2005
 CE#: 072 A003001

Location of Construction: 601 DANFORTH ST	Owner Name: MERRILL INDUSTRIES INC
Business Name:	Contractor Name: Ciabro Corp.
Lessee/Buyer's Name:	Phone:
Past Use: Marine Terminal	Proposed Use: Marine Terminal / Add a newsprint warehouse, Vinyl glad galvanized steel frame, insulated heated on reinforced concrete pad
Proposed Project Description: Add a newsprint warehouse, Vinyl glad galvanized steel frame, insulated heated on reinforced concrete pad	
Owner Address: 601 DANFORTH ST	City of Portland Street: Portland Phone: 2077735852
Contractor Address: 328 W. Commercial	Permit Type: Additions - Commercial
Permit Fee: \$21,711.00	Cost of Work: \$2,410,000.00
CEO District: 3	Zone: WPA

FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>with conditions</i>	INSPECTION: Use Group: S2 Type: 226 <i>6/22/05</i>
Signature: <i>[Signature]</i>	Signature: <i>[Signature]</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.):	
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	Date:

Permit Taken By: Idobson	Date Applied For: 05/20/2005	Zoning Approval	
<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.</p>	<p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland <i>NA</i></p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone <i>Zone 16</i></p> <p><input type="checkbox"/> Subdivision</p> <p><input checked="" type="checkbox"/> Site Plan # 2005-0002 Major <input checked="" type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> <i>OK with conditions</i></p> <p>Date: <i>6/21/05</i></p>	<p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p>	<p>Historic Preservation</p> <p><input checked="" type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied <i>[Signature]</i></p> <p>Date:</p>

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	ADDRESS	DATE	PHONE

7-7-05 West wall form to
rebar. installed OK to pour

7-15-05 Checked East wall for
footing

Pour rebar installed

7-26-05 Checked OK to pour and
footings OK to pour and

8/3/05 - checked loading dock wall after backfill

OK - checked formot rebar for left side

Wall OK - to pour. Jan M

8/12/05 - check foundation walls for backfill -
Backfill for

NO problems seen OK to ~~pour~~ pour. Jan M
8-19-05 checked ~~footings~~ walls OK to pour. Jan M

8/24/05 - checked foundation area for backfill (pour)

NO issues seen. OK to pour. Jan M

8-26-05 Started forming steel structure
and still pouring foundation
walls on north side MW

All Purpose Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: 601 DANFORTH ST (NW PAD)	
Total Square Footage of Proposed Structure 54,570 sq	Square Footage of Lot 1,263,210
Tax Assessor's Chart, Block & Lot Chart# 7Z Block# A Lot# 3,7,15	Owner: MERRILL INDUSTRIES INC Telephone: 207 846 0100
Lessee/Buyer's Name (if Applicable)	Applicant name, address & telephone: MERRILL INDUSTRIES INC 114 Eben Hill Road Yermouth, ME 04096
Current use: MARINE TERMINAL	Cost Of Work: \$ 2,410,000 Fee: \$ 2,170
If the location is currently vacant, what was prior use: _____	
Approximately how long has it been vacant: _____	
Proposed use: NEW PRINT WAREHOUSE	
Project description: Vinyl clad, galvanized steel frame, insulated and heated on reinforced concrete pad.	
Contractor's name, address & telephone: CANBRO, CORP 366 W Commercial St 773-5852 RUBB BUILDING SYSTEMS P.O. Box 711 324-2577	
Who should we contact when the permit is ready: PD. MERRILL	
Mailing address: 114 Eben Hill Road Yermouth, ME 04096	
We will contact you by phone when the permit is ready. You must come in and pick up the permit and review the requirements before starting any work, with a Plan Reviewer. A stop work order will be issued and a \$100.00 fee if any work starts before the permit is picked up. PHONE: 846-0100	

IF THE REQUIRED INFORMATION IS NOT INCLUDED IN THE SUBMISSIONS THE PERMIT WILL BE AUTOMATICALLY DENIED AT THE DISCRETION OF THE BUILDING/PLANNING DEPARTMENT, WE MAY REQUIRE ADDITIONAL INFORMATION IN ORDER TO APPROVE THIS PERMIT.

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:  Date: **May 20, 2001**

This is NOT a permit, you may not commence ANY work until the permit is issued.
If you are in a Historic District you may be subject to additional permitting and fees with the Planning Department on the 4th floor of City Hall.

RUBB, INC.
 P.O. Box 711
 Sanford Municipal Airport
 Sanford, ME 04073
 Phone: (207)324-2877

Handwritten signatures and initials:
 \$300
 \$150
 \$150
 10/6/05

Letter of Transmittal

Date: 12/2/05 | Job No. 05014
 Attention: Mike Nugent
 Regarding: Merrills

Phone: 207-874-8716
 Fax:

Mr. Mike Nugent
 Inspection Services Manager City of Portland
 389 Congress Street
 Portland, Me. 04101

- Shop Drawings
- Color Prints
- Calculations
- Samples
- Specifications
- Copy of Letter
- Diskettes
- Inspection Reports

We are sending you: Attached Under separate cover via FedEx the following items:

DRAWING #	COPIES	REV.	DESCRIPTION	DRAWN	APPROVED
--	1	--	WELD EXAMINATION REPORTS 12 PAGES	--	--
--	1	--	INSPECTION RECORD	--	--
--	7 SETS	--	PURCHASE ORDERS, INVOICES, AND TEST RESULTS	--	--

These are transmitted as checked below:

- For approval
- For review and comment
- For your use
- As requested
- Approved as submitted
- Approved as noted
- For fabrication
- Returned for corrections
- Resubmit copies for approval
- Submit copies for distribution
- Return approved prints
- For bids due
- Prints returned after loan to us
- copy of each print for your records

Remarks:

copy to: file SIGNED: Michelle Hood for Gary Sutryn

if enclosures are not as noted, kindly notify us at once.

WELD EXAMINATION REPORT

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/12/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
1	G7R	roof	40477	OK
1	G2F	roof	40477	OK
1	G3F	roof	40476	OK
1	G4F	roof	40475	OK
1	G5F	roof	40475	OK
1	G6F	roof	40476	OK
1	G7F	roof	40477	OK
1	B2	roof	40502	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent	<i>Mike Parent</i>	9/12/05
Inspector:	Print Name	Signature	Date
	Fred Smalley	<i>Fred Smalley</i>	9/14/05



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May 2005

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/8/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
2	B3	Roof	40501	OK
2	B4	Roof	40500	OK
2	B5	Roof	40500	OK
2	B6	Roof	40501	OK
2	B7	Roof	40502	OK
2	T2	Roof	40505	OK
2	T3	Roof	40504	OK
2	T4	Roof	40503	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/8/05
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/8/05

FIGURE 1

WELD EXAMINATION REPORT

Job Number: 05114	Customer Specifications: AWS D1.1:2004
Customer Name: MERRILL	Acceptance: AWS D1.1:2004
Date of Examination: 9/9/05	Procedure: VISUAL

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
4	CA1 L	CANOPY TRUS	40634	OK
4	CA1 R	CANOPY TRUS	40634	OK
3	CA2	CANOPY TRUSS PERLIN	40558	OK
4	CA3	CANOPY MID PERLIN	40558	OK
3	CA4	CANOPY COMPRESS PERLIN	40558	OK
1	C11	INNER MID Vertical	40669	OK
2	C13	Vertical	40671	OK
1	C14	LOWER Vertical COMPMN	40672	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages



Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/9/05
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/9/05

FIGURE 1



WELD EXAMINATION REPORT

Form No. 73
Rev. A
Date: May, 2005

Job Number: 05014
 Customer Name: Metzrell
 Date of Examination: 9/13/05
 Scope: Visual weld inspection performed on 100% of weld items listed below.

Customer Specifications: AWS D1.1:2004

Acceptance: AWS D1.1:2004

Procedure: Visual

QTY	ID	DESC.	DWG. #	STATUS
4	H11-H14	Outer Horizontal	40677	OK
2	H5	Gable Horizontal	40643	OK
3	H1,2,3,4,6	Gable Horizontal	40643	OK
1	H7, H7A	Outer Horizontal	40643	FAILED
2	H8, H8A	"	40643	OK
2	H9, H9A	"	40644	OK
2	H10, H10A	"	40644	OK
		"	40644	OK
		"	40644	OK
		"	40644	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

2 H5 weld size to small

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector: _____
 Inspector: _____
 Print Name: Mike Parent
 Print Name: Fred Smalley
 Signature: [Signature]
 Signature: [Signature]
 Date: 9/13/05
 Date: 9/14/05

FIGURE 1

Job Number: 05014	Customer Specifications: AWS D1.1:2004
Customer Name: MERBELL	Acceptance: AWS D1.1:2004
Date of Examination: 9/10/05	Procedure: VISUAL

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
4	P1	HIGH LIFT DOOR TOP TRIMMER	40553	OK
4	D2R	HIGH LIFT DOOR SIDE	40553	OK
3	P2L	" "	40553	OK
1	P3	SIDE TRIMMER w/ ACCESS LEG	40553	OK
4	D4	VERTICAL CHAIR BRICE	40553	OK
9	A14-A16	HEADERS & AXIAL TUBE	40553	OK
4	A3L	LEG BEND AXIAL w/ CORNER LEG	40553	OK
2	C12	VERTICAL	40670	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name Mike Parent	Signature <i>Mike Parent</i>	Date 9/10/05
Inspector:	Print Name Fred Smalley	Signature <i>Fred Smalley</i>	Date 9/10/05

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/15/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
18	M2	roof	40470	OK
18	M3	roof	40244	OK
18	M4	roof	40469	OK
1	G2R	roof	40477	OK
1	G3R	roof	40476	OK
1	G4R	roof	40475	OK
1	G5R	roof	40475	OK
1	G6R	roof	40476	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages



Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/15/05
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/15/05

FIGURE 1



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May 2005

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/7/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
1	GBR	leg	40467	OK
1	GIF	leg	40467	OK
1	GBF	leg	40467	OK
2	B1	leg	40243	OK
2	B8	leg	40243	OK
2	T1	leg	40507	OK
2	T8	leg	40507	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/7/05
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/2/05

FIGURE 1



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May, 2005

Job Number:	05D14	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/17/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG #	STATUS
28	II7	Peak Packet Tube	70589	OK
12	M1	leg	40243	OK
2	M5	leg	40243	OK
1	M6	leg	40243	OK
1	M7	leg	40556	OK
1	M8	leg	40555	OK
1	M9	leg	40243	OK
1	GIR	leg	40467	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name Mike Parent	Signature <i>Mike Parent</i>	Date 9/17/05
Inspector:	Print Name Fred Smalley	Signature <i>Fred Smalley</i>	Date 9/17/05

FIGURE 1



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May 2005

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/12/08	Procedure:	Visual

Scope:— Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
2	T5	roof	40503	OK
2	T6	roof	40504	OK
2	T7	roof	40505	OK
2	X8	Cable plate	37690	OK
2	A18	Clamps	39393	OK
1	A12	Underjint	40246	OK
204	A11	ension tube	40246	OK
		Longitudinal	40246	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/12/08
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/12/08

FIGURE 1



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May 2005

Job Number: 05014	Customer Specifications: AWS D1.1:2004
Customer Name: MERRILL	Acceptance: AWS D1.1:2004
Date of Examination: 9/3/05	Procedure: VISUAL

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
1	C15	SIDE DOOR TRIMME	40676	OK
2	C1	CENTER VERT	40635	OK
2	C2	INNER MID VERT	40636	OK
2	C3	INNER MID VERT	40637	OK
2	C4	INNER MID VERT	40638	FAIL
2	C5	INNER MID VERT	40639	OK
2	C4	INNER MID VERT	40638	OK
1	C6	INNER MID VERTICAL	40640	OK

*

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

2 C4 MISSING Item # 4 LUGS

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name Mike Parent	Signature 	Date 9/3/05
Inspector:	Print Name Fred Smalley	Signature 	Date 9/3/05

FIGURE 1



WELD EXAMINATION REPORT

Form No. 75
Rev. A
Date: May 2005

Job Number:	05014	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/10/06	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
4	A1	Peak Axial Frame	40247	OK
27	A2	Non Peak Axial Frame	40245	OK
20	A3	Leg Bend Axial Tube	40245	OK
60	A4	Non Peak Axial Tube	40245	OK
24	A5	Compression Tube	40246	OK
47	A6	Leg Node	40246	OK
10	A7	Peak Axial Tube	40247	OK
24	A8	Roof Node	40246	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/10/06
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/10/06

FIGURE 1

WELD EXAMINATION REPORT

Job Number:	05114	Customer Specifications:	AWS D1.1:2004
Customer Name:	Merrill	Acceptance:	AWS D1.1:2004
Date of Examination:	9/8/05	Procedure:	Visual

Scope: Visual weld inspection performed on 100% of weld items listed below.

QTY	ID	DESC.	DWG. #	STATUS
229	A9	Undersirt	40246	OK
33	A10	Node Undersirt	40246	OK
68	A17	Flange Undersirt	40246	OK
30	P1-P6	Perimeter Tubes	40550	OK
2	C7L/C1R	INNER MID Vertical	40655	OK
2	C8L/C8R	INNER MID Vertical	40656	OK
2	C9L/C9R	INNER MID Vertical	40657	OK
1	C10	INNER MID Vertical	40658	OK

Results:

All Welded assemblies listed above meet the requirements of AWS D1.1 for visual inspection.

Equipment Used:

Flashlight & Weld Gages

Assistant Inspector:	Print Name	Signature	Date
	Mike Parent		9/8/05
Inspector:	Print Name	Signature	Date
	Fred Smalley		9/8/05

FIGURE 1

We Cover The World.



BUILDING SYSTEMS

COPY

INSPECTION RECORD

Order Number:

Drawing No.	Description	Fabricated by	Checked by	Date
40221	L-3 perimeter	MD	SAG	5-23-05
40217	L-3 Tringirder	MD NA	SAG	6-7-05
40230	Westinghouse leg	MD NB	SAG	6-6-05
40259	Westinghouse Peak Frame	JT	SAG	6-13-05
40364	L-3 Tail door	MP CL	SAG	6-20-05
38630	CHAM roof	MD NB	SAG	6-27-05
40114	L-3 Vertical	MP MD	SAG	7-5-05
40170	Merrill roof 3	MP DS	SAG	7-11-05
38620	CHAM leg	NB DS	SAG	7-18-05
30007	Stack THA Roof	JS	SAG	7-23-05
40243	Merrill leg	JT	SAG	7-22-05
38654	CHAM Axial frame	MD B	SAG	8-7-05
40246	Merrill roof long	DS JS	SAG	8-8-05
40245	Merrill leg head Frame	DS JS	SAG	8-15-05
40550	Merrill Perimeter Tube	JS DS	SEB	8-22-05
40638	Merrill Gable Vertical	MD JS	SAG	8-29-05
40643	Merrill Gable Horizontal	MP NB	SAG	9-6-05
40634	Merrill Canopy	MP JS	SAG	9-12-05
40660	CHAM leg	MP	SAG	9-19-05
40678	ABEL Const Gable Vert	CC	SAG	9-26-05
40773	NYCT Roof	CC RC	SAG	9-30-05
40708	BuXT leg	CC	SAG	10-10-5
40773	NYCT leg	MP CC	SAG	10-17-05
40803	North Branch roof	DS JS	SAG	10-24-05
40826	North Branch Ground	JT DS	SAG	10-31-05
40861	North Branch leg	MP SSMT	SAG	11-8-05
40899	North Branch Axial frame	DS JS	SAG	11-7-05
40901	Alberic roof	CC MD	SAG	11-22-05

File Ref.: G:\AMIPRO\DOCS\US09001\QP8.SAM

Form No. 80 Rev. A



AN INTERNATIONAL COMPANY

We Cover The World.®



BUILDING SYSTEMS

November 23, 2005

Mr. Mike Nugent
 Inspection Services Manager
 City of Portland
 389 Congress Street
 Portland, ME 04101

RUBB, INC.

P.O. Box 711, 1 Rubb Lane
 Sanford, Maine 04073 USA
 Tel: 207 324 2877
 Fax: 207 324 2347
 E-mail: info@rubbusa.com

By Telefax: 207-874-8716

Re: "Merrill 7" Rubb Structure

Dear Mike:

Rubb, Inc. has designed, fabricated and installed the Merrill 7 Rubb structure to meet the requirements of IBC 2003.

All of the special inspections listed in the attached Statement of Special Inspections and Seismic Quality Plan have been completed satisfactorily.

If you have any questions please feel free to give me a call.

Best Regards,
 Rubb, Inc.

Gary E. Sutryn, P.E.
 Chief Engineer



AN INTERNATIONAL COMPANY

RUBB BUILDINGS LTD.
 Tel: +44 191 482 2211
 Fax: +44 181 482 2516

RUBB MOTOR AS
 Tel: +47 55 315032
 Fax: +47 55 317510



Rubb Inc., Sanford, Me. 04073

Statement of Special Inspections

Page 1 of 4

Project: MERRILL 7 STRUCTURE

Location: MERRILL MARINE TERMINAL, PORTLAND, ME.

Owner: SPRAGUE ENERGY

Design Professional in Responsible Charge: GARY E. SUTRYN, P.E.

This *Statement of Special Inspections* is submitted as a condition for permit issuance in accordance with the Special Inspection and Structural Testing requirements of the Building Code. It includes a schedule of Special Inspections applicable to this project and the name(s) of the Special Inspectors and the identity of other approved agencies (if any) to be retained for conducting these inspections and tests. This *Statement of Special Inspections* encompass the following disciplines:

- Structural
- Architectural
- Mechanical/Electrical/Plumbing
- Other:


A *Final Report of Special Inspections* documenting completion of all required Special Inspections, testing and correction of any discrepancies noted in the inspections shall be submitted prior to issuance of a Certificate of Use and Occupancy.

Prepared by:

GARY E. SUTRYN, P.E.
(type or print name)

[Signature]
Signature

6/14/05
Date



Schedule of Inspection and Testing Agencies

Page 2 of 4

This Statement of Special Inspections / Quality Assurance Plan includes the following building systems:

- | | |
|--|--|
| <input type="checkbox"/> Soils and Foundations
<input type="checkbox"/> Cast-in-Place Concrete
<input type="checkbox"/> Precast Concrete
<input type="checkbox"/> Masonry
<input checked="" type="checkbox"/> Structural Steel
<input type="checkbox"/> Cold-Formed Steel Framing | <input type="checkbox"/> Spray Fire Resistant Material
<input type="checkbox"/> Wood Construction
<input type="checkbox"/> Exterior Insulation and Finish System
<input type="checkbox"/> Mechanical & Electrical Systems
<input type="checkbox"/> Architectural Systems
<input type="checkbox"/> Special Cases |
|--|--|

Special Inspector	Firm	Address, Telephone, e-mail
1.	GARY SUTRYN RUBB INC.	SANTORD, ME. 207-324-2877
2.		
3.		
4. Testing Agency (if applic.)		
5. Testing Agency (if applic.)		
6. Other		

Note: The special inspections and testing will be performed by qualified Rubb personnel unless another firm is designated in the above table.

Quality Assurance Plan

Quality Assurance for Seismic Resistance

Seismic Design Category **D**

Quality Assurance Plan Required (Y/N) **YES**

Description of seismic force resisting system and designated seismic systems:

ORDINARY STEEL CONCENTRIC BRACED FRAMES

Quality Assurance for Wind Requirements

Basic Wind Speed (3 second gust) **100 MPH**

Wind Exposure Category **C**

Quality Assurance Plan Required (Y/N) **NO**

Description of wind force resisting system and designated wind resisting components:

ORDINARY STEEL CONCENTRIC BRACED FRAMES.

Statement of Responsibility

Each contractor responsible for the construction or fabrication of a system or component designated above must submit a Statement of Responsibility.

Structural Steel

Page 4 of 4

Special Inspection	Inspection frequency	Scope
1. Fabricator Certification/ Quality Control Procedures	One time report.	Review shop fabrication and quality control procedures.
2. Material Certification	One time report.	Review certified mill test reports, bolt certification and weld electrode certifications. Provide structural steel vendor information (name, etc.)
3. Bolting	Intermittent.	Inspect installation and tightening of pre-tensioned high-strength bolts.
4. Welding	100 % visual inspection.	Visually inspect all welds. Verify size and length of fillet welds.
5. Structural Details	Inspect sample each week.	Inspect steel frame for compliance with structural drawings, including bracing, member configuration and connection details.

RUBB INC., Sanford, Me. 04073

SEISMIC QUALITY PLAN

Page 1 of 3

Project: *Merrill 7 structure*

Location: *Merrill Marine Terminal, Portland, Me.*

Owner: *Sprague Energy*

Design Professional in Responsible Charge: *Gary E. Sutryn, P.E.*

This *Seismic Quality Plan* is submitted prior to commencement of structure fabrication as required in the Building Code. This *Seismic Quality Plan* encompasses the following disciplines:

- X Structural
- Architectural
- Mechanical/Electrical/Plumbing
- Other:

A final letter of completion documenting satisfactory completion of all Seismic Quality Plan requirements shall be submitted prior to issuance of a Certificate of Use and Occupancy.

Prepared by:


GARY E. SUTRYN

(Type or print name)

Gary E. Sutryn / *6/17/05*

Signature

Date



RUBB INC., Sanford, Me. 04073

SEISMIC QUALITY PLAN – Rubb Structures

Page 2 of 3

DESIGNATED SEISMIC FORCE RESISTING SYSTEMS:

- A) Truss arch spans – resists side to side seismic forces.
- B) Bracing cables and compression purlins in the braced bays – resists end to end seismic forces.

SPECIAL INSPECTIONS REQUIRED: See also attached table.

- 1.) Review quality control procedures.
- 2.) Review purchased material certifications.
- 3.) Inspect installation of pre-tensioned high strength bolts.
- 4.) Welding:
 - 100 % visual inspection of all welds.
 - welding performed according to AWS D1.1
 - use only qualified welders
 - follow written welding procedures.
- 5.) Inspect completed structural components to verify compliance with construction drawings.

DOCUMENTATION REQUIRED TO SUBMIT TO BUILDING OFFICIAL:

- material certifications for structural steel, structural bolts and welding electrode.
- vendor names of structural steel suppliers.
- statement of responsibility.
- letter of completion of requirements in this plan.

RUBB INC., Sanford, Me. 04075

Seismic Quality Plan – Seismic systems

Page 3 of 3

Special Inspection	Inspection frequency	Scope
1. Fabricator Certification/ Quality Control Procedures	One time report.	Review shop fabrication and quality control procedures.
2. Material Certification	One time report.	Review certified mill test reports, bolt certification and weld electrode certifications. Provide structural steel vendor information (name, etc.)
3. Bolting	Intermittent.	Inspect installation and tightening of pre-tensioned high-strength bolts.
4. Welding	100 % visual inspection.	Visually inspect all welds. Verify size and length of fillet welds.
5. Structural Details	Inspect sample each week.	Inspect steel frame for compliance with structural drawings, including bracing member configuration and connection details.