

COMMENTS

11-14: Met Dwight Brackett / Contractor @ site to review required inspections for Set back, Foundation, framing, pty, Elect. Etc. ; importance of BOCA?? Compliance. SKW.

11-20-2K Met @ Site w/ Contractor & explained that a surveyors letter stating proper location of Foundation will be required. SKW.

12-5-2K: Inspected Footing Drain & Foundation Sealer; OK to back fill. SKW

12-15-2K: Issued Stop Work Order due to Grading Change & foundation Change to Daylight Basement w/o Amendment to Plans SKW.

2/5/01 - Amendment for
See Amended permit # 010031

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

010004

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

342 A JAN 23 1971

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the 107 laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 5785 Margie's home Use of Building Residential Date 1/12/71
Name and address of owner of appliance Dorothy Conduccion

Installer's name and address Tracy Dackman 19 Charles St
5785 Margie's home 8405 Telephone (207) 252-2523

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Water Space

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # 41520067677
- Gas # _____
- Other _____

Type of Chimney:

- Masonry Lined
- Factory built _____

- Metal

Factory Built U.L. Listing # _____

Direct Vent

Type Alum Panel

U.L. # _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 275

Number of Tanks 1

Distance from Tank to Center of Flame _____ feet

Cost of Work: \$ 5500.00

Permit Fee: \$ 30.00

See attached letter or requirement

Approved

Approved with Conditions

Fire: _____
Elec.: _____
Bldg.: _____

Inspector's Signature _____

Date Approved _____

Signature of Installer _____

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

010069

342 A JAN 27 1983

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 5785 Propagie Lane Use of Building Residential Date 1/12/83
Name and address of owner of appliance Bracket Endline Lane

Installer's name and address Timothy D. Johnson 19 Clearborn St
Biddeford Maine 04005 Telephone (207) 252-2523

Location of appliance:
 Basement Floor
 Attic Roof

Type of Fuel:
 Gas Oil Solid

Appliance Name: Weslo Wrac
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 415200067677
 Gas # _____
 Other _____

Approved

Fire: _____
Ele.: _____
Bldg.: _____

Type of Chimney:
 Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type Weslo Wrac U.L. # _____

Type of Fuel Tank
 Oil
 Gas

Size of Tank 275

Number of Tanks 1

Distance from Tank to Center of Flame _____ feet

Cost of Work: \$ 5,500.00

Permit Fee: \$ 30.00

See attached letter or requirement

Approved with Conditions

Inspector's Signature _____ Date Approved _____

Signature of Installer _____



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

010059
2/6/01
24

342 A 2029

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 3765 Magazine Ave Use of Building Date 1/12/01
Name and address of owner of appliance Barbet Embury Hall

Installer's name and address Tommy D'Andrea 19 Clara Bar St
Billedon rd 6405 Telephone (207) 282-2523

Location of appliance:
 Basement Floor
 Attic Roof

Type of Fuel:
 Gas Oil Solid

Appliance Name: New base
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

If NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 41520087677
 Gas # _____
 Other _____

Approved

Fire: _____
Ele.: _____
Bldg.: _____

Signature of Installer _____

Type of Chimney:
 Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type New base U.L. # _____
Standard
Type of Fuel Tank:
 Oil Gas

Size of Tank: 275

Number of Tanks: 1

Distance from Tank to Center of Flame: 8 feet

Cost of Work: \$ 5500.00

Permit Fee: \$ 30.00

See attached letter or requirement
Approved with Conditions

Inspector's Signature _____ Date Approved _____



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

010070
2/6/2001
CA

349 A
JAN 29 2001

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL _____ Use of Building _____ Date 1/11/01
Name and address of owner of appliance 2000-7677

Installer's name and address _____ Telephone _____
2000-7677

Location of appliance:
 Basement Floor
 Attic Roof

Type of Fuel:
 Gas Oil Solid

Appliance Name: _____
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 5000-7677
 Gas # _____
 Other _____

Type of Chimney:
 Masonry Lined
Factory built _____

Metal
Factory Built U.L. Listing # _____

Direct Vent
Type Water U.L.# _____

Type of Fuel Tank
 Oil
 Gas

Size of Tank 75
Number of Tanks 1

Distance from Tank to Center of Flame _____ feet

Cost of Work: \$ 5500.00
Permit Fee: \$ 100.00

Approved with Conditions
 See attached letter or requirement

Fire: Approved
Elec.: _____
Bldg.: _____

Signature of Installer _____ Inspector's Signature _____ Date Approved _____

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

TO: Inspections

FROM: Jay Reynolds, Development Review Coordinator

DATE: April 12, 2001

RE: C. of O. for # 59-61 Maggie Lane (342-A-011011)

After visiting #59-61 Maggie Lane, I found the following:

1. Landscaping Incomplete.
2. Final Grading/Loam and Seed Incomplete.
3. The driveway is not paved.

Due to the time of year, it is not possible to complete these items. I would estimate that these items could be completed by June 30, 2001. Once these items are addressed and re-inspected, then a permanent Certificate of Occupancy can be issued.

At this time, I **recommend issuing a temporary Certificate of Occupancy.**

Please contact me if you have any questions or comments.
Thank You.

Cc: Sarah Hopkins, Development Review Services Manager

File: O:\drc\5961maggie1.doc