

City of Portland, Maine - Building or Use Permit Application
 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

PERMIT ISSUED

Permit No: 04-0726 Issue Date: JUN 04 2004 CBL: 392 B022001

Owner Name: Volger Theodore J Jr &
 1705 Washington AVENUE OF PORTLAND Phone:
 Contractor Name: John Ross Heating
 41 Middle Rd. Cumberland Phone: 2078294248
 Lessee/Buyer's Name: HVAC Zone: R-2

Permit Fee: \$66.00 Cost of Work: \$5,000.00 CEO District: 5

FIRE DEPT: Approved Denied

INSPECTION: Use Group: R-3 Type: Heating
 Signature: Bob Mechanical 1993

Signature: [Signature]
 PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
 Action: Approved Approved w/Conditions Denied
 Signature: [Signature] Date: [Blank]

Location of Construction:
 161 Hope Ave
 Business Name:
 Lessee/Buyer's Name:

Past Use:
 Single Family Home

Proposed Use:
 Single Family Home/ Install a Peerless/ beckett Boiler w/ 275 gal oil tank

Proposed Project Description:
 Single Family Home/ Install a Peerless/ beckett Boiler w/ 275 gal oil tank

6/4/04
Bob P
[Signature]

Permit Taken By:
 Idobson

1. This permit applicant(s) from Federal Rules.
2. Building permits, septic or electrical
3. Building permits within six (6) months
 False information permit and stop a

Zoning Approval

Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review
 Approved
 Approved w/Conditions
 Denied

Date: 6/4/04

PERMIT ISSUED
 JUN 04 2004
 CITY OF PORTLAND

Maj Minor MM
 Date: 6/4/04

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT _____ ADDRESS _____ DATE _____ PHONE _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ DATE _____ PHONE _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-0726 Date Applied For: 06/03/2004 CBL: 392 B022001

| | | | |
|---|---------------------------------------|---|--------------------------|
| Location of Construction: 161 Hope Ave | Owner Name: Volger Theodore J Jr & | Owner Address: 1705 Washington Ave | Phone: |
| Business Name: | Contractor Name: John Ross Heating | Contractor Address: 41 Middle Rd. Cumberland | Phone: (207) 829-4248 |
| Lessee/Buyer's Name | Phone: | Permit Type: HVAC | |

| | |
|---|---|
| Proposed Use: Single Family Home/ Install a Peerless/ beckett Boiler w/ 275 gal oil tank | Proposed Project Description: Single Family Home/ Install a Peerless/ beckett Boiler w/ 275 gal oil tank |
|---|---|

Dept: Zoning Status: Approved Reviewer: Tammy Munson Approval Date: 06/04/2004
Note: Ok to Issue:


Dept: Building Status: Approved with Conditions Reviewer: Tammy Munson Approval Date: 06/04/2004
Note: Ok to Issue:

1) Installation shall comply with 1993 BOCA Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules



392 B 022
FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL _____ Use of Building Res. Date 6/1/04
Name and address of owner of appliance 161 Hope Ave (valget)

Installer's name and address John Ross Hearty
41 Middle Rd Cumberland area Telephone 822-4248

Location of appliance: Basement Floor Roof
 Attic

Type of Fuel: Gas Oil Solid
 Gas


Appliance Name: Ross / Beckett
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 4585
 Gas # _____
 Other _____

Type of Chimney: Masonry Lined
Factory built _____
 Metal
Factory Built U.L. Listing # _____
 Direct Vent
Type _____
Type of Fuel Tank Oil Gas
Size of Tank _____
Number of Tanks 1
Distance from Tank to Center of Flame 5 feet.
Cost of Work: \$ 5,000
Permit Fee: \$ 110



Approved
Fire: _____
Ele.: _____
Bldg.: _____
Approved with Conditions
 See attached letter or requirement

Signature of Installer John Ross Hearty Inspector's Signature _____ Date Approved _____
White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy



392 B 022
FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL _____ Use of Building Res. Date 6/1/04
Name and address of owner of appliance 161 Hope Ave (Volpet)

Installer's name and address John Ross Heating
41 Middle Rd Scarborough, ME Telephone 823-4248

Location of appliance: Basement Floor Attic Roof
Type of Chimney: Masonry Lined Factory built

Type of Fuel: Gas Oil Solid
Appliance Name: Pro Boss / Beckett
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No
IF NO Explain: _____

The Type of License of Installer: _____
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 4585
 Gas # _____
 Other _____
Size of Tank _____ UL# _____
Number of Tanks 1
Distance from Tank to Center of Flame _____ feet.
Cost of Work: \$ 5000
Permit Fee: \$ 160


Approved Approved with Conditions
Fire: _____ See attached letter or requirement
Elec.: _____
Bldg.: _____
Signature of Installer [Signature] Inspector's Signature _____ Date Approved _____

392 B 002

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL _____ Use of Building Res. Date 6/1/04
Name and address of owner of appliance 161 Hope Ave (Volper)

Installer's name and address John Ross Henry Telephone 823-1248
41 Middle Rd Cumberland

Location of appliance: Basement Floor Attic Roof

Type of Fuel: Gas Oil Solid

Appliance Name: Res & Bus / Boilers
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 4585
 Gas # _____
 Other _____

Type of Chimney:

Masonry Lined
 Factory built

Metal

Factory Built U.L. Listing # _____

Direct Vent

Type _____ U.L.# _____

Type of Fuel Tank

Oil

Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 2000

Permit Fee: \$ 160.00

Approved

See attached letter or requirement


Fire: _____
Ele.: _____
Bldg.: _____
Inspector's Signature _____ Date Approved _____

Signature of Installer John Ross Henry
White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL _____ Use of Building Res Date 6/1/04
Name and address of owner of appliance 161 N. Main Ave

Installer's name and address Tom Coe Plumbing
221 11705 rd Telephone 422-1300

Location of appliance: Basement Floor Attic Roof

Type of Fuel: Gas Oil Solid

Appliance Name: Boiler / Radiator
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:
 Master Plumber # _____
 Solid Fuel # _____
 Oil # 11005
 Gas # _____
 Other _____

Type of Chimney: Masonry Lined Factory built
 Metal Factory Built U.L. Listing # _____
 Direct Vent Type _____ UL# _____
Type of Fuel Tank Oil Gas
Size of Tank 33
Number of Tanks 1
Distance from Tank to Center of Flame _____ feet.
Cost of Work: \$ 11000
Permit Fee: \$ 11000

Approved _____ Approved with Conditions _____
Fire: _____ See attached letter or requirement
Ele.: _____
Bldg.: _____

Signature of Installer Tom Coe Inspector's Signature _____ Date Approved _____
White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

$F_y = 36 \text{ ksi}$

BEAMS

W Shapes

Allowable uniform loads in kips
for beams laterally supported

For beams laterally unsupported, see page 2-146

W 12



| Designation | W 12 | | | W 12 | | | W 12 | | | | Deflection In. | |
|--------------|--------|------|------|-------|-------|-------|------|------|------|------|-------------------|------|
| | Wt./ft | 50 | 45 | 40 | 35 | 30 | 26 | 22 | 19 | 16 | | 14 |
| Flange Width | 8 1/2 | 8 | 8 | 6 1/2 | 6 1/2 | 6 1/2 | 4 | 4 | 4 | 4 | | |
| L_c | 8.50 | 8.50 | 8.40 | 6.90 | 6.90 | 6.90 | 4.30 | 4.20 | 4.10 | 3.50 | | |
| L_u | 19.6 | 17.7 | 16.0 | 12.6 | 10.8 | 9.40 | 6.40 | 5.30 | 4.30 | 4.20 | | |
| Span in Feet | 3 | | | | | | | | 76 | 69 | .02 | |
| | 4 | | | | | | 92 | 82 | 68 | 59 | .03 | |
| | 5 | | | | | | | | 80 | 67 | .05 | |
| | 6 | | | | | | | | 67 | 56 | .07 | |
| | 7 | 130 | 116 | | 108 | 92 | 81 | 67 | 56 | 45 | 39 | .10 |
| | 8 | 128 | 115 | 101 | 103 | 87 | 76 | 57 | 48 | 39 | 34 | .13 |
| | 9 | 114 | 102 | 91 | 90 | 76 | 66 | 50 | 42 | 34 | 30 | .17 |
| | 10 | 102 | 92 | 82 | 80 | 68 | 59 | 45 | 37 | 30 | 26 | .20 |
| | 11 | 93 | 84 | 75 | 72 | 61 | 53 | 40 | 34 | 27 | 24 | .25 |
| | 12 | 85 | 77 | 69 | 66 | 56 | 48 | 37 | 31 | 25 | 21 | .29 |
| | 13 | 79 | 71 | 63 | 60 | 51 | 44 | 34 | 28 | 23 | 20 | .35 |
| | 14 | 73 | 66 | 59 | 56 | 47 | 41 | 31 | 26 | 21 | 18 | .40 |
| | 15 | 68 | 61 | 55 | 52 | 44 | 38 | 29 | 24 | 19 | 17 | .46 |
| | 16 | 64 | 58 | 51 | 48 | 41 | 35 | 27 | 22 | 18 | 16 | .52 |
| | 17 | 60 | 54 | 48 | 45 | 38 | 33 | 25 | 21 | 17 | 15 | .59 |
| | 18 | 57 | 51 | 46 | 42 | 36 | 31 | 24 | 20 | 16 | 14 | .66 |
| | 19 | 54 | 48 | 43 | 40 | 34 | 29 | 22 | 19 | 15 | 13 | .74 |
| | 20 | 51 | 46 | 41 | 38 | 32 | 27 | 21 | 18 | 14 | 12 | .82 |
| | 21 | 49 | 44 | 39 | 36 | 31 | 26 | 20 | 1 | 14 | 12 | .90 |
| | 22 | 47 | 42 | 37 | 34 | 29 | 24 | 19 | 1 | 13 | 11 | .99 |
| | 23 | 45 | 40 | 36 | 33 | 28 | 24 | 18 | 15 | 12 | 11 | 1.08 |
| | 24 | 43 | 38 | 34 | 31 | 27 | 23 | 17 | 15 | 12 | 10 | 1.18 |
| | 25 | 41 | 37 | 33 | 30 | 25 | 22 | 17 | 14 | 11 | 10 | 1.28 |
| | 26 | 39 | 35 | 32 | 29 | 24 | 21 | 16 | 13 | 11 | 9 | 1.38 |
| | 28 | 37 | 33 | 29 | 28 | 24 | 20 | 15 | 13 | 10 | 9 | 1.61 |
| | 30 | 34 | 31 | 27 | 26 | 22 | 19 | 14 | 12 | 10 | 8 | 1.84 |

Properties and Reaction Values

| | | | | | | | | | | | |
|------------------------|------|------|------|------|------|------|------|------|------|------|---|
| $S_x \text{ in.}^3$ | 64.7 | 58.1 | 51.9 | 45.6 | 38.6 | 33.4 | 25.4 | 21.3 | 17.1 | 14.9 | For explanation of deflection, see page 2-32 |
| $V \text{ kips}$ | 65 | 58 | 51 | 54 | 46 | 40 | 46 | 41 | 38 | 34 | |
| $R_1 \text{ kips}$ | 30.2 | 24.9 | 21.9 | 17.8 | 14.5 | 12.0 | 13.5 | 11.3 | 9.80 | 8.17 | |
| $R_2 \text{ kips/in.}$ | 8.79 | 7.96 | 7.01 | 7.13 | 6.18 | 5.46 | 6.18 | 5.58 | 5.23 | 4.75 | |
| $R_3 \text{ kips}$ | 36.7 | 30.0 | 23.5 | 24.2 | 17.9 | 13.9 | 17.6 | 13.7 | 10.8 | 8.65 | |
| $R_4 \text{ kips/in.}$ | 3.97 | 3.32 | 2.56 | 2.54 | 1.98 | 1.50 | 2.06 | 1.87 | 2.05 | 1.83 | |
| $R \text{ kips}$ | 51 | 42 | 32 | 33 | 25 | 20 | 25 | 20 | 18 | 15 | |

Load above heavy line is limited by maximum allowable web shear.

W 10



W Shapes

Allowable uniform loads in kips
for beams laterally supported

For beams laterally unsupported, see page 2-146

| Designation | W 10 | | | | | | | | Deflect In. | |
|--------------|--------|--------|--------|--------|--------|--------|--------|--------|----------------|--------|
| | Wt./ft | 112 | 100 | 88 | 77 | 68 | 60 | 54 | | 49 |
| Flange Width | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 | 10 3/8 |
| L_c | 11.0 | 10.9 | 10.8 | 10.8 | 10.7 | 10.6 | 10.6 | 10.6 | 10.6 | 10.6 |
| L_u | 53.2 | 48.2 | 43.3 | 38.6 | 34.8 | 31.1 | 28.2 | 26.0 | | |
| Span in Feet | 8 | 247 | 217 | 189 | 162 | 141 | 124 | 108 | 98 | 1.1 |
| | 9 | 222 | 197 | 173 | 151 | 133 | 117 | 106 | 96 | 1.2 |
| | 10 | 200 | 177 | 156 | 136 | 120 | 106 | 95 | 86 | 1.3 |
| | 11 | 181 | 161 | 142 | 124 | 109 | 96 | 86 | 79 | 1.4 |
| | 12 | 166 | 148 | 130 | 113 | 100 | 88 | 79 | 72 | 1.5 |
| | 13 | 154 | 136 | 120 | 105 | 92 | 81 | 73 | 67 | 1.6 |
| | 14 | 143 | 127 | 111 | 97 | 86 | 75 | 68 | 62 | 1.7 |
| | 15 | 133 | 118 | 104 | 91 | 80 | 70 | 63 | 58 | 1.8 |
| | 16 | 125 | 111 | 98 | 85 | 75 | 66 | 59 | 54 | 1.9 |
| | 17 | 117 | 104 | 92 | 80 | 71 | 62 | 56 | 51 | 2.0 |
| | 18 | 111 | 99 | 87 | 76 | 67 | 59 | 53 | 48 | 2.1 |
| | 19 | 105 | 93 | 82 | 72 | 63 | 56 | 50 | 46 | 2.2 |
| | 20 | 100 | 89 | 78 | 68 | 60 | 53 | 48 | 43 | 2.3 |
| | 21 | 95 | 84 | 74 | 65 | 57 | 50 | 45 | 41 | 2.4 |
| | 22 | 91 | 81 | 71 | 62 | 55 | 48 | 43 | 39 | 2.5 |
| | 23 | 87 | 77 | 68 | 59 | 52 | 46 | 41 | 38 | 2.6 |
| | 24 | 83 | 74 | 65 | 57 | 50 | 44 | 40 | 36 | 2.7 |

Properties and Reaction Values

| | | | | | | | | | |
|------------------------|------|------|------|------|------|------|------|------|--------------------------------|
| $S_x \text{ in.}^3$ | 126 | 112 | 98.5 | 85.9 | 75.7 | 66.7 | 60.0 | 54.6 | F expla of def see pe |
| $V \text{ kips}$ | 124 | 109 | 94 | 81 | 70 | 62 | 54 | 49 | |
| $R_1 \text{ kips}$ | 84.1 | 70.7 | 58.4 | 47.2 | 38.4 | 32.7 | 27.5 | 24.0 | |
| $R_2 \text{ kips/in.}$ | 17.9 | 16.2 | 14.4 | 12.6 | 11.2 | 9.98 | 8.79 | 8.08 | |
| $R_3 \text{ kips}$ | 150 | 121 | 95.5 | 73.4 | 57.7 | 45.8 | 36.0 | 30.3 | |
| $R_4 \text{ kips/in.}$ | 18.5 | 15.5 | 12.6 | 9.88 | 7.93 | 6.52 | 5.00 | 4.30 | |
| $R \text{ kips}$ | 147 | 127 | 109 | 91 | 78 | 68 | 54 | 45 | |

Load above heavy line is limited by maximum allowable web shear.
Values of R in bold face exceed maximum web shear V .

**STATE OF MAINE
CHIMNEY OR FIREPLACE CONSTRUCTION/INSTALLATION
DISCLOSURE**

Dear Consumer: State law, specifically 32 M.R.S.A., Chapter 33, §2313-A, requires that chimney or fireplace installers, as of January 1, 1992, provide you with this "Disclosure" prior to the installation or construction of your chimney or fireplace. The purpose of this Disclosure is to inform you that the National Fire Protection Standard #211 (NFPA #211) is the current standard which applies to all new construction of chimneys and fireplaces. Please to note that the State of Maine does not require registration or licensure of chimney or fireplace installers. It is important to realize that many fires are caused each year from improperly constructed fireplaces and chimneys. This disclosure form should help you in making an informed decision as to the abilities of the installer and under what requirements the installation must comply.

INSTALLER INFORMATION

Name of Installer FRANK Di DONATO
D.B.A. F. DiDonato & Sons MASONRY
Name of Installer (if incorporated) _____
D.B.A. _____
Legal Address 87 SKYLARK Rd PORTLAND, ME
(Street and No.) (City or Town)
MAINE CUMBERLAND 04103
(State) (County) (Zip Code)
Home Telephone 207 1797 13098 Business Telephone SAME
Years of experience doing fireplace or chimney installations _____

CONSUMER IDENTIFICATION

Consumer's Name DAVE Thoyt
Mailing Address _____
(Street and No.) (City or Town)
Home Telephone 1 1 Business Telephone 1 1
(State) (County) (Zip Code)

Installer, please give a brief description of installation being offered.

ALL MASONRY FIREPLACE AND CHIMNEY WITH FIRE BRICK AND HEAT STOP REFRACTORY CEMENT IN FIRE BOX CLAY FLUE LINERS, CLAY BRICK AND CONCRETE BLOCK.

I, FRANK DiDONATO, the installer, hereby attest that the preceding information provided is true to the best of my knowledge. I also understand that if I fail to conform with the standards as outlined in NFPA #211 that I shall be subject to penalties as outlined under Title 32, Chapter 33, and the Oil and Solid Fuel Board Rules.

Signature Frank DiDonato Date 3-2-04

INSTALLATION STANDARDS

The 1996 Edition of NFPA #211 contains provisions for chimney, fireplaces, venting systems, and solid fuel burning appliances including their installations. The standards applies to residential as well as commercial and industrial installations.

PLEASE CHECK THE TYPE OF CONSTRUCTION TO BE BUILT:

- Factory-Built Chimney and Chimney Units.**
Factory-built chimney and chimney units shall be listed and installed in accordance with the temperature conditions of the listing, the manufacturer's instructions and all applicable sections of NFPA #211.
- Factory-Built Fireplaces.**
Factory-built fireplaces shall be listed and shall be installed in accordance with the terms of the listing. Hearth combustible construction in accordance with applicable sections of NFPA #211.
- Unlisted Metal Chimney (smokestacks) for Non Residential Applications.**
Single wall metal chimneys or unlisted metal chimneys shall not be used inside or outside of one and two family dwellings. Metal chimneys shall be constructed and installed in accordance with the appropriate sections of NFPA #211
- Masonry Chimney.**
Masonry chimneys shall be constructed by appropriate sections of NFPA #211 for proper design, support, re-enforced, and installation.
- Masonry Fireplace.**
Masonry fireplaces shall comply with all requirements of NFPA #211 and all other pertinent sections.

CONSUMER CHECKLIST

1. Has the installer provided you with a written contract? 10 M.R.S.A., Chapter 219-A requires written contracts for any home remodeling or construction with an estimated cost in excess of \$1,400.
2. Have you asked the local fire department or code enforcement officials to inspect the installation during and after construction?
3. Is the installer familiar with current NFPA #211 standards and does he have a copy of same?
4. Have you asked for references to be provided by the installer?

TO: Inspections Department
FROM: Jay Reynolds, Development Review Coordinator
DATE: June 11, 2004
RE: C. of O. for 161 Hope Avenue, Lot 22
(CBL390B022) (ID 2003-0161)

After visiting the site, I have the following comments:

Site work incomplete:
Paving
Final Grading
Landscaping
Loam and Seed

At this time, I recommend issuing a temporary Certificate of Occupancy.
I anticipate this work will be completed by July 1, 2004.

Please contact me if you have any questions or comments.

Cc: Sarah Hopkins, Development Review Services Manager
Mike Nugent, Inspection Services Manager

File: O:\plan\drc\hopelot22a.doc

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK
CITY OF PORTLAND
BUILDING INSPECTION
PERMIT

Please Read Application And Notes, if Any, Attached

Permit Number 20030900
SEP 23 2003

This is to certify that Volger Theodore J Jr & /Paul Volger Ted Volger
has permission to Construct a 30'x40' SF w/10' Breezeby and 12'x24' Attached 2 Car Garage
AT 161 Hope Ave (City of Portland, OR) 392 8022001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification inspection must be given and when permit is issued before this building or enclosed-in-structure notice is required.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____
Health Dept. _____
Appeal Board _____
Other _____
Department Name _____

Carrie Burke 9/25/03
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD