

**City of Portland, Maine - Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

|  |  |   |  |  |                          |
|--|--|---|--|--|--------------------------|
| Location of Construction:<br>33 Summit Street Portland 04103           |  | Owner:<br>* Mark and Frances Payne  |  | Phone:<br>797-4839   | Permit No: <b>990345</b> |
| Owner Address:   |  | Lessee/Buyer's Name:  |  | Phone:   | Business Name:           |
| Contract Name:<br>N/A  |  | Address:<br>100 Larrabee Road Westbrook ME 04092  |  | Phone:   |                          |
| Past Use:<br>1-family  |  | Proposed Use:<br>Same   |  | COST OF WORK:<br>\$ 3,500.00   | PERMIT FEE:<br>\$ 40.00  |
|  |  | FIRE DEPT. <input type="checkbox"/> Approved<br><input type="checkbox"/> Denied   |  | INSPECTION:<br>Use Group: Type:<br>001 111   |                          |
| Proposed Project Description:<br>Construct above ground pool and deck. |  | Signature:  |  | Signature: <i>[Signature]</i>  |                          |
|  |  | PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)<br>Action: Approved <input type="checkbox"/><br>Approved with Conditions: <input type="checkbox"/><br>Denied <input type="checkbox"/> |  | Zoning Approval: <i>[Signature]</i><br>Special Zone or Reviews:<br><input type="checkbox"/> Shoreland<br><input type="checkbox"/> Wetland<br><input type="checkbox"/> Flood Zone<br><input type="checkbox"/> Subdivision<br><input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/> |                          |
| Permit Taken By: SP  |  | Date Applied For: 4-13-99   |  | Zone: CBL: 398-A-008 1/1   |                          |

**PERMIT ISSUED**  
APR 16 1999  
**CITY OF PORTLAND**

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

*owner - 575-6195  
797-4839*

**PERMIT ISSUED  
WITH REQUIREMENTS**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

4-13-99

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

- Zoning Appeal**
- Variance
  - Miscellaneous
  - Conditional Use
  - Interpretation
  - Approved
  - Denied

- Historic Preservation**
- Not in District or Landmark
  - Does Not Require Review
  - Requires Review

- Action:
- Approved
  - Approved with Conditions
  - Denied

Date: *[Signature]*

CEO DISTRICT

2

BUILDING PERMIT REPORT

DATE: 15 APRIL 99 ADDRESS: 53 Summit St. CBL: 398-A-008 s 11

REASON FOR PERMIT: Above ground pool and deck

BUILDING OWNER: Mark & Frances Payne

PERMIT APPLICANT: \_\_\_\_\_

USE GROUP \_\_\_\_\_ BOCA 1996 CONSTRUCTION TYPE \_\_\_\_\_

CONDITIONS OF APPROVAL

This permit is being issued with the understanding that the following conditions are met:


Approved with the following conditions: \*12 \*11 \*13 \*22 \*29 \*32 \*34

- ~~1.~~ This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- ~~2.~~ Before concrete for foundation is placed, approvals from the Department Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- 3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2 Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
- 5. Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code.
- 6. Precast concrete must be taken to protect concrete from freezing. Section 1908.0
- 7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
- 8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)
- 9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
- 10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- ~~11.~~ Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 36" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
- 12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
- ~~13.~~ Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
- 14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (68") 1014.4
- 15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1113mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
- 16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
- 17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

- owner says  
 AHS 1991 - 1' above grade.  
 pool is 5' deep - 1' deep stairs  
 so 5' deep on top of stairs  
 put a door in back  
 to screen it  
 I don't see any work  
 Specs - call work  
 Specs - call work  
 Specs - call work  
 Specs - call work

Sec D

1st floor  
 1st floor  
 1st floor  
 1st floor



AHS 1991 - Fixing to  
 owner says  
 12'1' -  
 12'1' -


- R-2 Zone
- Pool Needs
- 10' x 10' Me
- 10' x 10' Me
- Deck requires
- 12' x 25' - 200' shor
- 12' x 12' - 12' shor
- side 12' x 12' - 20

12'1'  
 12'1'

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE  
PERMIT IS ISSUED**  
**Building or Use Permit Pre-Application**  
**Additions/Alterations/Accessory Structures**  
**To Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the information below for a Building or Use Permit.

**NOTE\*\*If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

|  |  |   |
|--|--|---|
| Location/Address of Construction: <u>53 Summit Street</u> <u>Portland, ME</u> <u>04103</u>             |  |   |
| Tax Assessor's Chart, Block & Lot Number<br>Chart# <u>398</u> Block# <u>A</u> Lot# <u>008</u>          | Owner:<br><u>MORE AND FRANCES PARRIS</u> | Telephone#:<br><u>797-4839</u>                    |
| Owner's Address:<br><u>53 Summit Street</u> <u>Portland, ME</u>  | Lessee/Buyer's Name (if Applicable)      | Cost Of Work: <u>\$ 3500.00</u> Fee: <u>\$ 90</u> |
| Proposed Project Description: (Please be as specific as possible)<br><u>Above Ground Pool and Deck</u> |  |   |
| Contractor's Name, Address & Telephone:<br><u>ALVINCO 100 LINDA BEE RENO WASHINGTON ME 04092</u>       |  |   |
| Rec'd By:         |  |   |

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

• All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.

• All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

• HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

If there is expansion to the structure, a complete plot plan (Site Plan) must include:


- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and porches, as well as, sheds, pools, garages and any other accessory structures.
- Scale and required zoning district setbacks


**4) Building Plans (Sample Attached)**

- A complete set of construction drawings showing all of the following elements of construction.
- Cross Sections w/Framing details (including porches, decks w/ railings, and accessories)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

**Certification**

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

|   |                      |
|---|----------------------|
| Signature of applicant:  | Date: <u>4/13/99</u> |
|---|----------------------|




Building Permit Fee: \$25.00 For the 1st \$1000.00 cost plus \$5.00 per \$1,000.00 construction cost thereafter.

ONSPPCORRESPONDENCE ADADSEID.WPD

398-A-8  
53 Summit St

Pool  
Please Place  
with Porcelain  
22/11/1/99  
OK



OK 10

