

Location of Construction: 340 Allen Ave  
 Owner: Robert Lockard  
 Lessee/Buyer's Name: Robert Lockard  
 Phone: 780-7375  
 Business Name: Robert Lockard  
 Phone: 780-7375

Contractor Name: Resolution Builders, Inc.  
 Address: 69 Auburn St #139 04103  
 Phone: 780-7375  
 Proposed Use: commercial  
 Past Use: commercial

PERMIT ISSUED  
 FEB - 6 1998  
 CITY OF PORTLAND  
 Permit No: 980186

PERMIT ISSUED  
 FEB - 6 1998  
 CITY OF PORTLAND  
 Permit No: 980186

Proposed Project Description: Bathroom Renovations (per plans) Replacing exterior door  
 Permit Taken By: Sherry Plamad  
 Date Applied For: February 27, 1998  
 PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)  
 Action:  Approved  Approved with Conditions  Denied  
 Signature: [Signature] Date: [Date]

Zoning Appeal  
 Variance  
 Miscellaneous  
 Conditional Use  
 Interpretation  
 Approved  
 Denied  
 Zoning Approval: [Signature] CB: 987-E-037  
 Special Zone or Reviews: [Signature]

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.  
 2. Building permits do not include plumbing, septic or electrical work.  
 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.  
 I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.  
 SIGNATURE OF APPLICANT: [Signature]  
 ADDRESS: [Address]  
 DATE: February 27, 1998  
 PHONE: [Phone]

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector  
 PHONE: [Phone]  
 GEO DISTRICT: 7

PERMIT ISSUED WITH REQUIREMENTS

# BUILDING PERMIT REPORT


DATE: 3/5/98 ADDRESS: 340 Allen Ave  
REASON FOR PERMIT: Interior Renovation  
BUILDING OWNER: Robert Lockard  
CONTRACTOR: Solutions Builders Inc.  
PERMIT APPLICANT: Dr. Johnson  
USE GROUP: F-1 BOCA 1996 CONSTRUCTION TYPE

## CONDITION(S) OF APPROVAL

This Permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: \*1 \*8 \*9 \*10 \*17 \*18 \*20

- \*1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". Headroom in habitable space is a minimum of 7'6".
9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread, 7" maximum rise.
10. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
12. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.)
14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the



SECTION. A - A

340 ALLEN AVENUE

SUBWAY

344-E-37

346 ALMA AVE

344-E-57

