

PERMIT ISSUED

City of Portland, Maine - Building or Use Permit Application  
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 01-0641	Issue Date: JUN 8 2001	CBL 409 C030001
-----------------------	---------------------------	--------------------

Location of Construction: 33 Huntington Ave	Owner Name: Stewart Richard III &	Owner Address: 33 Huntington Ave Portland, Me 04101	Phone: 207-797-6649
Business Name: n/a	Contractor Name: no contractor/self	Contractor Address: n/a n/a	Phone
Lessee/Buyer's Name n/a	Phone: n/a	Permit Type: Additions - Dwellings	Zone: R-3
Past Use: Single Family	Proposed Use: Same: Build 419 SqFt Attached Deck. Call Richard at 797-2425 when ready. If he's not at this # try him at 797-2425. <i>pages 750-0756</i>	Permit Fee: \$42.00	Cost of Work: \$2,500.00
Proposed Project Description: Build 419 SqFt Attached Deck		CEO District: 2	FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied
		INSPECTION: Use Group: <i>513</i> <b>PERMIT ISSUED WITH REQUIREMENTS</b> <i>000A/19C/1999</i>	
		Signature: <i>[Signature]</i>	
		Signature: <i>[Signature]</i>	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)	
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	
		Signature: _____ Date: _____	
Permit Taken By: cjh	Date Applied For: 06/05/2001	<b>Zoning Approval</b>	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>6/7/01</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>[Signature]</i>
	<i>to rezoning AS w/ family</i>		

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

01-0641

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED



# All Purpose Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: 33 WASHINGTON AVE. PORTLAND

Total Square Footage of Proposed Structure 419 SF      Square Footage of Lot 8,656

Tax Assessor's Chart, Block & Lot Number  
Chart# 409      Block# ~~2~~      Lot# 30  
Owner: RICHARD & ROBERT STEWART  
Telephone#: ~~797-6649~~  
797-6649  
797-2425

Lessee/Buyer's Name (If Applicable) N/A      Owner's/Purchaser/Lessee Address: N/A  
Cost Of Work: \$ 2500.00      Fee: \$ 42.<sup>00</sup>

Current use: SINGLE FAMILY  
If the location is currently vacant, what was prior use:  
Approximately how long has it been vacant:  
Proposed use: Bldg 419 SF ATTACHED DECK  
Project description: SAME

Contractor's Name, Address & Telephone: SELF  
Applicants Name, Address & Telephone: RICHARD A. STEWART III      797-0649      call 1st      797-2425  
Who should we contact when the permit is ready: RICHARD  
Telephone:  
If you would like the permit mailed, what mailing address should we use:  
CH  
Rec'd By: 6/5

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED**

**PLOT PLAN INCLUDES THE FOLLOWING:**

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches; a bow windows cantilever sections and roof overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and North arrow; Zoning District & Setbacks
- First Floor sill elevation ( based on mean sea level datum);
- Location and dimensions of parking areas and driveways;
- Location and size of both existing utilities in the street and the proposed utilities serving the building;
- Location of areas on the site that will be used to dispose of surface water.
- Existing and proposed grade contours

**A COMPLETE SET OF CONSTRUCTION DRAWINGS INCLUDES THE FOLLOWING:**

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
  - Floor Plans & Elevations
  - Window and door schedules
  - Foundation plans with required drainage and damp proofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

**SEPARATE PERMITS ARE REQUIRED FOR INTERNAL & EXTERNAL PLUMBING, HVAC AND ELECTRICAL INSTALLATIONS**

- All construction must be conducted in compliance with the 1999 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1999 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

Minor/Minor Site Review Fee for New Single Family homes: \$300.00/Building Permit Fee: \$30.00 for the 1st \$1000.cost plus \$6.00 per \$1,000.00 construction cost thereafter.

**ONE SET OF SUBMISSIONS INCLUDING CONSTRUCTION AND SITE PLAN DRAWINGS MUST BE SUBMITTED ON PAPER NO LARGER THAN 11" x 17" BEFORE ANY BUILDING PERMIT WILL BE ISSUED**

**Certification**

*I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.*

Signature of applicant:

*R. J. ...*

Date: 6/5/01

BUILDING PERMIT REPORT

DATE: 6 June 2001 ADDRESS: 33 Huntington Ave CBL: 409-C-030

REASON FOR PERMIT: Deck

BUILDING OWNER: The Stewarts

PERMIT APPLICANT: CONTRACTOR SAO

USE GROUP: A-3 CONSTRUCTION TYPE: 513 CONSTRUCTION COST: 2500.00 PERMIT FEES: 426.00

The City's Adopted Building Code (The BOCA National Building Code/1999 with City Amendments)  
The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions shall be met: \*1, \*2, \*3, \*33, \*35, \*36

- \*1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- \*2. Before concrete for foundation is placed, approval from the ~~Development Review Coordinator and~~ Inspection Services must be obtained. (A 24 hour notice is required prior to inspection) "ALL LOT LINES SHALL BE CLEARLY MARKED BEFORE CALLING."
- 3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- 4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' O.C. between bolts. Section 2305.17
- 5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
- 6. Precaution must be taken to protect concrete and masonry. Concrete Sections 1908.9-19.8.10/ Masonry Sections 2111.3-2111.4.
- 7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
- 8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1999)
- 9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
- 10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- \*11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42". In occupancies in Use Group A, B, H-4, I-1, I-2, M, R, public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. Handrails shall be a minimum of 34" but not more than 38". Exception: Handrails that form part of a guard shall have a height not less than 36 inches (914 mm) and not more than 42 inches (1067 mm). Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0). Handrails shall be on both sides of stairway. (Section 1014.7)
- 12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
- \*13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
- 14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
- 15. The Minimum required width of a corridor shall be determined by the most restrictive of the criteria under section 1011.3 but not less than 36".
- 16. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1010.4)
- 17. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
- 18. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closure's. (Over 3 stories in height requirements for fire rating is two (2) hours. (Section 710.0)
- 19. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)

# ELECTRICAL PERMIT

## City of Portland, Me.




To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical Code and the following specifications:

Date 2/9/06  
 Permit # 06-4115  
 CBL# 409 C 030

LOCATION: 33 Huntington Ave METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # \_\_\_\_\_ OWNER \_\_\_\_\_  
 TENANT STEWART PHONE # 797-6649

				TOTAL EACH FEE	
OUTLETS	Receptacles	Switches	Smoke Detector		.20
FIXTURES	Incandescent	Fluorescent	Strips		.20
SERVICES	Overhead	Underground	TTL AMPS <800		15.00
	Overhead	Underground	>800		25.00
Temporary Service	Overhead	Underground	TTL AMPS		25.00
					25.00
METERS	(number of)				1.00
MOTORS	(number of)				2.00
RESID/COM	Electric units				1.00
HEATING	oil/gas units	Interior	Exterior		5.00
APPLIANCES	Ranges	Cook Tops	Wall Ovens		2.00
	Insta-Hot	Water heaters	Fans		2.00
	Dryers	Disposals	Dishwasher		2.00
	Compaotors	Spa	Washing Machine		2.00
	Others (denote)				2.00
MISC. (number of)	Air Cond/wln				3.00
	Air Cond/cent		Pools		10.00
	HVAC	EMS	Thermostat		5.00
	Signs				10.00
	Alarms/res				5.00
	Alarms/com				15.00
	Heavy Duty(CRKT)				2.00
	Circus/Carnv				25.00
	Alterations				5.00
	Fire Repairs				15.00
	E Lights				1.00
	E Generators				20.00
PANELS	Service	Remote	Main		4.00
TRANSFORMER	0-25 Kva				5.00
	25-200 Kva				8.00
	Over 200 Kva				10.00
				TOTAL AMOUNT DUE	
MINIMUM FEE/COMMERCIAL 45.00				MINIMUM FEE	35.00



CONTRACTORS NAME Matt Hodgins MASTER LIC. # MS 4088763  
 ADDRESS 197 SHERWOOD ST. LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 773-9975

SIGNATURE OF CONTRACTOR Matt Hodgins

White Copy - Office • Yellow Copy - Applicant

\*\*\*\*\*CERTIFICATE OF OCCUPANCY FEE \$50.00

CAD LT. 2000, DXF FORMAT OR EQUIVALENT.  
144.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO  
\*\*\*ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION

CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD. ( You Shall Call for Inspections )  
CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR  
SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE  
WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER  
CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE  
\*\*\*THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE

\*\*This permit is herewith issued, on the basis of plans submitted and conditions placed on these plans, any deviations shall require a separate approval.

PSH 10/1/00

P. Samuel Hoffses, Building Inspector  
C. LE McDougall, PFD  
Marge Schumackal, Zoning Administrator  
Michael Nugent, Inspection Service Manager

- 20. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1999), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements
- 21. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
- 22. The Fire Alarm System shall be installed and maintained to NFPA #72 Standard.
- 23. The Sprinkler System shall be installed and maintained to NFPA #13 Standard.
- 24. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1999)
- 25. Section 25 - 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 26. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
- 27. Ventilation and access shall meet the requirements of Chapter 12 Sections 1210.0 and 1211.0 of the City's Building Code. (Crawl spaces & attics).
- 28. All electrical, plumbing and HVAC permits must be obtained by Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
- 29. All requirements must be met before a final Certificate of Occupancy is issued.
- 30. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).
- 31. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)
- 32. Please read and implement the attached Land Use Zoning report requirements.
- 33. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.
- 34. Bridging shall comply with Section 2305.16.
- 35. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2406.0)
- 36. All flashing shall comply with Section 1406.3.10.
- 37. All signage shall be done in accordance with Section 3102.0 signs of the City's Building Code. (The BOCA National Building Code/1999).

Please note:

The top rail on the deck ~~is~~  
could be 2x4 trying to find 5/4 x 6 x 12  
WESTERN RED CEDAR,

# PLUMBING APPLICATION

Department of Health and Human Services  
Division of Environmental Health

## PROPERTY ADDRESS

Town or Plantation	Portland Me
Street	33 Huntington
Subdivision Lot #	

## PROPERTY OWNERS NAME

Last:	Stewart	First:	Richard
Applicant Name:	David MacWilliams		
Mailing Address of Owner/Applicant (If Different)	119 Skilling St		

PORTLAND PERMIT # 2709 TOWN COPY

Date Permit Issued: 11/25/06 \$ 124.00  Double Fee Charged

*Marlene Wing*  
Local Plumbing Inspector Signature

L.P.I. # 116108

409 C 030

## Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspectors to deny a Permit.

*David E MacWilliams 11/25/06*  
Signature of Owner/Applicant

Date

## Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature

Date Approved

## PERMIT INFORMATION

### This Application is for

- 1.  NEW PLUMBING
- 2.  RELOCATED PLUMBING

### Type of Structure To Be Served:

- 1.  SINGLE FAMILY DWELLING
- 2.  MODULAR OR MOBILE HOME
- 3.  MULTIPLE FAMILY DWELLING
- 4.  OTHER - SPECIFY \_\_\_\_\_

### Plumbing To Be Installed By:

- 1.  MASTER PLUMBER
  - 2.  OIL BURNERMAN
  - 3.  MFG'D. HOUSING DEALER/MECHANIC
  - 4.  PUBLIC UTILITY EMPLOYEE
  - 5.  PROPERTY OWNER
- LICENSE # 108444

### Hook-Up & Piping Relocation Maximum of 1 Hook-Up

HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.

OR

HOOK-UP: to an existing subsurface wastewater disposal system.

PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.

OR

TRANSFER FEE  
[\$6.00]

Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
	Hosebibb / Sillcock	/	Bathtub (and Shower)
	Floor Drain		Shower (Separate)
	Urinal		Sink
	Drinking Fountain		Wash Basin
	Indirect Waste		Water Closet (Toilet)
	Water Treatment Softener, Filter, etc.		Clothes Washer
	Grease / Oil Separator		Dish Washer
	Roof Drain		Garbage Disposal
	Bidet		Laundry Tub
	Other: _____		Water Heater
	Fixtures (Subtotal) Column 2		Fixtures (Subtotal) Column 1
			Fixtures (Subtotal) Column 2
			Total Fixtures
			Fixture Fee
			Transfer Fee
			Hook-Up & Relocal Permit Fee
			(Total)

SEE PERMIT FEE SCHEDULE  
FOR CALCULATING FEE



# BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 to schedule your inspections as agreed upon

Permits expire in 6 months, if the project is not started or ceases for 6 months.

The Owner or their designee is required to notify the inspections office for the following inspections and provide adequate notice. Notice must be called in 48-72 hours in advance in order to schedule an inspection:

By initializing at each inspection time, you are agreeing that you understand the inspection procedure and additional fees from a "Stop Work Order" and "Stop Work Order Release" will be incurred if the procedure is not followed as stated below.

A Pre-construction Meeting will take place upon receipt of your building permit.

- Footing/Building Location Inspection: Prior to pouring concrete
- Re-Bar Schedule Inspection: Prior to pouring concrete
- Foundation Inspection: Prior to placing ANY backfill
- Framing/Rough Plumbing/Electrical: Prior to any insulating or drywalling
- Final/~~Certificate of Occupancy~~: Prior to any occupancy of the structure or use. NOTE: There is a \$75.00 fee per inspection at this point.

Certificate of Occupancy is not required for certain projects. Your inspector can advise you if your project requires a Certificate of Occupancy. All projects DO require a final inspection

If any of the inspections do not occur, the project cannot go on to the next phase, REGARDLESS OF THE NOTICE OR CIRCUMSTANCES.

CERTIFICATE OF OCCUPANCIES MUST BE ISSUED AND PAID FOR, BEFORE THE SPACE MAY BE OCCUPIED

[Signature] 1/30/06  
Signature of Applicant/Designee Date

Donna Martin Admin 1 30 06  
Signature of Inspections Official Date

CBL: 409-C-30 Building Permit #: 06-0115

8/28/01 Pre-con w/ owner's architect.

9/13/01 Checked Footing & setbacks ok to  
Pou. Pre-con w/ contractor on stairs, rails,  
hand rail, spacing etc. Question on whether  
2-2x8's could be used for Beam. Per  
span charts This would be allowable ~~per~~ per the spans  
of the post footings. JB

7/23/02 checked rough framing, no decking in place. still need  
final inspection JB