



CITY OF PORTLAND

JOSEPH E. McDONOUGH
FIRE CHIEF

January 20, 1987

OK
1-29-87

Jack Donovan
13 Portland Road
Gray, ME 04039

Re: Smoke Detectors

Dear Mr. Donovan:

During a recent inspection of the property owned by you at 104 Cumberland Ave., it was noted that smoke detectors were missing in the following areas:

~~BEDROOM, HALL, AND LIVING ROOM - inoperative smoke detector~~

25 M.R.S.A. §2464 requires that approved smoke detectors be installed in each of the above listed areas. Failure to comply with this statute may result in a fine of up to \$500 for each violation.

Re-inspection of your property will be made in ten (10) days. Lack of compliance will result in referral of the matter for legal action.

Sincerely yours,
Joseph E. McDonough
Chief of the Fire Department
City of Portland

Arthur Addato
Arthur Addato, Code Enforcement
Officer (7)

cc: Lt. James Collins, Fire Prevention Bureau

imr