

82 CHESTNUT STREET

REQUEST FOR SERVICE

PORTLAND HEALTH DEPARTMENT


DATE RECEIVED	6-1-82	BY		DISTRICT	3rd	Hayton
REQUEST BY	NAME	Mrs. Scott 772-2490				
	ADDRESS	1 Hall Court				
OWNER	NAME	Mary Kibbee				
	ADDRESS	82 Chestnut				
CONDITIONS	ADDRESS	82 Chestnut				
<p>Says steps + porch in rear threaten to topple onto her property.</p>						
COMMENTS	<p>CNT-6/1/82 1:30PM - GB</p> <p style="text-align: center;">NO.</p>					
SPECIAL INSTRUCTIONS						
DIVISION	SANITATION		HOUSING		NURSING	
PRIORITY	ROUTINE		SPECIAL		BY	
	URGENT		REPORT TO		DATE	

REQUEST FOR SERVICE

PORTLAND HEALTH DEPARTMENT

DATE RECEIVED	3-17-82	BY	Goye	DISTRICT	Bartlett
REQUEST BY	NAME	James Vance - 775-2752			
	ADDRESS	82 Chestnut St.			
OWNER	NAME	Mary Kibbie			
	ADDRESS	Portland			
CONDITIONS	ADDRESS	82 Chestnut St - 2nd Fl. Cockroaches			
COMMENTS	Unsafe stairs, possibly. (Tenant terminated conversation because inspector is sick today and can't make inf. He said he would get a professional carpenter to inspect stairs. Tenant called Sam a few minutes later, says he wants to re-open this complaint.				
SPECIAL INSTRUCTIONS	3/18/82 RNJ (BB)				
DIVISION	SANITATION		HOUSING		NURSING
PRIORITY	ROUTINE		SPECIAL		BY
	URGENT		REPORT TO		DATE

82 CHESTNUT STREET Housing





## CITY OF PORTLAND

JOSEPH E. GRAY, JR.  
DIRECTOR OF PLANNING  
AND URBAN DEVELOPMENT

May 21, 1985

Mary Kibbee  
436 Ocean Avenue  
Portland, ME 04103

RE: Complaint concerning 2nd floor fire escape at  
82 Chestnut Street

Dear Ms. Kibbee:

Evaluation of the above complaint on May 13, 1985 revealed that, although the fire escape is not an object of beauty, structurally it appears to be stable, creating no hazard to the tenants if good judgement is used.

The hand rail must, however, have balusters installed at intervals not exceeding 6 inches on center to eliminate a potential accident hazard. This work should be done no later than June 21, 1985.

Thank you.

Sincerely,

Mike Nugent  
Code Enforcement Officer

MN/kat  
cc: P. Samuel Hoffses

Inspection Services  
Samuel P. Hoffses  
Chief



Planning and Urban Development  
Joseph E. Gray Jr.  
Director

CITY OF PORTLAND

May 1, 1992

Arrow Realty  
198 Lancaster St.  
Portland, ME 04101

Re: 42 Cedar St  
193 Oxford St  
82 Chestnut St 026-A-005 (2 fam)


Dear Mr. Cardente,

A stop work order has been placed on the above because the sewer lines were not capped as per the City's Sewer Department's requirements.

Please contact the Sewer Division and obtain the information necessary to complete the closing of the sewer lines as per their regulations.

If you have any questions regarding this requirement, please do not hesitate to contact this office.

Sincerely,

  
P. Samuel Hoffses  
Chief of Inspection Services

cc: Hugh Irving, Code Enforcement Officer  
Charles Perry, Parks and Public Works  
Carol Polisky, Parks and Public Works