



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

Permit No. 1872

OCT 20 1932

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, October 27, 1932

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 142 Middle Street Use of Building Manufacturing
Name and address of owner Edish Bros. 142 Middle St.
Contractor's name and address Cutler & Cutler, Inc. 186 Federal St. Telephone P 5405

INSPECTION NOT COMPLETED

To install Oil Burning General Description of Work Oil Burning Equipment

CERTIFICATE OF OCCUPANCY OR CLOSING-IN IS WAIVED. REQUIREMENT IS WAIVED.

IF HEATER, POWER BOILER OR COOKING DEVICE
Is heater or source of heat to be in cellar? If not, which story 2d Kind of Fuel Oil
Material of supports of heater or equipment (concrete floor or what kind) wood - to be protected as required by Building Code
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, from top of smoke pipe, from front of heater, from sides or back of heater.

IF OIL BURNER
Name and type of burner Williams Oil-O-Matic
Labeled and approved by Underwriters Laboratories
Will operator be always in attendance? yes
Type of oil feed (gravity or pressure) gravity
Location oil storage basement
No. and capacity of tanks 1 - 275 gal.
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed?

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)
Signature of contractor By [Signature]

INSPECTION COPY

10/29/32

873/A

895

Ward 3 Permit No. 32/1872
 Location 142 Middle St
 Owner Kadick Bros
 Date of permit 10/29/32
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. _____
 Cert. of Occupancy issued _____

NOTES

1. Kind of heat Steam
2. Label
3. Anti-siphon
4. Oil storage
5. Tank distance
6. Vent pipe
7. Fill pipe
8. Gauge
9. Leakage
10. Feet safety
11. Pipe sizes & material
12. Control valve
13. Ash pit vent
14. Temp or pressure safety
15. Instruction card
16. _____

Bodine Electric Co
1/19/32 - Letter - mnd

12/14/32 - Leak around pump. Box on which pump rests is not fastened solidly. Tank sits on wooden floor. Float in auxiliary tank with mercury switch shuts off pump when block of oil in auxiliary tank reaches certain low point. Same pump as ever. Do not believe there is any automatic shut off in case of fire.

12/14/32 - Mr. Cutler to mail copy of letter received from pump manufacturer.

1/27/33 - Letter - mnd

1/28/33 - Mr. David Cutler was in to go over matters in letter. He questioned whether any listed pumps will pump the oil 20 ft. Told him we will write Und. Lab. and get the information. - A.J.L.

General Description of M. E.