

At 24 Portland-Pier-I

April 12, 1949

Mr. L. F. Murray  
Ocean House Road  
Cape Elizabeth, Maine

Subject: Permit for alterations to  
building at 24 Portland Pier

Dear Sir:

The permit for the work as outlined in the application is issued herewith subject to the following:

No indication is made as to the size of headers to be provided over the new show window openings. Lacking this information, the Inspector will check the adequacy of the headers provided at the time of the "closing-in" inspection, notice for which must be given before sheetrock is applied to walls, ceilings or partitions. In case of doubt it might be well to have the adequacy of the headers checked before they are installed.

Very truly yours,

Inspector of Buildings

AJS/0

CC: Mr. Samuel Seiger  
24 Portland Pier