



INDUSTRIAL ZONE APPLICATION FOR PERMIT

PERMIT ISSUED 6957

Class of Building or Type of Structure Gasoline Installation

Portland, Maine, June 27, 1938

JUN 28 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~construct~~ install the following building-structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 220 Commercial Street Within Fire Limits? yes Dist. No. 2

Owner's or Lessee's name and address Williams Express, 220 Commercial St. Telephone _____

Contractor's name and address Harris Oil Co., 17 Main St. So. Portland Telephone 2-8704

Architect _____ Plans filed yes No. of sheets 1

Proposed use of building _____ No. families _____

Other buildings on same lot _____

Estimated cost \$ 500. Fee \$.75

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

To install one 550 gallon tank and one electric pump for gasoline, new installation, private use, tank will bear Underwriters' Label, will be at least 3' below grade, coated with asphaltum, minimum diameter of piping tank to pump.

Storage applied for

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED

Height average grade to top of plate _____

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Framing Lumber—Kind _____ Dressed or Full Size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Owner _____
 By Williams Express
Harris Oil Co.

INSPECTION COPY _____
 Signature of Inspector _____
 By B. J. Harris

CHIEF OF POLICE _____

Rept. 1403C-I

March 14, 1938

Harris Oil Company,
17 Main Street,
South Portland, Maine

Gentlemen:

Enclosed is the permit covering construction of a metal-clad building for a filling station office and the installation of gasoline tanks, pipes, pumps, etc., at the end of Brown's Wharf.

The application for the permit indicates that there is to be no floor in the building other than the deck of the present wharf. If this is the case, the 4x4 sills are satisfactory, if there is to be a floor supported by wooden joists in the building, the sills should be at least 4x6 and all solid in cross-section, that is not built up of one or more members. Please see to it that the woodwork of the building exposed on the exterior is all covered with metal. This includes cornices, corner boards and all wooden trim, except sashes and doors.

Chief Sanborn has approved this permit with the following notations: "Tanks are to have at least three feet of earth around them and a foot of concrete on top. Pipes are to be on top of the wharf with at least three inches of concrete around them."

Please be governed accordingly.

Very truly yours,

Inspector of Buildings

WMcB/n