



## CITY OF PORTLAND

JOSEPH E. GRAY, JR.  
DIRECTOR OF PLANNING  
AND URBAN DEVELOPMENT

January 4, 1983

Consolidated Constructors & Bldrs, Inc.  
106 Commercial Street  
Portland, Maine 04112

Dear Sir:

Your application for making renovations at 193 Middle Street, Portland, Maine has been reviewed and a building permit to make these changes, as per plan, is herewith being issued subject to the following Building and Fire Code requirements:

1. All partitions and doors which enclose the stairway shall be of one hour fire rated material.
2. All fire doors shall be equipped with self closers.

If you have any questions on these requirements, please call this office.

Sincerely,

P. S. HOFFSES,  
CHIEF OF INSPECTION SERVICES

PSH/nlb

CC: File

Lt. Collins