



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

May 25, 1984

Mr. Thomas Moser
Box 60
New Gloucester, Maine 04260

Re: 415 Cumberland Avenue, Portland, Maine


Dear Sir:

Your application to change the use of 415 Cumberland Avenue from vacant space to office with renovations, as per plans, has been reviewed and a building permit is herewith issued subject to the following requirements.

1. The spiral stairs shall comply with Section 5-2.2.1.6 of the 101 Life Safety Code.
2. The apartment shall be equipped with a single station smoke detector powered by the house current.
3. The fire escape shall comply with the requirements of Section 5-2.9 of the 101 Life Safety Code.
4. The boiler room shall be enclosed with one-hour fire rated construction including ceiling and fire door.

If you have any questions on these requirements, please call this office, 775-5451, Ext. 346.

Sincerely,



P. Samuel Hoffses,
Chief of Inspection Services

PSH/jmr

APPLICATION FOR PERMIT

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 568
ZONING LOCATION PORTLAND, MAINE May 14, 1984.

HERMIT ISSUED
MAY 25 1984
CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 415 Cumberland Avenue Attic only Fire District #1 [] #2 []
1. Owner's name and address Thomas Moser - Box 68, New Gloucester, Me. 04260 Telephone 926-4446
2. Lessee's name and address Designer: David Rogers - 217 Main St., Auburn Telephone 782-8331
3. Contractor's name and address owner Telephone

Proposed use of building offices No. of sheets 25
Last use vacant No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot

Estimated contractual cost \$4,000.00 Appeal Fee \$
FIELD INSPECTOR - Mr. 85,000.00 - add. cost. Rowe Base Fee 25.00 Change
@ 775-5451 Late Fee of Use
TOTAL \$ 30.00
\$ 35.00
\$ 25.00 add. cost.

Change of Use from vacant to offices with renovations, as per plans. Attic only. Constructing dormers (2). also to make renovations to 3 floors of building and to construct parking pad.

Stamp of Special Conditions
PERMIT ISSUED WITH LETTER

ISSUE PERMIT TO #1

NOTE TO APPLICANT: separate permits are required by the installers and sub-contractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber - Kind Dressed or full size? Corner posts Sills
Size Girders Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION - PLAN EXAMINER Will work require disturbing of any tree on a public street? no
ZONING: Will there be in charge of the above work a person competent
BUILDING CODE: to see that the State and City requirements pertaining thereto
Fire Dept: are observed? yes
Health Dept:
Others:

Signature of Applicant David P. Rowe Phone #
Type Name of above David Rogers Thomas Moser 2 3 4
Other and Address

PERMIT ISSUED WITH LETTER FIELD INSPECTOR'S COPY

Signature of Field Inspector: M.A. Rowe

APPLICANT'S COPY OFFICE FILE COPY

NOTES

8/7/84 *Wing Sh-*

12/27/84 CSJO enter.

~~Large section of lined paper crossed out with a large X.~~

Permit No. 811568
 Location *Yt Cumberland Ave.*
 Owner *Laonora Myers*
 Date of permit 5-11-84
 Approved 5-25-84
 Dwelling *Change of use*
 Garage
 Alteration



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTION SERVICES
ELECTRICAL INSTALLATIONS

Date Aug. 10, 1984
 Receipt and Permit number B22785

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 415 Cumberland Avenue
 OWNER'S NAME: Thomas Moser ADDRESS: Box 58, Cobbs Bridge Rd., New Gloucester

OUTLETS:		RECEPTACLES	50	SWITCHES	30	PLUGMOLD	_____	ft. TOTAL	80	✓	7.00
FIXTURES: (number of)											
Incandescent		92	Flourescent		_____	(not strip) TOTAL		92	✓	11.20	
Strip Flourescent		_____ ft. _____									
SERVICES:											
Overhead		_____	Underground	x	Temporary	_____	TOTAL amperes	400 - 3-phase	_____	✓	6.00
METERS: (number of)		5									
MOTORS: (number of)											
Fractional		_____									
1 HP or over		_____									
RESIDENTIAL HEATING:											
Oil or Gas (number of units)		_____									
Electric (number of rooms)		_____									
COMMERCIAL OR INDUSTRIAL HEATING:											
Oil or Gas (by a main boiler)		x									
Oil or Gas (by separate units)		_____									
Electric Under 20 kws		_____	Over 20 kws	_____							
APPLIANCES: (number of)											
Ranges	_____	1	Water Heaters	2							
Cook Tops	_____		Disposals	_____							
Wall Ovens	_____		Dishwashers	_____							
Dryers	_____		Compactors	_____							
Fans	_____	2	Others (denote)	_____	✓						
TOTAL		5									
MISCELLANEOUS: (number of)											
Branch Panels		4									
Transformers		_____									
Air Conditioners Central Unit		_____									
Separate Units (windows)		_____									
Signs 20 sq. ft. and under		_____									
Over 20 sq. ft.		_____									
Swimming Pools Above Ground		_____									
In Ground		_____									
Fire/Burglar Alarms Residential		_____									
Commercial		1									
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under		_____									
over 30 amps		_____									
Circus, Fairs, etc.		_____									
Alterations to wires		_____									
Repairs after fire		_____									
Emergency Lights, battery		2									
Emergency Generators		_____									
INSTALLATION FEE DUE:										_____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE:										_____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) :										_____	
TOTAL AMOUNT DUE:										49.20	

INSPECTION:

Will be ready on _____, 19__; or Will Call x

CONTRACTOR'S NAME: Caron's Electric

ADDRESS: 14 Atwood Street, Lewiston, Me.

TEL.: 782-8556

MASTER LICENSE NO.: 4314 SIGNATURE OF CONTRACTOR:

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

Handwritten signature: Robert Caron

APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 0014 33
ZONING LOCATION PORTLAND, MAINE

DEC 10 1985

City Of Portland

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or in all the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION ... 415 Commercial Street ... Fire District #1 [] #2 []
1. Owner's name and address ... Telephone ...
2. Lessee's name and address ... Telephone ...
3. Contractor's name and address ... Telephone ...

Proposed use of building ... No. of stories ...
Last use ... No. families ...
Material ... No. stories ... Heat ... Style of roof ... Roofing ...

Other buildings on same lot ...
Estimated contractual cost \$...
FIELD INSPECTOR—M: ... @ 775-5451
Appeal Fees \$...
Base Fee ... 240.00
Late Fee ...
TOTAL \$...

To complete construction of addition
31' x 50' 2 story as per plans.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? ... Is any electrical work involved in this work? ...
Is connection to be made to public sewer? ... what is proposed for sewage? ...
Has septic tank notice been sent? ... rm notice sent? ...
Height average grade to top of plate ... Height average grade to highest point of roof ...
Size front ... depth ... No. stories ... soil or filled land? ... earth or rock? ...
Material of foundation ... Thickness top ... bottom ... cellar ...
Kind of roof ... Rise per foot ... Roof covering ...
No. of chimneys ... Material of chimneys ... of lining ... Kind of heat ... fuel ...
Framing Lumber—Kind ... Dressed or full size? ... Corner posts ... Sills ...
Size Girder ... Columns under girders ... Size ... Max. on centers ...
Studs (outs de walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor ... 2nd ... 3rd ... roof ...
On centers. 1st floor ... 2nd ... 3rd ... roof ...
Maximum span 1st floor ... 2nd ... 3rd ... roof ...
If one story building with masonry walls, thickness of walls? ... height?

IF A GARAGE

No. cars now accommodated on same lot ... to be accommodated ... number commercial cars to be accommodated ...
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? ...

APPROVALS BY: DATE MISCELLANEOUS
BUILDING INSPECTION—PLAN EXAMINER ... Will work require disturbing of any tree on a public street? ...
ZONING: ...
BUILDING CODE: ... Will there be in charge of the above work a person competent
Fire Dept.: ... to see that the State and City requirements pertaining thereto
Health Dept.: ... are observed? ...
Others: ...

Signature of Applicant ... Phone # 628-4434
Type Name of above: ... 1 [] 2 [] 3 [] 4 []
Other ...
and Address ...

FIELD INSPECTOR'S COPY APPLICANT'S COPY OFFICE FILE COPY



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date March 21, 19 86
 Receipt and Permit number 23498

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine.

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications.

LOCATION OF WORK: 415 Cumberland Avenue - Moser Cabinet
 OWNER'S NAME Thomas Moser ADDRESS: New Gloucester

OUTLETS:		FEES
Receptacles	Switches	Plugmold
ft. TOTAL		
FIXTURES: (number of)		
Incandescent	Flourescent	(not strip) TOTAL
Strip Flourescent	ft.	
SERVICES:		
Overhead <input checked="" type="checkbox"/>	Underground	Temporary
TOTAL amperes		<u>300</u>
METERS: (number of)		<u>3000</u>
MOTORS: (number of)		
Fractional		
1 HP or over		
RESIDENTIAL HEATING:		
Oil or Gas (number of units)		
Electric (number of rooms)		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler)		
Oil or Gas (by separate units)		
Electric Under 20 kws	Over 20 kws	
APPLIANCES: (number of)		
Ranges	Water Heaters	
Cook Tops	Disposals	
Wall Ovens	Dishwashers	
Dryers	Compactors	
Fans	Others (denote)	
TOTAL		
MISCELLANEOUS: (number of)		
Branch Panels <u>1</u>		<u>1.00</u>
Transformers		
Air Conditioners Central Unit		
Separate Units (windows)		
Signs 20 sq. ft. and under		
Over 20 sq. ft.		
Swimming Pools Above Ground		
In Ground		
Fire/Burglar Alarms Residential		
Commercial		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under		
over 30 amps		
Circus, Fairs, etc.		
Alterations to wires <u>alteration to service</u>		<u>2.00</u>
Repairs after fire		
Emergency Lights, battery		
Emergency Generators		
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT		INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)		DOUBLE FEE DUE:
TOTAL AMOUNT DUE:		<u>3.00</u>
		min <u>5.00</u>

INSPECTION: Will be ready on _____, 19__; or Will Call xxx

CONTRACTOR'S NAME: Linwood May

ADDRESS: Box 117, New Gloucester, Me.

TEL: 926-4185

MASTER LICENSE NO.: 1561

LIMITED LICENSE NO.: _____ SIGNATURE OF CONTRACTOR: Linwood B. May

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

Issued to **THOMAS LOSER**

LOCATION **415 Cumberland Avenue**

Date of Issue **August 11, 1986**

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. **85-1433**, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Limiting Conditions: **Entire**

Offices, Studio & Workshop

This certificate supersedes certificate issued

Approved:

(Date)

Inspector

James P. Hall
Carl J. [Signature]
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

CITY OF PORTLAND, MAINE
Department of Building Inspection



Certificate of Occupancy

LOCATION 415 Cumberland Avenue

Issued to THOMAS OSER

Date Issue AUGUST 11, 1986

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permits No. _____, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES:

APPROVED OCCUPANCY

Limiting Conditions: Offices, Studio & Workshop

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

[Signature]
Inspector of Buildings

Note: This certificate identifies lawful use of building or premises and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

December 9, 1985

Re: 415 Cumberland Ave.-Portland, Maine

Mr. Thomas Moser
Cobbs Bridge Road
New Gloucester, Maine 04260


Dear Sir:

Your application to complete construction of addition (38' X 50' second floor), as been reviewed and a building permit is herewith issued subject to the following requirements:

- * 1. Door #7 shall not be held open with fusible links.
The only approved method is with electro-magnetic hold open device connected to an approved automatic smoke detection system; and
2. Provide an approved 1 hour rated fire door with closer to separate stairs to 2nd floor from mailing room. *OK*

If you have any questions on these requirements, please call this office.

Sincerely,


S. Samuel Hoffses
Chief of Inspection Services

PSH/el

cc: Lt. James Collins

* No door in bldg. is held open with fusible link or any other device.

APPLICATION FOR PERMIT

PERMIT ISSUED

S.O.C.A. USE GROUP
 B.O.C.A. TYPE OF CONSTRUCTION **001433**

DEC 10 1985

ZONING LOCATION **PORTLAND, MAINE** NOV. 21, 1985
 City Of Portland

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE
 The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION .. **415, Cumberland Avenue** Fire District #1 #2
 1. Owner's name and address .. **Thomas Moser - Cobbs Bridge Rd.** Telephone **774-3791**
 2. Lessee's name and address .. **New Gloucester** Telephone ..
 3. Contractor's name and address .. **Owner** Telephone ..

Proposed use of building .. **offices & design studio & work shop** No. of sheets ..
 Last use .. No. families ..
 Material .. No. stories .. Heat .. Style of roof .. No. families ..
 Other buildings on same lot .. Roof ..
 Estimated contractual cost \$.. **40,000**

FIELD INSPECTOR—Mr.
 @ 775-5451

Appeal Fees \$..
 Base Fee
 Late Fee
 TOTAL \$..

To complete construction of addition
 38' x 50' 2 story as per plans.

Stamp of Special Conditions

PERMIT ISSUED WITH LETTER

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? .. **no** Is any electrical work involved in this work? .. **no**
 Is connection to be made to public sewer? .. **no** If not, what is proposed for sewage? ..
 Has septic tank notice been sent? .. **no** Form notice sent? ..
 Height average grade to top of plate .. Height average grade to highest point of roof ..
 Size, front .. Thickness, top .. solid or filled land? .. earth or rock? ..
 Material of foundation .. Rise per foot .. bottom .. cellar ..
 Kind of roof .. Material of chimneys .. of lining .. Kind of heat .. fuel ..
 No. of chimneys .. Dressed or full size? .. Corner posts .. Sills ..
 Framing Lumber—Kind .. Columns under girders .. Size .. Max. on centers ..
 Size Girder .. Studs (outside walls and carrying partitions) 2x4-16" O. C Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor .. 2nd .. 3rd .. roof ..
 On centers: 1st floor .. 2nd .. 3rd .. roof ..
 Maximum span: 1st floor .. 2nd .. 3rd .. roof ..
 If one story building with masonry walls, thickness of walls? .. height? ..

IF A GARAGE

How many cars now accommodated on same lot .. to be accommodated .. number commercial cars to be accommodated ..
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? ..

APPROVALS BY:
 BUILDING INSPECTION—PLAN EXAMINER ..
 ZONING ..
 BUILDING CODE ..
 Fire Dept ..
 Health Dept ..
 Other ..

MISCELLANEOUS
 Will work require disturbing of any tree on a public street? .. **no**
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? .. **es**

Signature of Applicant .. **Thomas Moser** Phone # .. **926-4434**
 Type Name of above .. **Thomas Moser** 2 3 4
 Other .. and Address ..

PERMIT ISSUED WITH LETTER
 APPLICANT'S COPY OFFICE FILE COPY

FIELD INS ..
MAC

NOTES

January - foundation
 down hill side toward
 MIA finished,
 foundation OK.
 March - superstructure
 built OK according
 to plans.

Trustees - met
 regularly and
 met with
 blueprints
 April - May
 Interior work
 progressing -
 August 8th all
 completed, issue
 C of O. Offices,
 Studio, & Workshop.

Permit No. 85/1933
 Location 115 Cumberland Ave
 Owner Thomas Moser
 Date of permit 11-21-85
 Approved 12-10-85
 Dwelling
 Garage
 Alteration addition



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date Feb 10, 1986
 Receipt and Permit number D23147

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:
 LOCATION OF WORK: 415 Cumberland Ave.
 OWNER'S NAME: Thomas Moser ADDRESS: New Gloucester

		FEE
OUTLETS:		
Receptacles	Switches	Plugmold
		ft. TOTAL 39-60
		5.00
FIXTURES: (number of)		
Incandescent	x	Flourescent
		x (not strip) TOTAL 20
		Strip Flourescent
		ft.
		4.00
SERVICES:		
Overhead	Underground	Temporary
		TOTAL amperes
METERS: (number of)		
MOTORS: (number of)		
Fractional		
		2.00
1 HP or over		
		11.00
RESIDENTIAL HEATING:		
Oil or Gas (number of units)		
Electric (number of rooms)		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler)		
Oil or Gas (by separate units)		
Electric Under 20 kws		
Over 20 kws		
APPLIANCES: (number of)		
Ranges	Water Heaters	
Cook Tops	Disposals	
Wall Ovens	Dishwashers	
Dryers	Compactors	
Fans	Others (denote)	
TOTAL		
MISCELLANEOUS: (number of)		
Branch Panels	1	
		1.00
Transformers		
Air Conditioners	Central Unit	
		Separate Units (windows)
Signs	20 sq. ft. and under	
		Over 20 sq. ft.
Swimming Pools	Above Ground	
		In Ground
Fire/Burglar Alarms	Residential	
		Commercial
Heavy Duty Outlets, 220 Volt (such as welders)	30 amps and under	
		over 30 amps
Circuits, Fairs, etc.		
Alterations to wires		
Repairs after fire		
Emergency Lights, battery		
Emergency Generators		

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT
 FOR REMOVAL OF A "STOP ORDER" (304-16.b)

INSTALLATION FEE DUE: _____
 DOUBLE FEE DUE: _____
 TOTAL AMOUNT DUE: 23.00

INSPECTION:
 Will be ready on _____, 19__; or Will Call _____
 CONTRACTOR'S NAME: Lirwood May
 ADDRESS: Box 117, New Gloucester
 TEL: 926-4185
 MASTER LICENSE NO.: 1561
 LIMITED LICENSE NO.: _____
 SIGNATURE OF CONTRACTOR: *Lirwood May*

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

City of Portland, Maine -- Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 415 Cumberland Ave		Owner: Panela Hurley		Phone:	Permit No: 951016
Owner Address:		Leasee/Buyer's Name:		Phone:	Business Name:
Contractor Name: Normandeau Consulting Services		Address: 226 Valley St Portland, ME 04102		Phone: 775-0763	
Past Use: Multi Use		Proposed Use: Same		COST OF WORK: \$ 5,000.00	PERMIT FEE: \$ 45.00
Proposed Project Description: Install Windows		Signature:		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type: Signature: <i>[Signature]</i>
Permit Taken By: Mary Gresik		Date Applied For: 22 Sept 95		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: Date:	
<p>1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.</p>					
<p><i>call for plan</i></p> <p>CERTIFICATION</p> <p>I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by the permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit</p>					
SIGNATURE OF APPLICANT <i>[Signature]</i>		ADDRESS: Daniel Normandeau		DATE: 22 Sept 95	PHONE: 775-0763
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE				PHONE:	
White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector				CEO DISTRICT 5	

PERMIT ISSUED
SEP 25 1995
CITY OF PORTLAND

Zone: **B-3** CBL: 036-G-033
Zoning Approval: *[Signature]*
Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan major minor mm
Zoning Appeal:
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review
Action:
 Approved
 Approved with Conditions
 Denied
Date: *[Signature]* 22 Sept 95

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

951016

Location of Construction: 415 Cumberland Ave		Owner: Paola Hurley		Phone:	
Owner Address:		Leasee/Buyer's Name:		Phone:	
Contractor Name: Normandeau Consulting Services		Address: 226 Valley St Portland, ME 04102		Phone: 775-0763	
Past Use: Multi Use		Proposed Use: Same		COST OF WORK: \$ 5,000.00	
				PERMIT FEE: \$ 45.00	
Proposed Project Description: Install Windows		Signature:		INSPECTION: Use Group: Type: Signature: Date:	
Permit Taken By: Mary Gresik		Date Applied For: 22 Sept 95		Signature: Date:	

PERMIT ISSUED
Permit Issued:
SEP 25 1995
CITY OF PORTLAND

Zone: CBL: 036-G-037
Zoning Approval:
Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan major minor mm

- This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

Zoning Appeal:
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation:
 Not in District or Landmark
 Does Not Require Review
 Requires Review

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT: Daniel Normandeau ADDRESS: DATE: 22 Sept 95 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

Action:
 Approved
 Approved with Conditions
 Denied
Date: 25 Sept 95

CEO DISTRICT 5

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

COMMENTS

10/11/95 Old windows taken out & plywood
installed WIP making
~~New windows installed~~

Type	Inspection Record	Date
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____




204 Pine Hill Road, Berwick, Me 03901-2423 • Tel: (207) 698-1332 • Toll Free: 1-800-577-6344 • Fax: (207) 698-5309

\$1000.00
Deposit




Installing custom built window (3 adjoining to make one window area) into existing window location that is presently bricked in. Project consists of removing bricks & placing new window system. Granite Lintel extant presently.

James Eaton



COM. ANY NAME: <u>Pamela Hickey</u>		SALES PERSON:		P.O.# <u>Portland</u>	
UNIT TYPE (Check one)					
<input type="checkbox"/> Half Round	<input type="checkbox"/> Ellipse	<input type="checkbox"/> Palladian	<input type="checkbox"/> Triangle	<input type="checkbox"/> Half Round Pan	
<input type="checkbox"/> Quarter Round	<input type="checkbox"/> Treston	<input type="checkbox"/> Trapezoid	<input type="checkbox"/> Ellipse Pan	<input type="checkbox"/> Dome	<input type="checkbox"/> Other
JAMB THICKNESS:		GLASS TYPE: <input type="checkbox"/> ES <input type="checkbox"/> DB <input type="checkbox"/> 5/8 Linsale <input type="checkbox"/> Other			
LOW "E": <input type="checkbox"/> Yes <input type="checkbox"/> No		SASH CONSTRUCTION: <input type="checkbox"/> AD <input type="checkbox"/> One Light			
GRILL OR SASH DESIGN: (Please draw and dimension if necessary)			EXTERIOR CASING:		
			INTERIOR CASING:		
			EXTERIOR FINISH:		
			INTERIOR FINISH:		
			SUBTILE: <input type="checkbox"/> Yes <input type="checkbox"/> No		
NUMBER OF UNITS:		NET AMOUNT: <u>\$3780</u>		DIVIDED TOTAL:	
				PAYMENT TERMS:	



AUTHORIZED SIGNATURE _____
 DELIVERY DATE 1st week of October DUE _____