



CITY OF PORTLAND, MAINE

389 CONGRESS STREET  
PORTLAND, MAINE 04101  
(207) 874-8300

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF  
INSPECTION SERVICES DIVISION

October 10, 1991

RE: 241 Commercial St. (first floor)

Mr. William Nemmers  
424 Forr Street  
Portland, Maine 04101

Dear Sir:


Your application to make interior renovations on the first floor at 241 Commercial Street has been reviewed and a permit is herewith issued subject to the following requirements:

No certificate of occupancy can be issued until all requirements of this letter are met.

1. All required Fire Alarm systems shall have the capability of "Zone Disconnect" via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
2. All remote annunciators shall have a visible "trouble" indicator along with the Fire Alarm "Zone" indicators.
3. Fire Alarm Systems shall be in accordance with Sections 26-3.4 of N.F.P.A. 101 1991 Ed. and N.F.P.A. #72.
4. Portable fire extinguishers shall be provided in accordance with N.F.P.A. #10.
5. Stairs shall be of non combustible materials in accordance with Section 5-2.2.3.2 and meet all other requirements of Section 5-2.2.
6. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act, Title 5 M.R.S. refers, shall obtain a certification from a design professional that the plans of the facility meet the standards of construction required by this section. Prior to commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
7. Exit lighting shall be in accordance with Section 822.0 and 823.0 of the 1990 BOCA National Building Code.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

  
P. Samuel Hoffses  
Chief of Inspection Services

/el

cc: I.T. Wallace Garroway, Fire Prevention Bureau



CITY OF PORTLAND, MAINE

389 CONGRESS STREET  
PORTLAND, MAINE 04101  
(207) 874-8300

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF  
INSPECTION SERVICES DIVISION

October 10, 1991

Hill Nemmers And Assoc.  
424 Fore St  
Portland, ME 04101

Re: 241 Commercial St

Dear Mr. Nemmers,

This letter is in reference to your application to change the use of the building at 241 Commercial Street in Portland from storage space to restaurant with bar. I have reviewed the plans and attached material and do agree that site plan is not required based on the information provided.

However, it is apparent that other portions of the building will need a change of use permit in the near future. Please be advised that such changes will require site plan review as described in Sections 14-521 through 14-528 of the Land Use Code. I have attached these sections so you may advise the building owners of this requirement.

Sincerely,

  
William D. Giroux  
Zoning Administrator

cc: Joseph E. Gray, Director of Planning and Urban Development  
P. Samuel Hoffses, Chief of Inspection Services  
Hugh Irving, Code Enforcement Officer

/mg



**Hill  
Nemmers  
and Associates  
Architects · Planners**

October 9, 1991

Lt Galloway  
City of Portland Dept. of Building Inspections  
389 Congress Street  
Portland, Maine 04101

Re Renovations to 241 Commercial Street

Dear Lt. Galloway

I am submitting with this letter a revised plan of the project, revised to show the items we reviewed on Monday. I have included the following list on the plans as well to clarify the work to be done.

- a Stairwells will be protected by 2-hour enclosures
- b Doors at stairwells will be 1 1/2-hour rated with hydraulic closers
- c The boiler room will be enclosed by a smoke partition which will include a self closing door
- d A fire alarm system will be provided which will include the following
  - 1 a pull station at the entry to each stair on each floor including the unoccupied floors
  - 2 an alarm on each floor
  - 3 smoke detectors on each floor including the unoccupied floors, rate-of-rise heat detectors in the boiler room
  - 4 a battery operated emergency light to illuminate each stairwell between the first and second floor
  - 5 illuminated exit lights at each exit from the second floor
- e The first floor tenant will submit plans for a separate building permit for the interior work on the first floor. These plans will include seating layouts, kitchen layouts, kitchen fire suppression systems, dumpster location and protection, fire alarm system and emergency lights.
- f. This project is concerned only with the 1st and 2nd floors and the basement which is used for mechanical equipment and a cooler. A future project is planned to develop the remaining floors, 2 and above, for first class office space. At the time of that project the fire requirements will change and those changes will be addressed then. Included in these future requirements will be non-combustible stairs, and the installation of a door isolating the Union Street stair

I have included the area of refuge as called for in the Human Rights Legislation although talks with the folks at Alpha One have indicated that since the office on the second floor is a private office with limited public access it may not require such a refuge area. This topic is still being worked out

Sincerely,

William Nemmers

COZY HARBOR  
 424 FORE STREET

WEST SOUTHPORT, MAINE 04576  
PORTLAND, MAINE 04101

207 633-3683  
207 774-3683

 **Hill  
Nemmers  
and Associates  
Architects • Planners**

September 19, 1991

Mr. Sam Hoffses  
Department of Building Inspections  
City of Portland  
389 Congress Street  
Portland, Maine 04101

Re: The Praver Block 241 Commercial Street


Dear Mr. Hoffses:

I am submitting with this letter two copies of the plans and outline specifications for the renovation work proposed for the first floor of this building. Also enclosed is a check for \$645.00 to cover the fee for the project which we have estimated to cost about \$125,000.00.

We have submitted materials to Gary Hamilton at the Historic Preservation office because this project is in the Waterfront Historic District and therefore will require the approval of the Historic Commission.

I will be available at your convenience to answer any questions or to provide additional information.

Sincerely,

  
William Nemmers  
Encl: plans and check

**RECEIVED**

SEP 18 1991

DEPT. OF BUILDING INSPECTIONS  
CITY OF PORTLAND

☐ COZY HARBOR WEST SOUTHPORT, MAINE 04576  
☐ 424 FORE STREET PORTLAND, MAINE 04101

207 633-3683  
207 774-3683

940609

Permit # \_\_\_\_\_ City of Portland BUILDING PERMIT APPLICATION Fee 630. Zone \_\_\_\_\_ Map # \_\_\_\_\_ Lot# \_\_\_\_\_  
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: SLC Assoc. Phone # 772-3310

Address: 446 Fore St Portland, ME 04101

LOCATION OF CONSTRUCTION 241 Commercial St

Contractor: Consultant Services Sub: \_\_\_\_\_

Address: One Portland Sq Portland, ME 04101 Phone # 773-4125

Est. Construction Cost: 122,000.00 Proposed Use: Restaurant w/bar

Past Use: Storage Space

# of Existing Res. Units \_\_\_\_\_ # of New Res. Units \_\_\_\_\_

Building Dimensions L \_\_\_\_\_ W \_\_\_\_\_ Total Sq. Ft. \_\_\_\_\_

# Stories \_\_\_\_\_ # Bedrooms \_\_\_\_\_ Lot Size: \_\_\_\_\_

Is Proposed Use: Seasonal \_\_\_\_\_ Condominium \_\_\_\_\_ Conversion \_\_\_\_\_

Explain Conversion: Interior Renovations - Change of Use

\* Mail to: William Nemmers 424 Fore St Portland, ME 04101  
Foundation:

- 1. Type of Soil: 038-F-004
- 2. Set Backs - Front \_\_\_\_\_ Rear \_\_\_\_\_ Side(s) \_\_\_\_\_
- 3. Footings Size: \_\_\_\_\_
- 4. Foundation Size: \_\_\_\_\_
- 5. Other \_\_\_\_\_

- Floor:
- 1. Sills Size: \_\_\_\_\_ Sills must be anchored.
  - 2. Girder Size: \_\_\_\_\_
  - 3. Lally Column Spacing \_\_\_\_\_ Size: \_\_\_\_\_
  - 4. Joists Size: \_\_\_\_\_
  - 5. Bridging Type: \_\_\_\_\_ Size: Spacing 16" O.C.
  - 6. Floor Sheathing Type: \_\_\_\_\_ Size: \_\_\_\_\_
  - 7. Other Material: \_\_\_\_\_

- Exterior Walls
- 1. Studding Size \_\_\_\_\_ Spacing \_\_\_\_\_
  - 2. No. windows \_\_\_\_\_
  - 3. No. Doors \_\_\_\_\_
  - 4. Header Sizes \_\_\_\_\_ Span(s) \_\_\_\_\_
  - 5. Bracing: Yes \_\_\_\_\_ No \_\_\_\_\_
  - 6. Corner Posts Size \_\_\_\_\_
  - 7. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_
  - 8. Sheathing Type \_\_\_\_\_ Size \_\_\_\_\_
  - 9. Siding Type \_\_\_\_\_ Weather Exposure \_\_\_\_\_
  - 10. Masonry Materials \_\_\_\_\_
  - 11. Metal Materials \_\_\_\_\_

- Interior Walls
- 1. Studding Size \_\_\_\_\_ Spacing \_\_\_\_\_
  - 2. Header Sizes \_\_\_\_\_ Span(s) \_\_\_\_\_
  - 3. Wall Covering Type \_\_\_\_\_
  - 4. Fire Wall If required \_\_\_\_\_
  - 5. Other Materials \_\_\_\_\_

**For Official Use Only PERMIT ISSUED**

Date 17 June 1994

Inside Fire Limits \_\_\_\_\_

Bldg Code \_\_\_\_\_

Time Limit \_\_\_\_\_

Estimated Cost \_\_\_\_\_

Subdivision \_\_\_\_\_

Name \_\_\_\_\_

Address \_\_\_\_\_

City \_\_\_\_\_

State \_\_\_\_\_

Zip \_\_\_\_\_

Ownership \_\_\_\_\_

City of Portland

Zoning: Street Frontage Provided: \_\_\_\_\_

Provided Setbacks: Front \_\_\_\_\_ Back \_\_\_\_\_ Side \_\_\_\_\_

Review Required: Zoning Board Approval: Yes \_\_\_\_\_ No \_\_\_\_\_ Date: \_\_\_\_\_

Planning Board Approval: Yes \_\_\_\_\_ No \_\_\_\_\_ Date: \_\_\_\_\_

Conditional Use: \_\_\_\_\_ Variance \_\_\_\_\_ Site Plan \_\_\_\_\_ Subdivision \_\_\_\_\_

Shoreland Zoning Yes \_\_\_\_\_ No \_\_\_\_\_ Floodplain Yes \_\_\_\_\_ No \_\_\_\_\_

Special Exception \_\_\_\_\_

Other (Explain) \_\_\_\_\_

Ceiling: 1. Ceiling Joists Size: \_\_\_\_\_

2. Ceiling Strapping Size \_\_\_\_\_ Spacing \_\_\_\_\_ Not in District nor Landmark.

3. Type Ceiling: \_\_\_\_\_ Does not require review.

4. Insulation Type \_\_\_\_\_ Size \_\_\_\_\_ Requires Review.

5. Ceiling Height: \_\_\_\_\_

Roof: 1. Truss or Rafter Size \_\_\_\_\_ Spacing: \_\_\_\_\_

2. Sheathing Type \_\_\_\_\_ Size: \_\_\_\_\_ Approved with conditions.

3. Roof Covering Type \_\_\_\_\_

Chimneys: Type: \_\_\_\_\_ Number of Fire Places \_\_\_\_\_ Date: \_\_\_\_\_

Heating: Type of heat: \_\_\_\_\_

Electrical: Service Entrance Size: \_\_\_\_\_ Smoke Detector Required Yes \_\_\_\_\_ No \_\_\_\_\_

Plumbing: 1. Approval of soil test if required Yes \_\_\_\_\_ No \_\_\_\_\_

2. No. of Tubs or Showers \_\_\_\_\_

3. No. of Flushes \_\_\_\_\_

4. No. of Lavatories \_\_\_\_\_

5. No. of Other Fixtures \_\_\_\_\_

Swimming Pools: 1. Type: \_\_\_\_\_

2. Pool Size: \_\_\_\_\_ x \_\_\_\_\_

3. Must conform to National Electrical Code and State Code

**PERMIT ISSUED BY**  
**WITH LEADER**

Permitted By: Mary Gralik  
Signature: \_\_\_\_\_  
Date: 17 June 1994  
CEO's District: 3 William Nemmers

**PERMIT ISSUED WITH LEADER**

White - Tax Assessor

CONTINUED TO REVERSE SIDE  
Ivory Tag - CEO [3] Ms Munson


941352



APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. \_\_\_\_\_

Portland, Maine, \_\_\_\_\_



To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE 12 Dec 94

The undersigned hereby applies for amendment to Permit No. 94/0609 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, (if any, submitted herewith), and the following specifications:

Location 241 Commercial St Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_
Owner's name and address XXXXXXXXXXXXXXXX SLM Assoc. Telephone \_\_\_\_\_
Lessee's name and address Three Dollar Deweys Telephone \_\_\_\_\_
Contractor's name and address Telephone \_\_\_\_\_
Architect William Nemmers Assoc. 424 Fore St Pctd, ME 04103 Plans filed 774-3683 No. of sheets \_\_\_\_\_
Proposed use of building Bar No. families \_\_\_\_\_
Last use Vacant No. families \_\_\_\_\_
Increased cost of work 4,000. Additional fee 45.00

Description of Proposed Work

See attached description.

H.P. OK
Call Bill
D. Winston 12/12/94 774-3683
Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_
Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_
Framing lumber -- Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_
Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max on centers \_\_\_\_\_
Studs (outside walls and carrying partitions) 2x4-16" O.C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Approved: [Signature]

I called Mr. Nemmers to verify that this was his work.
Signature of Owner [Signature]

INSPECTION COPY - WHITE
APPLICANT'S COPY - YELLOW

FILE COPY - PINK
ASSESSOR'S COPY - GOLDEN

Approved: [Signature] Inspector of Buildings

[Handwritten initials and numbers]

**PLUMBING APPLICATION**

Department of Human Services  
Division of Health Engineering  
(207) 287-3326

Town/County: FURLAND

Street: Commercial St

Property Owner: S. M. [unclear]

Applicant Name: R. B. [unclear]

Mailing Address of Owner: 12 Hunter Street Furland ME 04032

FURLAND 5340 TOWN COPY

Date: 3.7.95

Local Plumbing Inspector Signature: \_\_\_\_\_

L.P.L. # 0124

Owner's Applicant Statement:  
I hereby certify that the information submitted is correct to the best of my knowledge and understanding and that any false information is cause for the Local Plumbing Inspector to deny a permit.

Signature of Owner/Applicant: \_\_\_\_\_ Date: 3/7/95

Caution: Inspection Required

I have inspected the installation shown above and found it to be in compliance with the Maine Plumbing Rules.

Signature of Plumbing Inspector: Tammy Munson

Date Approved: 3-95

**PERMIT INFORMATION**

This Application is for:  NEW PLUMBING  RELOCATED PLUMBING

Type Of Structure To Be Served:  
 SINGLE FAMILY DWELLING  
 MODULAR OR MOBILE HOME  
 MULTIPLE FAMILY DWELLING  
 OTHER - SPECIFY: Line Restaurant

Plumbing To Be Installed By:  
 MASTER PLUMBER  
 OIL BURNERMAN  
 MFG. HOUSING DEALER / MECHANIC  
 PUBLIC UTILITY EMPLOYEE  
 PROPERTY OWNER

LICENSE: 102645

Hook-Up & Piping Relocation Main Use: Hook-Up	Column 2		Column 1	
	Number	Type of Fixture	Number	Type of Fixture
HOOK-UP to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District	1	Hosebib / Silcock	1	Bathub (and Shower)
	1	Floor Drain	1	Shower (Separate)
OR	3	Urinal	3	Sink
	1	Drinking Fountain	1	Wash Basin
HOOK-UP to an existing subsurface wastewater disposal system	1	Indirect Waste	1	Water Closet (Toilet)
	1	Water Treatment (softener, filter, etc.)	1	Clothes Washer
PIPING RELOCATION of sanitary lines, drains, and piping without new fixture	1	Grease / Oil Separator	1	Dish Washer
	1	Dental Cuspidor	1	Garbage Disposal
Number of Hook-Ups & Relocations	1	Bidet	1	Laundry Tub
	1	Other: _____	1	Water Heater
Hook-Up & Relocation Fee	Features (Subtotal) Column 2		1.7	Features (Subtotal) Column 1
	TRANSFER FEE (\$2.00)		1.2	Features (Subtotal) Column 2
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE				
			\$12.91	Fixture Fee
			\$16.00	Transfer Fee
			\$	Hook-Up & Relocation Fee
			\$16.00	Permit Fee (Total)



**APPLICATION FOR PERMIT**  
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES  
 ELECTRICAL INSTALLATIONS

Date February 28, 1985  
 Receipt and Permit number 2436

To the CHIEF ELECTRICAL INSPECTOR Portland, Maine

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 241 Commercial St.  
 OWNER'S NAME: Sandra Marston ADDRESS: same

	FEES
<b>OUTLETS:</b>	
Receptacles <u>30</u> Switches <u>20</u> Plugmold _____ ft TOTAL <u>50</u> .....	<u>10.00</u>
<b>FIXTURES: (number of)</b>	
Incandescent <u>30</u> Fluorescent <u>10</u> (not strip) TOTAL <u>40</u> .....	<u>8.00</u>
Strip Fluorescent _____ ft. ....	
<b>SERVICES:</b>	
Overhead <u>X</u> Underground _____ Temporary _____ TOTAL amperes <u>100</u> ..	<u>25.00</u>
METERS: (number of) <u>2</u> .....	<u>2.00</u>
<b>MOTORS: (number of)</b>	
Fractional _____ .....	
1 HP or over <u>3</u> .....	<u>6.00</u>
<b>RESIDENTIAL HEATING:</b>	
Oil or Gas (number of units) _____ .....	
Electric (number of rooms) _____ .....	
<b>COMMERCIAL OR INDUSTRIAL HEATING:</b>	
Oil or Gas (by a main boiler) <u>1</u> .....	<u>5.00</u>
Oil or Gas (by separate units) _____ .....	
Electric Under 20 kws _____ Over 20 kws _____ .....	
<b>APPLIANCES: (number of)</b>	
Ranges _____ Water Heaters <u>1</u> .....	
Cook Tops _____ Disposals <u>1</u> .....	
Wall Ovens _____ Dishwashers <u>1</u> .....	
Dryers _____ Compactors _____ .....	
Fans <u>1</u> _____ Others (denote) _____ .....	
TOTAL <u>4</u> .....	<u>8.00</u>
<b>MISCELLANEOUS: (number of)</b>	
Branch Panels <u>2</u> .....	<u>8.00</u>
Transformers _____ .....	
Air Conditioners Central Unit <u>1</u> .....	
Separate Units (window) _____ .....	<u>10.00</u>
Signs 20 sq. ft. and under _____ .....	
Over 20 sq. ft. _____ .....	
Swimming Pools Above Ground _____ .....	
In Ground _____ .....	
Fire/Burglar Alarms Residential _____ .....	
Commercial <u>1</u> .....	<u>15.00</u>
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ .....	
over 30 amps _____ .....	
Circus, Fairs, etc. _____ .....	
Alterations to wires _____ .....	
Repairs after fire _____ .....	
Emergency Lights, battery <u>2</u> .....	<u>2.00</u>
Emergency Generator. _____ .....	
	INSTALLATION FEE DUE
FOR ADDITIONAL WORK ON ORIGINAL PERMIT .....	DOUBLE FEE DUE
FOR REMOVAL OF A "STOP ORDER" (304-18.b) .....	
	<b>TOTAL AMOUNT DUE.</b>
	<u>99.00</u>

**INSPECTION:**

Will be ready on \_\_\_\_\_ 19\_\_; or Will Call X

CONTRACTOR'S NAME: Mancini Elec.

ADDRESS: 179 Sheridan St. Portland 04101

TEL: 774-5829

MASTER LICENSE NO. 2436 SIGNATURE OF CONTRACTOR: \_\_\_\_\_

LIMITED LICENSE NO. \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN





City of Portland, Maine -- Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 374-0000 FAX: 874-8706

Location of Construction: 241-243 Commercial St		Owner: SLM Properties, Inc.		Phone:	Permit No: <b>850264</b>
Owner Address:		Leasee/Buyer's Name: Three Dollar Drapery's, Inc.	Phone:	Business Name:	
Contractor Name: Scarborough Signs		Address:		Phone:	PERMIT ISSUED MAR 23 1995 CITY OF PORTLAND
Past Use: Bar/Restaurant		Proposed Use: Same w/signage	COST OF WORK: \$		
Proposed Project Description: Erect Signage as per plans		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type: DOCA 93 Signature: <i>[Signature]</i>	
Permit Taken By: Mary Gresik		Date Applied For: 16 March 1995		Zone: <b>B-3</b> CBL: 038-F-004	
1. This permit application doesn't preclude the applicant(s) from meeting applicable State and Federal rules.		2. Building permits do not include plumbing, mechanical or electrical work.		3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Signature: _____ Date: _____		Zoning Approval: <b>OK</b> <b>3/17/95</b> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan map <input type="checkbox"/> minor <input type="checkbox"/> im <input type="checkbox"/>	
Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied		Historic Preservation <input type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input checked="" type="checkbox"/> Requires Review		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied	

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *[Signature]* Don Berry ADDRESS: \_\_\_\_\_ DATE: 16 March 1995 PHONE: \_\_\_\_\_

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: \_\_\_\_\_ PHONE: \_\_\_\_\_

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT **2**

*[Signature]*  
Ms Munson