

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

February 7, 1991

Vessel Service, Inc.
1 Portland Fish Pier
Portland, ME 04101

Re: 1 Portland Fish Pier

Dear Sir:

Your application to install above-ground 500 gal. waste oil tank at Portland Fish Pier has been reviewed and a permit is herewith issued subject to the following requirement(s):

No certificate of occupancy can be issued until all requirements of this letter are met.

1. Installation shall be in accordance with N.F.P.A. #30 Section 2-3.
2. Tank shall be located in accordance with Table 7-6 at least 10 f. property line that is or can be built upon, including the opposite side of a public way and at least 5' from nearest side of any public way or from nearest important building on the same property. 4-2 zone.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

Samuel P. Hoffses
Chief of Inspection Services

cc: Lt. Wallace G. Gray, P.S.D.

PSH/d1a