



**APPLICATION FOR PERMIT**  
**DEPARTMENT OF BUILDING INSPECTIONS SERVICES**  
**ELECTRICAL INSTALLATIONS**

Date November 30, 19 92  
 Receipt and Permit number 3088

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 7 Portland Fish Pier  
 OWNER'S NAME: Marine Trade Center ADDRESS: same FEES

OUTLETS:  
 Receptacles 8 Switches 3 Plugmold \_\_\_\_\_ ft. TOTAL 11 ..... 2.20

FIXTURES: (number of)  
 Incandescent \_\_\_\_\_ Fluorescent 2 (not strip) TOTAL 2 ..... .40  
 Strip Fluorescent \_\_\_\_\_ ft. ....

SERVICES:  
 Over head \_\_\_\_\_ Underground \_\_\_\_\_ Temporary \_\_\_\_\_ TOTAL amperes \_\_\_\_\_

METERS: (number of) \_\_\_\_\_

MOTORS: (number of)  
 Fractional \_\_\_\_\_  
 1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING:  
 Oil or Gas (number of units) \_\_\_\_\_  
 Electric (number of rooms) \_\_\_\_\_

COMMERCIAL OR INDUSTRIAL HEATING:  
 Oil or Gas (by a main boiler) \_\_\_\_\_  
 Oil or Gas (by separate units) \_\_\_\_\_  
 Electric Under 20 kws \_\_\_\_\_ Over 20 kws \_\_\_\_\_

APPLIANCES: (number of)  
 Ranges \_\_\_\_\_ Water Heaters \_\_\_\_\_  
 Cook Tops \_\_\_\_\_ Disposals \_\_\_\_\_  
 Wall Ovens \_\_\_\_\_ Dishwashers \_\_\_\_\_  
 Dryers \_\_\_\_\_ Compactors \_\_\_\_\_  
 Fans \_\_\_\_\_ Others (denote) \_\_\_\_\_

TOTAL \_\_\_\_\_

MISCELLANEOUS: (number of)  
 Branch Panels \_\_\_\_\_  
 Transformers \_\_\_\_\_  
 Air Conditioners Central Unit \_\_\_\_\_  
 Separate Units (windows) \_\_\_\_\_  
 Signs 20 sq. ft. and under \_\_\_\_\_  
 Over 20 sq. ft. \_\_\_\_\_  
 Swimming Pools Above Ground \_\_\_\_\_  
 In Ground \_\_\_\_\_  
 Fire/Burglar Alarms Residential \_\_\_\_\_  
 Commercial \_\_\_\_\_  
 Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under \_\_\_\_\_  
 over 30 amps \_\_\_\_\_  
 Circus, Fairs, etc. \_\_\_\_\_  
 Alterations to wires \_\_\_\_\_  
 Repairs after fire \_\_\_\_\_  
 Emergency Lights, battery \_\_\_\_\_  
 Emergency Generators \_\_\_\_\_

INSTALLATION FEE DUE: 2.60

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ..... DOUBLE FEE DUE:  
 FOR REMOVAL OF A "STOP ORDER" (304-16.b) .....  
 TOTAL AMOUNT DUE: MIN 15.00

INSPECTION:  
 Will be ready on NOW, 19 92; or Will Call \_\_\_\_\_  
 CONTRACTOR'S NAME: Seacoast Elec  
 ADDRESS: 76 Leavitt St. Long Island 04050  
 TEL: 774-6171  
 MASTER LICENSE NO.: X 03088 SIGNATURE OF CONTRACTOR: Klarry C. Pophell  
 LIMITED LICENSE NO.: \_\_\_\_\_

INSPECTOR'S COPY — WHITE  
 OFFICE COPY — CANARY  
 CONTRACTOR'S COPY — GREEN

**ELECTRICAL INSTALLATIONS**

Permit Number: 3088

Location: 2 Pine Hill Apartments, 12th St

Owner: Mr. Thomas C. ...

Date of Permit: 11-20-42

Final Inspection: 12-2-42

By Inspector: [Signature]

Permit Application Register Page No. 134

INSPECTIONS: Service \_\_\_\_\_ by \_\_\_\_\_

Service called in \_\_\_\_\_

Closing-in: 12-2-42 by SB

PROGRESS INSPECTIONS: \_\_\_\_\_

DATE	REMARKS

*[Handwritten signature]*

# APPLICATION FOR SUBMETER



**RECEIVED**  
MAY 31 1985  
DEPARTMENT OF PUBLIC WORKS

## For Sewer User Charge Adjustments

The undersigned hereby requests permission to install additional water meter(s) in accordance with Section 322.6C of the "Municipal Code of the City of Portland, Maine".

It is understood that all expenses related to the purchase, installation and maintenance of the meter(s) is to be borne by the applicant.

To be Completed by Applicant *Portland*  
270-340 Commercial Street

Address where sub-meter is requested (Maine Trade Center) 2 Portland Fish Pier  
 Property owner name Portland Fish Pier Assoc. (2 PORTLAND PIER)  
 Tax Map Reference (on Real Estate Tax Bill) T.S.A. NEW Building, NO TAX BILL, CITY PROPERTY  
 Property owner address same  
 Person to be contacted to schedule inspections ROBERT TERRANT SUITE #211 773-4362 (H)  
 (Name and Telephone Number) 772-4777 (B)  
 Portland Water District Acct. No. (on bill) P-95-P744 761-4418 (B) 3rd Fl.

Billing Name & Address (on bill) MAINE TRADE CENTER PORTLAND FISH PIER ASSOC  
Suite 301, MAINE TRADE CENTER, 2 PORTLAND FISH PIER  
PORTLAND ME 04101

Location and size existing Portland Water District Service Meter SW CORNER OF Building; TRILENT A"


Proposed location and size of sub-meter 5-5/8" submeters; one on each outside spicket of five service shops, 4 on east side of Building, one on west

Will a remote reading register be utilized? NO  YES (If yes, state location outside of Bldg SW corner if possible Be Required)

Description of proposed changes in plumbing required for submetering:

cut into supply immediately inside building from spicket

Sketch plan showing proposed changes in plumbing and the location of existing and proposed meters. Show water flow through submeter to non-discharge equipment or location (use additional sheet of paper if necessary).



The volume of water to be submetered can be shown not to enter the sewerage system by virtue of its use for:

Commercial Fishing Vessels, Fire Boat, other watercraft, Repair Maintenance

I certify the above information is true and correct.  
Robert M. Terrant  
 Signature

June 12 1985

5-15-85  
 Date

**INSTRUCTIONS**

- First - The applicant is to complete a form of this form. The fee and reference are on page 2 of this form. The fee is \$10.00. The fee is to be paid in cash or by check. The fee is to be paid to the City of Portland, Maine. The fee is to be paid to the City of Portland, Maine. The fee is to be paid to the City of Portland, Maine.
- Second - Mail completed application form to  
 City of Portland  
 Dept. of Public Works  
 624 City Hall  
 Portland, Maine 04102  
 ATTN: MR. WILLIAM GOODWIN
- Third - The Public Works Department will call the person indicated on front of form to set up pre-installation inspection. During this inspection the Public Works Department will be completed. Following this inspection Public Works will make copies of the application form. If the application is approved 3 copies will be made. One will be mailed to the Portland Water District, one will be forwarded to the City Planning Inspector and one will be mailed back to the applicant. If the application is denied, the copy will be made and mailed to the applicant showing reason for denial.
- Fourth - Upon receipt of a copy of the approved application, the applicant can purchase and install the sub-meter as approved. Following installation the applicant or his plumber must call the Chief Plumbing Inspector at 273-5451 Ext. 444 for an inspection of the completed installation. Following inspection by the Chief Plumbing Inspector, the Water District will be requested to seal the sub-meter and arrange to have an automatic reading system installed - See General Information. Installation here by the volume shown by the submeter will be credited on the Sewer User Charges of the City.

353

**GENERAL INFORMATION**

Section 22.60 of the Municipal Code of the City of Portland, Maine reads as follows:

Installation of water meters. Any person who installs or causes to be installed an additional water meter on a line approved by the Director to measure a volume of water which can be shown not to exceed the amount specified in the permit installing such meter shall, immediately notify the Director of such installation and shall be responsible to the Director for arranging meter readings not less often than every three months. Such person shall be entitled with the water charges for the volume shown to such meter, which meter shall be a standard for reading by the City or its agents at all reasonable times.

The City and the District have arranged to release the customer from the responsibility required above if such meters can be read simultaneously by the District meter readers during their regular scheduled visits to read the metering service meter. This can be accomplished by locating the submeter directly adjacent to the metering service meter or by installing the submeter located elsewhere with a remote reading register located so both registers can be read at the same time.

Approved meters are, Heritage and Roswell meters, conforming to the following specifications:

- shall meet or exceed ANSI accuracy test requirements and be accompanied by a certificate of test accuracy;
- the meters will have straight reading, cubic foot registers;
- the meters will have the meter number stamped into the main case;
- shall have either a magnetic drive;
- shall have either a rotating disc or oscillating piston.

Approved meters are available from the Water District, which sells them for the price the District pays them from the manufacturer. If you wish to purchase a sub-meter from the District you must bring your copy of an approved application with you at time of purchase.

**TO BE COMPLETED BY PUBLIC WORKS**

Pre-installation inspection by DAVID E. PETERSON on 6-7-85

Automatic reading system requested  YES  NO

A Back Flow Preventer or equal shall be installed

Application  Approved  Denied

Comments Back Flow Preventers have been installed on out side sillcock

**TO BE COMPLETED BY THE PLUMBING INSPECTOR**

An inspection of the completed installation of the submetering system approved on this application was conducted on 6/10/85 by Ernest R. Goodwin, Chief Plumbing Inspector of the City of Portland.

- The submetering system was installed as approved.
- No cross connections were found.

The installation is  approved  dis-approved E. Goodwin

**TO BE COMPLETED BY THE WATER DISTRICT**

Date submeter sold 6/25/85

Submeter account number P95-P744

Submeter make and number 5/R # 35490257 rdg

Submeter installation readings 35490256 -0-

Submeter account entered into computer 35490254 -0-

Submeter account entered into meter book 35490253 -0-

Special Instructions 35490252

To Be Read By City  
-Per Bill Goodwin 6/25/85

# APPLICATION FOR SUBMETER



## For Sewer User Charge Adjustments

The undersigned hereby requests permission to install additional water meter(s) in accordance with Section 322.6C of the "Municipal Code of the City of Portland, Maine".

It is understood that all expenses related to the purchase, installation and maintenance of the meter(s) is to be borne by the applicant.

### To be Completed by Applicant

Address where sub-meter is requested Portland Fish Pier - (270-340 Commercial Street)

Property owner name Vessel Services, Inc.

Tax Map Reference (on Real Estate Tax Bill) Map 41

Property owner address Portland Fish Pier, P.O. Box 4812 DTS, Portland, Maine 04112

Person to be contacted to schedule inspections David E. Leeman, Manager 772-5718/2512  
(Name and Telephone Number)

Portland Water District Acct. No. (on bill) New account

Billing Name & Address (on bill) Vessel Services, Inc., Portland Fish Pier

P.O. Box 4812 DTS, Portland, Maine 04112

Location and size existing Portland Water District Service Meter Building under construction, on Portland Fish Pier (old Brown's wharf), main PWD meter will be 4"

Proposed location and size of sub-meter Adjacent to main PWD meter, submeter will be 2"

Will a remote reading register be utilized?  YES (If yes, state location \_\_\_\_\_)

Description of proposed changes in plumbing required for submetering:

New building, integral part of

new plumbing installation

Sketch plan showing proposed changes in plumbing and the location of existing and proposed meters. Show water flow through submeter to non-discharge equipment or location (use additional sheet of paper if necessary)

See attachments:

1. Below grade water and DWV
2. Water distribution schematic

The volume of water to be submetered can be shown not to enter the sewerage system by virtue of its use for:

1. Cooling up to 96 ton of ice per day and

2. Use on fishing vessels also fresh

water for fishing vessel cooking and sanitation

I certify the above information is true and correct:

David E. Leeman  
Signature

JUL. 18, 1983

3/25/83  
Date

**INSTRUCTIONS**

- First - The applicant is to complete front of this form. The Tax Map Reference can be found on your Real Estate Tax Bill directly following owners name and address in the center of your Property (or 1) Billing name and address should be copied from your Water & Sewer Bill as well as the Portland Water District Account Number which is on the lower left corner of the Water and Sewer Bill.
- Second - Mail completed application form to  
 City of Portland  
 Dept. of Public Works  
 421 City Hall  
 Portland, Maine 04101  
 ATTN: MR. WILLIAM GOODWIN
- Third - The Public Works Department will call the person indicated on front side to schedule pre-installation inspection. During this inspection the Public Works section of this form (below) will be completed. Following this inspection Public Works will make copies of the application form. If the application is approved 3 copies will be made, one will be mailed to the Portland Water District, one will be forwarded to the City Plumbing Inspector and one will be mailed back to the Applicant. If the application is denied, one copy will be made and mailed to the applicant showing reason for denial.
- Fourth - On receipt of a copy of the approved application, the applicant can purchase and install the sub-meter as approved. Following installation the applicant or his plumber must call the Chief Plumbing Inspector at 775-5451 Ext. 204 for an inspection of the completed installation. Following inspection by the Chief Plumbing Inspector, the Water District will be requested to seal the sub-meter and arrange to have an automatic reading system (if applicable - see General Information) instituted where by the volume shown by the sub-meter will be credited on the Sewer User Charges of the Bill.

353

**GENERAL INFORMATION**

Section 322.6C of the "Municipal Code of the City of Portland, Maine" reads as follows:

"Submetering of Water Volume. Any person who feels that recorded water records are not a reliable index of its discharge volume may install an additional water meter of a type approved by the Director or meet the volume of water shown not to enter the sewerage system. The person installing such a meter shall immediately notify the Director of such installation and shall be responsible to the Director for reporting water readings not less often than every three months. Such person shall be credited with the volume charges for the volume shown by such meter, which meter shall be accessible reading by the City or its agents at all reasonable times."

The City and the District have arranged to relieve the customer from the reporting responsibility required above in both meters can be read simultaneously by the District Meter Readers during their regularly scheduled visits to read the pre-existing service meter. This can be accomplished by locating the sub-meter directly adjacent to the pre-existing service meter or by mounting the sub-meter located elsewhere with a remote reading register located so data readings can be made at the same time.

Approved meters are Water and Rockwell meters, conforming to the following specifications:

- shall not exceed ANSI accuracy test requirements and
- be accompanied by a certificate of test accuracy;
- the meter will have straight reading, cubic foot register;
- the meter shall be Lagrange drive;
- shall have either a rotating disc or oscillating piston;
- shall have a bronze case.

Approved meters are available from the Water District, which sells them for the price the District has a them from the manufacturer. If you wish to purchase a sub-meter from the District you must bring your copy of an approved application with you at time of purchase.

**TO BE COMPLETED BY PUBLIC WORKS**

Pre-installation inspection by William B. Goodwin on April 1, 1983

Automatic reading system requested  YES  NO

A Watts No. 9 inline Back Flow Preventer or equal shall be installed in line

Application  Approved  Denied

Comments \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_


**TO BE COMPLETED BY THE PLUMBING INSPECTOR**

An inspection of the completed installation of the submetering system approved on this application was conducted on 7/18/83 by Ernest R. Goodwin, Chief Plumbing Inspector of the City of Portland.

The submetering system was installed as approved.

No cross connections were found.

The installation is  approved  dis-approved



**TO BE COMPLETED BY THE WATER DISTRICT**

Date submeter sold 6-30-83  
 Submeter account number DA5-8694  
 Submeter make and number 278-26073215  
 Submeter installation readings -2000028-  
 Submeter account entered into computer 7-14-83  
 Submeter account entered into meter book 7-18-83  
 Special Instructions \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_