


~~Vinyls~~ Variety

828 Danforth St.
Port. ME



All work will
be done using
Alga-metal.

All penetrations
will have a 3"
air space between
metal and any other
materials.

The wall under hood
will have a 24 ga.
metal covering with
a 1" air space between
metal and wall.

DEPT. OF BUILDING INSPECTIONS
CITY OF PORTLAND

OCT - 5 1987

RECEIVED



FILE IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 5, 1987

PERMIT ISSUED

OCT 15 1987

City Of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, ME

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications

Location 88 Danforth Street Use of Building store No Stories New Building Existing "
Name and address of owner of appliance Mr. Coyne, same
Installer's name and address Bay Sheetmetal, 155 Washington Ave. Telephone 761-2092

General Description of Work

To install kitchen exhaust system

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material from top of appliance or casing, top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
It gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner Size of vent pipe
Location of oil storage Number and capacity of tanks
Low water shut off Make No
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance behind counter Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

this is just an exhaust system that they are installing, not the stove

Amount of fee enclosed? 15.00

APPROVED:

James F. Collins, Seal

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

CS 306

INSPECTION FILE

Signature of Installer
APPLICANT'S ASSESSOR'S COPY

Hugh Irving

NOTES

Installed as per plan
sheet

Permit No.

Location

88 T. D. ...

Owner

Date of permit

Oct 15 / 87

Approved

[Large handwritten scribble]

[Empty lined area]