

INQUIRY BLANK

ZONE _____

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

FIRE DIST. _____

Verbal
By Telephone

Date _____

LOCATION 653 Congress St OWNER Reveries Inc

MADE BY Edgar Pappas TEL. 2-9202

ADDRESS 92 Spring St

PRESENT USE OF BUILDING Dine Room 1st & 2nd floors

CLASS OF CONSTRUCTION 2, 1 NO. OF STORIES 2

REMARKS: _____

INQUIRY: What afflic it or more Bldg. have
have to making 1st floor drug store
into restaurant with 2nd floor
of 75 partitions + 12 surf. in case at 1st
floor - no safe of mail & here no
safe - no safe means of egress

ANSWER: Special problem is now at
where there is no way now to reach
place of safety, etc. I mean one of
the building leading to Columbia Hotel
Stairway in road passing to 1st story
roof of Columbia Hotel - there to
to Columbia Hotel for escape
would not satisfy 2d b e

DATE OF REPLY 4/27/48 REPLY BY WHE



(C) GENERAL BUSINESS ZONE

PERMIT ISSUED
02330

APPLICATION FOR PERMIT TO ERECT SIGN OVER PUBLIC SIDEWALK OR STREET

Permit No. 231945

Portland, Maine, November 20, 1946

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 653a Congress Street

Within Fire Limits? yes Dist. No. 1

Owner of building to which sign is to be attached Tr. R. High Rises

Name and address of owner of sign Longfellow Studio, 453a Congress St.

Contractor's name and address United Neon Display, 71 Elm Street

Telephone 2-0695

When does contractor's bond expire? January 1, 1947

11-82-46, O.K. 2-26

Information Concerning Building

No. stories 2 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Electric? no Vertical dimension after erection 3' Horizontal 6'

Weight 80 lbs. Will there be any hollow spaces? yes Any rigid frame? yes

Material of frame angle iron No. advertising faces 2 material metal

No. rigid connections 2 Are they fastened directly to frame of sign? yes

No. through bolts none Size _____ Location, top or bottom _____

No. guys 3 material angle iron and gable Size 1 1/2 x 1 3/16" - 9/16"

Minimum clear height above sidewalk or street 13'6"

Maximum projection into street 6'8"

Fee \$ 1.00

Signature of contractor By: _____

United Neon Display

W. C. Roberts

Permit No. W4-2350

Location 653rd Congress St

Owner Longfellow Studios

Date of permit 11/23/46

Sign Contractor

Fiscal Inspn. 1/25/47. 1946

NOTES

*Permit to erect 17'
on top of high 6' wall
for sign*



PERMIT ISSUED

Permit No. _____

MAY 15 1941

(G) GENERAL BUSINESS ZONE

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, ~~May 15, 1941~~

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 653 Congress St Use of Building Store No. Stories 2 ~~New Building~~
Name and address of owner of appliance Royal Drug Store, 653 Congress St Existing "

Name and address of owner of appliance Yossi Drug Store, 553 Congress St. No. Stories 2 Existing "

Installic's name and address, Portland Gas Light Co., 5 Temple Street Telephone 2-5321

General Description of Work

To install ~~224~~ ~~224~~ ~~224~~

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? no If not, which story 1st Kind of Fuel gas

Material of supports of appliance (concrete floor or what kind) road - 6" logs

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, _____

from top of smoke pipe _____ from front of appliance 1' _____ from sides or back of appliance 6"

Size of chimney flue _____ Other connections to same flue _____
Hood to be provided with _____ from sides or back of appliance 6"

Hood to be provided which is vented to outside air
Enclosed burners produce 13,000 Btu/hr IF OIL BURNER

Enclosed burners produce 13,000 BTU per hour. IF OIL BURNER

Name and type of burner _____

Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____

Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) _____

Location oil storage _____
Will all tanks be _____

Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? 1.22 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY James B. [Signature] Signature of Installer [Signature] [Signature] [Signature]

INSPECTION COPY Wanda B. B. B. Signature of Installer. By Carl M. M. 45

Permit No.

41/680

Location

653 Congress St.

Owner

For Dug Store

Date of Permit

5/13/41.

Post Card sent

Notification

INSPECTION NO. COMPLETED

Approval Tag issued

41/289

On Burner Check List (date)

1. Kind of heat

2. Label

3. Anti-siphon

4. Oil storage

5. Tank distance

6. Vent Pipe

7. Fill Pipe

8. Gauge

9. Rigidity

10. Feed safety

11. Pipe sizes and material

12. Control valve

13. Ash pit vent

14. Temp. or pressure safety

15. Instruction card

16.

NOTES

Rept. 8357C-I

March 11, 1941

Mr. Ernest L. Foss,
653 Congress Street,
Portland, Maine

Dear Sir:

Enclosed is the building permit covering alterations in the drug store at 653 Congress Street to partition off a new kitchen. Please note the following:

Because food is evidently going to be prepared and served on the premises and because the Building Code provides that no toilet room shall open directly into any room where food is prepared or served, it is necessary that you supply a suitable self-closing device on each toilet room door and on the door leading from the rear room and the drug store, this rear room being the one through it is necessary to pass in order to reach the toilet rooms. By the term "self-closing" is meant a door which is normally closed and kept closed by a suitable device such as a door check or a suitable spring. Each of these three doors must fit its opening tightly.


Because this kitchen is to be a room without any outside windows in it, I understand that the Health Department is requiring that some type of mechanical ventilation be provided for the room, that the hood over the cooking appliance be vented suitably to the outside air. A sketch which has been supplied with the application for the permit seems to show an intake fan intended to take cold air from the outside, push it through a metal duct into the kitchen, and another exhaust fan designed to draw air from the kitchen through a metal duct and discharge it outside the building. I claim no particular knowledge of ventilation design, but from what knowledge I have I doubt if this arrangement will work satisfactorily. To the contrary, I believe the diverse currents of air introduced will not only fail to ventilate the kitchen, but may seriously interfere with the operation of any fire-actuated device in the kitchen. I am sure this department and I doubt if the Health Department either will take any responsibility for the satisfactory operation of this arrangement. If it is put in operation and does not work satisfactorily, especially if it seems to interfere or make hazardous the use of the appliances in the kitchen or elsewhere, it will be necessary to change it when such conditions are found out. If you contemplate now cooking or hot water heating devices in the kitchen, when permits for those appliances are applied for we shall have to go into the matter of their safe operation under those circumstances with the installer very carefully.

Under the circumstances the best advice I can give is either that you extend the kitchen to the rear, relocating one toilet room and then provide an outside window in the kitchen and eliminate the complex ventilating system, or else employ a ventilation engineer of un doubted ability to design a ventilation system that will work under all circumstances, taking into account all factors.


Very truly yours,

Inspector of Buildings

WAB/H
CC: National Bank of Commerce, Tr., 467 Congress St.
Dr. Treasau



RECEIVED
MAR 5 - 1941
DET. OF ENGS. Insp.
CITY OF PORTLAND



REAR
GUTS
TOILET

SODA FOUNTAIN

Toilet



GENERAL BUSINESS
APPLICATION FOR PERMIT

PERMIT ISSUED

Permit No. 0289

Class of Building or Type of Structure Second Class

MAR 11 1941

Portland, Maine, March 5, 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~construct~~ install the following building structure ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 653 Congress Street Within the Limits? yes Dist. No. 1

Owner's name and address National Bank of Commerce, Trust Co. Telephone 3-7569

Contractor's name and address Ernest L. Foss, 653 Congress St. Telephone 3-7569

Architect _____ Plans filed yes No. of sheets 1

Proposed building Drug Store and Offices No. families _____

Other buildings on same lot _____

Estimated cost \$ 150 Fee \$.75

Description of Present Building to be Altered

Material brick No. stor. 2 Heat _____ Style of roof _____ Roofing _____

Last use Drug Store and Offices No. families _____

General Description of New Work

To partition off new kitchen 6' x 13' in rear room of store - 2x4 studs 12" OC covered on both sides with sheet rock - room to be ventilated by mechanical ventilator
To cut in one new door to this room

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

CITY OF PORTLAND
REQUIREMENT IS WAIVED

Is any plumbing work involved in this work? yes

Is any electrical work involved in this work? yes Height average grade to top of plate _____

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Framing lumber—Kind _____ Dressed or full size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts full one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

National Bank of Commerce, Trust Co.

Signature of owner

INSPECTION COPY

Wm B. Bunting

Ernest L. Foss

Permit No. 41/283

Location 653 Congress St.

Owner Nail Bank of Congress
Trust

Date of permit 3/1/74

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. INSPECTION NOT COMPLETED

Go Range 41/200
City of Occupancy issued

NOTES

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.


April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

April 1st. Work started.

Congress St. entrance




Present Toilet

Present Window
(or vent) 3' x 4'

54'

New Toilet

Present 3' x window
for vent. 2'



main floor



(G) GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

Permit No. 0240

MAR 16 1940

Class of Building or Type of Structure second

Portland, Maine, Mar. 16, 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building ~~structure~~ ^{equipment} in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 653 Congress St. Within Fire Limits? yes Dist. No. 1
Owner's or ~~lessee's~~ name and address Edward L. Foss Est. Boston Mass. Telephone 9-3732
Contractor's name and address C. F. Hanson 153 Franklin St. Plans filed No. of sheets
Architect No. families
Proposed use of building Drug Store
Other buildings on same lot Fee \$.50
Estimated cost \$ 40

Description of Present Building to be Altered

Material brick No. stories 4 Heat Style of roof Roofing
Last use Drug Store No. families

General Description of New Work

To provide new toilet for Drug Store, partitions to be 2x3 studs 16" ~~stud~~ ^{O.C.} covered with sheathing both sides door to be at least 24" wide and made self-closing present window at least 3 Sq. ft. in area for ventilation.
Toilet to be 7' high covered on top

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED
O.C.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? yes
Is any electrical work involved in this work? Height average grade to top of plate
Size, front depth No. stories Height average grade to highest point of roof
To be erected on solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of Roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining
Kind of heat Type of fuel Is gas fitting involved?
Framing Lumber Kind Dressed or Full Size?
Corner posts Sills Girt or ledger board? Size
Material columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor , 2nd , 3rd , roof
On centers: 1st floor , 2nd , 3rd , roof
Maximum span: 1st floor , 2nd , 3rd , height?

If one story building with masonry walls, thickness of walls?
Is a Garage

No. cars now accommodated on same lot , to be accommodated
Total number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Signature of owner Edward L. Foss Est.

INSTRUCTION COPY

Wm. B. Runkle

C. F. Hanson

65320

Permit No.

40/240

Location

653 Congress St.

Owner

Edward L. Ford Est.

Date of permit

3/16/40

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

4/6/40. C.H.

Cert. of Occupancy issued

None

NOTES

3/20/40. For one working.
Toilet almost done but
not satisfactory. Door 22"
wide with self-closing
Partitions consists of corner
studs with horizontal
boards inserted between
flange and the enclosure
with vertical bracing.
C.H.

3/20/40. Mr. Hammond
was in and
told him the
only thing he could
do is to make it
according to
application.
-mmd

3/21/40. Mr. Hammond called
this morning to rebuild
no called for it.

3/23/40. I could not
show for fully and corner
studs needed. C.H.

3/25/40. Work done except
corner studs on inside
check with restaurant
map regarding them.
C.H.

4/1/40. This work all done.
Toilet window in toilet
to have pane made to
open and give 36" vent-
ilation. C.H.



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

PERMIT ISSUED

JUL 29 1929 1432

Portland, Maine, July 29, 1929

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ alter ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 653A Congress Street Ward 5 Within Fire Limits? Yes Dist. No. 1Owner's or Lessee's name and address R. H. Rines, Charman Bldg. Telephone _____Contractor's name and address H. O. Strom, 686 Sawyer St. So. Portland Telephone F 9713

Architect's name and address _____

Proposed use of building Store and offices No. families _____

Other buildings on same lot _____

Description of Present Building to be Altered

Material brick No. stories 2 Heat _____ Style of roof _____ Roofing _____Last use store and offices No. families _____

General Description of New Work

To remove existing double door to entrance to second floor, and replace with single door, recessed in 20" more than existing doors which are 6' 10" in from sidewalk,

Door to swing outward, but not over sidewalk

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Distance, heater to chimney _____

If oil burner, name and model _____

Capacity and location of oil tanks _____

Is gas fitting involved? _____ Size of service _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? noPlans filed as part of this application? no No. sheets _____Estimated cost \$ 95. Fee \$.50

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of owner _____

R. H. Rines
Henry O. Strom

INSPECTION COPY

1471

Ward 5 Permit No. 29/1432

Location 653 A - Congress St

Owner R H Pines

Date of permit 7/29/29

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

NOTES

8/2/29 - New door frame
in casing on. Three
foot door when hung
will swing outward
but not over sidewalk.
AJS

X



OFFICE HOURS
10 TO 12 M.
4 TO 5 P. M.

City of Portland.

OFFICE OF INSPECTOR OF BUILDINGS

R-1 1911

To the Inspector of Buildings of the City of Portland:

The undersigned respectfully makes application for a permit to erect/enlarge a building on.....
.....street, at number.....to be.....
.....feet long.....
.....stories high.....
feet wide; also an addition to be.....stories high.....
feet long.....feet wide, and to be used as a.....

CELLAR WALL—To be constructed of.....to be.....inches wide on bottom and
batter to.....inches on top.

UNDERPINNING—To be.....Height of underpinning from top of cellar wall to bottom of
sill.....ft.....inches to be.....inches in thickness.

EXTERIOR WALLS—To be constructed of.....If of Brick, Stone, etc. Total length of wall
.....ft.....inches. Thickness of 1st.....2d.....3d.....4th.....
5th.....6th.....story walls. If of reinforced concrete state mix and reinforcing system
to be used.

If wood construction, sills to be.....Girders.....
Posts.....Girts.....Studs.....to be spaced.....

This building will be used for the purposes of.....(If for apartments,
tenements, or other family uses state number of families accommodated and number on each floor.
If for manufacturing or mercantile purposes state character of business and amount of estimated
weight to be carried by the floor.)
Number of families on floor.....
Total number of families.....
Manufacturing (state character).....
Estimated load on floors per sq. ft.....
Mercantile business (state character and load per sq. ft.).....

If building is used for tenement house or family use and more than one family, the following provis-
ions of the Building Laws regarding dividing partitions shall be adhered to (Quote Law re. this).

FIRESTOPS—All bearing and center partitions will have firestops cut in.....light on top of each partition cap
and between each set of floor timbers. Where ledger boards are used there shall be firestops cut in
tight against bottom of ledger boards, of same size as wall studs. Also wherever the Inspector of
Buildings may consider necessary.

STAIRWAYS—No. in building.....location.....to be enclosed
with.....walls to be lathed with.....lathing.

ROOF—To be constructed of.....Rafters to be.....inches to be spaced.....
.....inches on centers. Roof to be covered with.....
Gutters to be made of.....Cornices to be made of.....
Bay windows to be made of.....to be covered with.....
Dormer Windows to be made of.....to be covered.....
Chimneys, Smoke flues to be lined with.....and provided with a 10 inch outside collar and an
inside collar to go to the inside of the flue.

Estimated Cost of Building.....
INSPECTION—The Inspector of Buildings is to be notified when building is ready for lathing and at least
24 hours before the lathing is begun.

The Builder is.....Address.....
The Architect is.....Address.....
The Owner is.....Address.....
No Deviation will be made from the above application without written permission from the Inspector of
Buildings.
The above petition was granted the.....day of.....1911.

(Applicant to sign here)

Albert S. Nelson



City of Portland.

3445

9-22 1911

To the Inspector of Buildings of the City of Portland:

The undersigned respectfully makes application for a permit to erect enlarge a building on Longview street, at number 655 to be _____ stories high _____ feet long, _____ feet wide; also an addition to be _____ stories high, _____ feet long, _____ feet wide, and to be used as a _____

The material to be used in the erection enlargement of said building is to be as follows:

Exterior walls to be made of Good covered with iron

Roof to be made of General Rip Rap

Gutters to be made of Metal

Cornices to be made of To be covered with tin

Bay windows to be made of _____

Dormer windows to be made of _____

The builder is River Address Longview St

The architect is " Address "

The owner is " Address "

(Applicant to sign here)

River

OFFICE OF
INSPECTOR OF BUILDINGS,
FOR THE
CITY OF PORTLAND.

OFFICE HOURS:
10-11 A. M. 4-6 P. M.

The above petition was granted the 22 day of Sept 1911

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee \$30.00 Zone _____ Map # _____ Lot# _____

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Neon Diner Phone # _____
 Address: 653 Congress Street Portland
 LOCATION OF CONSTRUCTION 653 Congress Street
 Contractor: Biltarm Sheet Metal Co.
 Address: 155 Washington Ave. Port Phone # 761-2092
 Est. Construction Cost: 2,000.00 Proposed Use: Diner
 Past Use: _____
 # of Existing Res. Units _____ # of New Res. Units _____
 Building Dimensions L _____ W _____ Total Sq. Ft. _____
 # Stories _____ # Bedrooms _____ Lot Size: _____
 Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
 Explain Conversion to install hood as per plan - to replace existing hood

For Official Use Only
 Date January 16, 1990 Subdivision: _____
 Inside Fire Limits _____ Name _____
 Bldg Code _____ Lot _____
 Time Limit _____ Ownership: _____ Public _____ Private _____
 Estimated Cost: 2000.00
 Zoning: B-7 Business
 Street Frontage Provided: _____
 Provided Setbacks: Front _____ Back _____ Side _____ Side _____
 Review Required:
 Zoning Board Approval: Yes _____ No _____ Date: _____
 Planning Board Approval: Yes _____ No _____ Date: _____
 Conditional Use: _____ Variance _____ Site Plan _____ Subdivision _____
 Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
 Special Exception _____
 Other (Explain): OK WPA 1-25-90

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other: _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____
3. Type Ceiling: _____
4. Insulation Type _____ Size _____
5. Ceiling Height: _____

Roof:

1. Truss or Rafter Size _____ Span _____
2. Sheathing Type _____ Size _____
3. Roof Covering Type _____

Chimneys:

1. Type: _____ Number of Fire Places _____

Heating:

1. Type of Heat: _____

Electrical:

1. Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By Latini

Signature of Applicant Bill Glavin Date 1-16-90

Signature of CBO William Glavin Date 1-22-90

Inspection Dates _____

10 Hugh Irving

White-Tax Assessor

Yellow-GPCOG

White Tag -CEO

© Copyright GPCOG 1988