

29A PINE STREET

MADE IN U.S.A.
GARY WALKER
1963-3R

NOTES

5-9-52 work complete

Handwritten notes on a set of horizontal lines.

Large set of horizontal lines for notes, currently blank.

Large set of horizontal lines for notes, currently blank.

Permit No. 52/413

Location 29 A Power Pl.

Owner Christian Hillier

Date of permit 4/9/52

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 5-9-52 WJH

Cert. of Occupancy issued

5-9

ONE ON ORDER



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 2, 1951

PERMIT ISSUED NOV 2 1951 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 29A Pine Street Use of Building Dwelling No. Stories 1 1/2 No. Existing 1 No. Existing 1 Name and address of owner of appliance Christos Linas, 29A Pine Street Installer's name and address J. B. Smith, 102 Oak Street Telephone 3-2615

General Description of Work

To install 301 steam heat (replacement)

IF HEATER, OR POWER BOILER

Location of appliance or source of heat Cellar Type of floor beneath appliance Concrete If wood, how protected? Kind of fuel oil Minimum distance to wood or combustible material, from top of appliance or casing top of furnace 30" From top of smoke pipe 12" with shield From front of appliance over 4' From sides or back of appliance over 3' Size of chimney flue 8x10 Other connections to same flue none If gas fired, how vented? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Labeled by underwriters' laboratories? Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? Type of floor beneath burner Location of oil storage Number and capacity of tanks If two 275-gallon tanks, will three-way valve be provided? Will all tanks be more than five feet from any flame? How many tanks fire proofed? Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Kind of fuel Type of floor beneath appliance If wood, how protected? Minimum distance to wood or combustible material from top of appliance From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

(Burner permit to be taken out by others)

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] 11-2-51

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of Installer

[Signature]

39592 (2218 2012) (Jim Lawler - 78369)
4617 (Tanner) (NOTES)

Permit No. 51/2233
Loc Ion 591
Owner Charles Stewart
Date of permit 11/21/51
APPROVED

3-1-52 711 for value of burner
with instructions - Card
R. 715

6-17-52. 711 at burner
R. 715

6-20-52 burner says burner
has completed the
installation
R. 715

6-16-52 could not
get in
R. 715

