

10 BLYTH COURT

SEARCHED
SERIALIZED
INDEXED
MAR 24 1964

PERMIT TO INSTALL PLUMBING

Date Issued: 9-17-63
PORTLAND PLUMBING INSPECTOR

By: J. P. Yeloh
APPROVED FIRST INSPECTION

Date: 9-26-63
By: [Signature]
APPROVED FINAL INSPECTION

JOSEPH P. WELCH
TYPE OF BUILDING

- COMMERCIAL
- RESIDENTIAL
- SINGLE
- MULTI FAMILY
- NEW CONSTRUCTION
- REMODELING

Address: 10 Blyth Court
 Installation For: Faith E. Obeir
 Owner of Bldg: Faith E. Obeir
 Owner's Address: 50 Pine Street
 Plumber: Wilbur P. Lund

13262
PERMIT NUMBER

PROPOSED INSTALLATIONS	Date: 9-17-63	
	NUMBER	FEES
SINKS		
LAVATORIES		
TOILETS		
BATH TUBS		
SHOWERS		
DRAINS		
HOT WATER TANKS		
TANKLESS WATER HEATERS		
GARBAGE GRINDERS		
SEPTIC TANKS		
HOUSE SEWERS	1	\$ 2.00
ROOF LEADERS (Conn. to house drain)		

PORTLAND HEALTH DEPT. PLUMBING INSPECTION
 TOTAL ▶ \$ 2.00



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, September 11, 1963

ISSUED SEP 11 1963 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 10 Elvth Court Use of Building Dwelling 2-fam. No. Stories New Building Existing
Name and address of owner of appliance Miss Faith E. O'bear, 59 Pine St., Portland, Me
Installer's name and address Lunt Heating Service Corp., 585 Broadway Telephone

General Description of Work

To install forced hot water heating system and oil burning equipment in place of stove heat

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3'
From top of smoke pipe 18" From front of appliance 4' From sides or back of appliance 3'
Size of chimney flue 8x10 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Weil McLain Labeled by underwriters' laboratories? Yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 1-275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED: OK 9-11-63 [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Lunt Heating Service Corp.

Signature of Installer By: [Signature]

INSPECTION COPY

P/6