

45 Carleton Street

BRAMHALL

STANDARD
#8503-3R

April 17, 1967

J. B. Brown and Sons
57 Exchange Street
Portland, Maine

Sirs:

RE: 43 Carleton Street



CITY OF PORTLAND

JOSEPH E. McDONOUGH
FIRE CHIEF

October 24, 1984

Mr. & Mrs. Owen G. & Ruth W. Evans Jts.
43 Carleton Street
Portland, Maine 04102

Re: Smoke Detectors

Dear Mr. & Mrs. Evans:

During a recent inspection of the property owned by you at 43 Carleton Street, it was noted that smoke detectors were missing in the following areas:

All the rooming units.

25 MRSA §2464 requires that approved smoke detectors be installed in each of the above listed areas. Failure to comply with this statute may result in a fine of up to \$500 for each violation.

Re-inspection of your property will be made in ten (10) days. Lack of compliance will result in referral of the matter for legal action.

Sincerely yours,
Joseph E. McDonough
Chief of the Fire Department
City of Portland

Merlin Leary
Merlin Leary

Code Enforcement
Officer (5)

cc: Lt. James Collins, Fire Prevention Bureau

jmr