

7-11 BUSHMAN STREET



Full cut # 920R - Half cut # 910/R - Third cut # 9203R - Fifth cut # 9205R



CITY OF PORTLAND

JOSEPH E. McDONOUGH
FIRE CHIEF

September 23, 1981

Mr. Rupert Edwards
34 Underwood Road
Falmouth, Maine 04105

Re: 11 Cushman St.

Dear Mr. Edwards:

Your permit application to renovate first and second floors, at the above named address, is hereby approved subject to the following conditions:

- CODE #
10. All doors involved in the means of egress shall be equipped with latch sets which shall open from the inside without the use of keys, special knowledge, or ability, but by merely turning the usual knob or by pressure on a plate or lever.
11. The boiler room shall be enclosed with construction having a fire rating of at least one hour, including the ceiling, and fire door with self-closers.
14. All vertical openings (stairways) shall be enclosed with construction having a fire rating of at least one hour including fire door with self-closers.
16. Each apartment shall be equipped with a single station smoke detector wired to the house current. These detectors shall be placed in a manner which will protect the sleeping areas.
18. Each apartment shall have access to two separate and remote approved exits. Upon entering the exit enclosures, one shall be able to remain in the protected enclosure until reaching the building exterior.
25. Each apartment unit shall have a one hour fire separation from an adjoining unit. This separation shall extend from the basement or lowest level, through to the under part of the roof.

If I may be of any further assistance, please feel free to contact me at 775-5451, Ext. 350.

Yours truly,

Lt. James P. Collins
Fire Prevention Bureau

JPC/jmr

109 MIDDLE STREET • PORTLAND, MAINE 04101 • TELEPHONE (207) 775-6361



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION PORTLAND, MAINE, Sept. 17, 1981

PERMIT ISSUED

SEP 23 1981

1001-995
CITY OF PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 11 Cushman St. Fire District #1 , #2

1. Owner's name and address James Mackey Telephone

2. Lessee's name and address Telephone

3. Contractor's name and address Rupert Edwards 34 Underwood Rd. Telephone 781-2161
Palmouth

Architect Specifications Plans No. of sheets

Proposed use of building apt. No. families

Present use No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 2,000. Fee \$ 20.

FIELD INSPECTOR—Mr. [Signature] GENERAL DESCRIPTION

This application is for @ 775-5451 To renovate 1st & second floor, will close
Dwelling Ext. 234 doors as marked - replace & patch sheet rock
Garage as per plan

Masonry Bldg. Stamp of Special Conditions

Metal Bldg.

Alterations

Demolitions

Change of Use

Other

PERMIT ISSUED WITH LETTER

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 2 3 4
Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimney of lining Kind of heat fuel

Framing Lumber—Kind Dressed size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated ... number commercial cars to be accommodated ...

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? ..

ZONING:

BUILDING CODE Will there be in charge of the above work a person competent

Fire Dept. [Signature] See that the State and City requirements pertaining thereto

Health Dept. [Signature] are observed? yes

Others: [Signature] WITH LETTER

Signature of Applicant Rupert H. Edwards Phone #

Type Name of above Rupert H. Edwards 1 2 3 4

Other and Address

FIELD INSPECTOR'S COPY

4

NOTES

Permit No. 51/993

Location 11 Chestnut

Owner James Mackery

Date of permit 9-25-81

Approved

10/5/81 All partition of wall OK to close in. Eple & plumbing OK, checked across throughout the building. Contractor has a copy of St Collins letter Re: other repairs needed. Smoke detector locations approved.


11/17/81 The excavation work is now complete. A concrete slab should be installed in next few days. The work is about 2/3 completed. The rest of it will be completed by the end of the year.

12/17/82 Excavation work is now complete. A concrete slab should be installed in next few days. The work is about 2/3 completed. The rest of it will be completed by the end of the year.

1/13/82 Satisfactory progress - (slow but good work)

1/30/82 About completed.

1-12-83



PERMIT TO INSTALL PLUMBING

PERMIT NUMBER **2421**

Date Issued **10-7-81**
 Portland Plumbing Inspector
 By **ERNOLD R GOODWIN**

App. First Insp.
 Date **OCT 8 1980**
 By **ERNOLD R GOODWIN**

App. Final Insp.
 Date **OCT 21 1980**
 Type of Bldg.

- Commercial
- Residential
- Single
- Multi Family
- New Construction
- Remodeling

Address 11 Cushman St.			
Installation For multi family			
Owner of Bldg Rozzi Davis			
Owner's Address John Douglass-129 Holm Ave		Date: 10-7-81	
NEW	REPL	NO	FEE
<input checked="" type="checkbox"/>		2	6.00
	SINKS		
<input checked="" type="checkbox"/>		1	3.00
	LAVATORIES		
	TOILETS	1	3.00
	BATH TUBS		
	SHOWERS	1	3.00
<input checked="" type="checkbox"/>	REFAINS	FLOOR SURFACE	
	HOT WATER TANKS		
	TANKLESS WATER HEATERS		
	GARBAGE DISPOSALS		
	SEPTIC TANKS		
	HOUSE SEWERS		
	ROOF LEAKERS		
	AUTOMATIC WASHERS		
	DISHWASHERS		
	OTHER		
TOTAL			15.00

Building and Inspection Services Dept: Plumbing Inspection



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date September 17, 19 81
 Receipt and Permit number A73170

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 11 Cushman St. - 1st & 2nd Floors
 OWNER'S NAME: James Mackey ADDRESS: same

		FEES
OUTLETS:	Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL 1-30 _____	3.00 ✓
FIXTURES: (number of)	Incandescent <u>x</u> _____ Fluorescent _____ (not strip) TOTAL 1-10 _____	3.00 ✓
	Strip Fluorescent _____ ft. _____	
SERVICES:	Overhead _____ Underground _____ Temporary _____ TOTAL ampere _____	
METERS: (number of)	_____	
MOTORS: (number of)	Fractional _____	
	1 HP or over _____	
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____	
	Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____	
	Oil or Gas (by separate units) _____	
	Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	Ranges _____ Water Heaters _____	
	Cook Tops _____ Disposals _____	
	Wall Ovens _____ Dishwashers _____	
	Dryers _____ Compactors _____	
	Fans _____ Others (denote) _____	
	TOTAL _____	
MISCELLANEOUS: (number of)	Branch Panels _____	
	Transformers _____	
	Air Conditioners Central Unit _____	
	Separate Units (windows) _____	
	Signs 20 sq. ft. and under _____	
	Over 20 sq. ft. _____	
	Swimming Pools Above Ground _____	
	In Ground _____	
	Fire/Burglar Alarms Residential _____	
	Commercial _____	
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
	over 30 amps _____	
	Circus, Fairs, etc. _____	
	Alterations to wires _____	
	Repairs after fire _____	
	Emergency Lights, battery _____	
	Emergency Generators _____	
	INSTALLATION FEE DUE: _____	
	FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____	
	FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	
	TOTAL AMOUNT DUE: <u>6.00</u>	

INSPECTION: Will be ready on _____, 19__; or Will Call x
 CONTRACTOR'S NAME: ~~Russell Edwards~~ Gordon Doyle
 ADDRESS: 84 Underwood Rd., Falmouth, Me. (14)
 TEL: 781-221-4741
 MASTER LICENSE NO.: 03064 SIGNATURE OF CONTRACTOR: Gordon Doyle
 LIMITED LICENSE NO.: Gordon Doyle Russell Edwards

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS -

Permit Number

73170

Location

11 Cashman St.

Owner

J. Facchini

Date of Permit

9-17-81

Final Inspection

11-18-81

By Inspector

E. Kelly

Permit Application Register Page No.

99

INSPECTIONS: Service _____ by _____

Service called in _____

Closing-in 9-17-81 by Kelly

PROGRESS INSPECTIONS: _____

11-18-81

CODE
COMPLIANCE
COMPLETED
DATE: 11-18-81

REMARKS:

REMARKS: _____



APPLICATION FOR PERMIT
 DEPARTMENT OF BUILDING INSPECTIONS SERVICES
 ELECTRICAL INSTALLATIONS

Date Aug. 28, 19 79
 Receipt and Permit number A 34707

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine.
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
 Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:
 LOCATION OF WORK: 11 Cushman St. ADDRESS: lives there
 OWNER'S NAME: James Mackey

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL <u>1.30</u>	FEE <u>3.00</u>
FIXTURES: (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____		
	Strip Flourescent _____	ft. _____			
SERVICES:	Overhead <input checked="" type="checkbox"/>	Underground _____	Temporary _____	TOTAL amperes <u>200</u>	FEE <u>3.00</u>
METERS: (number of) <u>1</u>					FEE <u>.50</u>
MOTORS: (number of)	Fractional _____				
	1 HP or over _____				
RESIDENTIAL HEATING:	Oil or Gas (number of units) _____				FEE <u>4.00</u>
	Electric (number of rooms) <u>4</u>				
COMMERCIAL OR INDUSTRIAL HEATING:	Oil or Gas (by a main boiler) _____				
	Oil or Gas (by separate units) _____				
	Electric Under 20 kws _____	Over 20 kws _____			
APPLIANCES: (number of)	<input checked="" type="checkbox"/>	Water Heaters <input checked="" type="checkbox"/>			
Ranges _____		Dishwashers _____			
Cook Tops _____		Compactors _____			
Wall Ovens _____		Others (denote) _____			FEE <u>4.50</u>
Driers <input checked="" type="checkbox"/>					FEE <u>2x10x</u>
Fans _____					
MISCELLANEOUS: (number of)					FEE <u>1.00</u>
Branch Panels <u>1</u>					
Transformers _____					
Air Conditioners Central Unit _____					
	Separate Units (windows) _____				
Signs 20 sq. ft. and under _____					
	Over 20 sq. ft. _____				
Swimming Pools Above Ground _____					
	In Ground _____				
Fire/Burglar Alarms Residential _____					
	Commercial _____				
Heavy Duty Outlets, 220 Volt: (such as welders) 30 amps and under _____					
	over 30 amps _____				
Circus, Fairs, etc. _____					
Alterations to wires _____					
Repairs after fire _____					
Emergency Lights, battery _____					
Emergency Generators _____					
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT _____				INSTALLATION FEE DUE:	
FOR REMOVAL OF A "STOP ORDER" (304-10 b) _____				DOUBLE FEE DUE:	
				TOTAL AMOUNT DUE:	<u>16.00</u>

INSPECTION: Will be ready on ready, 19 79; or Will Call _____
 CONTRACTOR'S NAME: Mellow Electric
 ADDRESS: Box 5134
 TEL.: _____
 MASTER LICENSE NO.: 03580 SIGNATURE OF CONTRACTOR: [Signature]
 LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

**CERTIFICATE OF APPROVAL
FOR INTERNAL PLUMBING**

THE TOWN/CITY OF Portland

TOWN/CITY CODE 035710 LPI NUMBER 011723 DATE ISSUED 8/20/79
Month Day Year

No **32722 IC**

Certificate of App. Number

Installer Name W. J. [unclear] F. I. M. I. [unclear]

Installer Code 2

- 1. Owner
- 2. Licensed Master Plumber
- 3. Licensed Oil Burnerman
- 4. Employees of Public Utilities
- 5. Manufactured Housing Dealer
- 6. Manufactured Housing Mechanic

Owner Name [unclear]
Address St./Lot Number [unclear] Street/Road Name [unclear] Subdivision [unclear]
(Location where plumbing was done and inspected)

THE INTERNAL PLUMBING INSTALLED PURSUANT TO THE ABOVE CERTIFICATE OF APPROVAL NUMBER HAS BEEN TESTED IN MY PRESENCE, FOUND TO BE FREE FROM LEAKS, AND WAS INSTALLED IN COMPLIANCE WITH THE MUNICIPAL AND STATE PLUMBING REGULATIONS.

OWNER'S COPY

Signature of LPI [Signature]

Date Inspected **AUG 20 1979**

ORIGINAL--To be sent to: Department of Human Services,
Division of Health
Engineering, Augusta, Maine 04333

INTERNAL PLUMBING PERMIT FOR THE TOWN/CITY OF

Town/City Code 035710 LPI Number 011723 Date Issued 8/20/79 INSTALLER'S License No. [unclear]
Month Day Year

No **32722 IP**

PERMIT NUMBER

Address of Where Plumbing is Done St./Lot Number [unclear] Street/Road Name [unclear] Subdivision [unclear]

- Installer Code 2
- 1. Owner
 - 2. Licensed Master Plumber
 - 3. Licensed Oil Burnerman
 - 4. Employees of Public Utilities
 - 5. Manufactured Housing Dealer
 - 6. Manufactured Housing Mech

Name of Owner Last Name [unclear] F. I. M. I. [unclear] Mailing Address [unclear] Zip Code [unclear]

Type of Construction: 1. New, 2. Remodeling, 3. Addition, 4. Renovation & Addition, 5. Replacement of Hot Water Heater, 6. Hook-up of Mobile Home, 7. Hook-up of Modular Home, 8. Other (Specify) [unclear]

Plumbing To Serve: 1. Single (Res. or Farm/Res), 2. Mobile Home or Modular Home, 3. Commercial, 4. School, 5. Other (Specify) [unclear]

Number of Fixtures or Hook-Ups: Sinks(s) 1, Toilets(s) 1, Bath(s) 1, Lavatory(s) 1, Shower(s) 1, Urinal(s) 0, Clothes Washer(s) 0, Dish Washers(s) 0, Hot Water Heater(s) 1, Floor Drain(s) 0, Hook-Up(s) 0

This "Internal Plumbing Permit" is invalid if work is not commenced within 3(3) months from date of issuance. Upon completion of work a "Certificate of Approval" must be obtained from the LPI.

SCHEDULE OF "FEES"

1-10	Fixtures	\$2.00 each
11-20	Fixtures	\$1.00 each
21	Fixtures	\$.50 each
	Hook-Ups	\$2.00 each

Fixture Fee 17
Hook-Up Fee 00
Administrative Fee 300
Total Fee 317
If Double Fee Check Box

TOWN'S COPY

Signature of LPI [Signature] HHE 211 Rev. 4/75



APPLICATION FOR PERMIT

RECEIVED 195079

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION 000704

1979

ZONING LOCATION PORTLAND, MAINE, . Aug. 17, 1979 CITY OF PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 11 Cushman Street Fire District #1 #2

1. Owner's name and address James C. Mackey & Rosalyn Davis Telephone 772-6278

2. Lessee's name and address Telephone

3. Contractor's name and address Telephone

4. Architect Specifications Plans No. of sheets

Proposed use of building 3 family No. families

Last use 2 family No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 8,000 Fee \$ 37.00

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451

Dwelling Ext. 234

Garage

Masonry Bldg.

Metal Bldg.

Alterations

Demolitions

Change of Use with alterations

Other

To change use from 2 to 3 family with alterations to 3rd floor no structural changes. Stamp of Special Conditions as per plans. 1 sheet of plans.

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 2 3 4

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining Kind of heat fuel

Framing Lumber—Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girder Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. P in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated ... number commercial cars to be accommodated ... Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING:

BUILDING CODE:

Fire Dept.:

Health Dept.:

Others:

MISCELLANEOUS

Will work require disturbing of any tree on a public street? ..

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant Rosalyn Davis Phone # same

Type Name of above Rosalyn Davis 1 2 3 4

Other and Address

OFFICE FILE COPY

PERMIT TO INSTALL PLUMBING

Date Issued: 1-15-62
 Address: 11 Cushman Street
 Installation For: Mrs. S. K. Stein
 Owner of Bldg.: Mrs. S. K. Stein
 Owner's Address: 11 Cushman Street
 Plumber: Henry Caryl Company Date: 1-15-62
 By: J. P. Welch

APPROVED FIRST INSPECTION	NEW	REPL	PROPOSED INSTALLATIONS	NUMBER	FEE	
			SINKS			
			LAVATORIES			
			TOILETS			
			BATH TUBS			
			SHOWERS			
			DRAINS			
			HOT WATER TANKS			
			TANKLESS WATER HEATERS			
			GARBAGE GRINDERS			
			SEPTIC TANKS			
			HOUSE SEWERS			
			ROOF LEADERS (Conn. to house drain)			
	1		LOAD BEAR	1	\$ 2.00	
					TOTAL	\$ 2.00

Date: Jan 15 1962
 By: JOSEPH P. WELCH
 APPROVED FINAL INSPECTION
 Date: Jan 17 1962
 By: JOSEPH P. WELCH

TYPE OF BUILDING
 COMMERCIAL
 RESIDENTIAL
 SINGLE
 MULTI FAMILY
 NEW CONSTRUCTION
 REMODELING

PORTLAND HEALTH DEPT. PLUMBING INSPECTOR

PERMIT NUMBER 9816

PERMIT TO INSTALL PLUMBING

Date Issued 3/3/61

Address: 7 Cushman Street

PORTLAND PLUMBING INSPECTOR

Installation For: Mrs. H. Randall

Owner of Bldg.: Mrs. H. Randall

Owner's Address: 22 Bradford Street

By J. P. Welch

Plumber: Harry Carvel Company Date: 3/3/61

APPROVED FIRST INSPECTION

NEW	REPAIR	PROPOSED INSTALLATION	NUMBER	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS	3	
		GARBAGE GRINDERS		
		SEPTIC TANKS		
	1	HOUSE SEWERS (repair)	1	\$ 2.00
		ROOF LEADERS (conn. to house drain)		
			1	\$ 2.00
			Total	

Date: Mar 3-61

APPROVED FINAL INSPECTION

Date: Mar 3-61

By JOSEPH P. WELCH

- TYPE OF BUILDING
- COMMERCIAL
 - RESIDENTIAL
 - SINGLE
 - MULTI FAMILY
 - NEW CONSTRUCTION
 - REMODELING

SM 12-53

PORTLAND HEALTH DEPT.

PLUMBING INSPECTION

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. **2332**
 Issued **11/12/74**
 Portland, Maine Nov. 6, 1974, 19 ..

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address Mrs. Helen Stewart Tel. _____
 Contractor's Name and Address Ballard Oil & Equipment Co. Tel. 772-1991
 Location 11 Cushman St. Use of Building Residence
 Number of Families 1 Apartments Stores Number of Stories 2
 Description of Wiring: New Work Additions Alterations X
 Wiring of high pressure gun type burner and controls.
 Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
 No. Light Outlets Plugs Light Circuits Plug Circuits
 FIXTURES: No. Fluor. or Strip Lighting (No. feet)
 SERVICE: Pipe Cable Underground No. of Wires Size
 METERS: Relocated Added Total No. Meters
 MOTORS: Number 1 Phase 1 H. P. 1/8 Amps 3.0 Volts 115 Starter
 HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
 Commercial (Oil) No. Motors Phase H.P.
 Electric Heat (No. of Rooms)
 APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
 Elec. Heaters Watts
 Miscellaneous Watts Extra Cabinets or Panels
 Transformers Air Conditioners (No. Units) Signs (No. Units)
 Will commence 19 Ready to cover in ~~Will Call~~ Inspection **2 Dec 19 74**
 Amount of Fee \$ 2.00
 Signed *J. F. Libby*

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1/2-6 7 1/2 12-12-74 1-17-75	4	5 6
7	8 9 10	11 12
REMARKS: <i>no one home</i>		
	INSPECTED BY <i>Libby</i>	(OVER)

2510



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT 1102

Portland, Maine, Nov. 6, 1974

PERMIT ISSUED

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 11 Cushman St. Use of Building Residence No. Stories 2 New Building Existing " Mrs. Helen Stewart Telephone 772-1991

General Description of Work

To install a Crane Model 70-SS-122 PT steam boiler for first floor

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? none Kind of fuel? # 2 Minimum distance to burnable material, from top of appliance or casing top of furnace 3' From top of smoke pipe 2' From front of appliance 3' From sides or back of appliance 4' Size of chimney flue 8 x 12 Other connections to same flue none If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Crane Labeled by underwriters' laboratories? Yes Will operator be always in attendance? No Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/4" Location of oil storage basement Number and capacity of tanks 1-275 Low water shut off yes Make C. Donnell No. 467 Will all tanks be more than five feet from any flame? yes How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners 1-275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smoke pipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 5.00

APPROVED:

OK 11-12-74-NFC

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

CS 300

Signature of Installer

[Handwritten Signature]

INSPECTION COPY

NOTES

- 1. 1/2" FILL PIPE
- 2. 1/4" VENT PIPE
- 3. Kind of Heat
- 4. Burner Rating & Support
- 5. Name & Label
- 6. Pressure Control
- 7. High Limit Control
- 8. Manual Off Switch
- 9. Low Water Cutoff
- 10. High Limit Control
- 11. Flue support & protection
- 12. Valves in Supply line
- 13. Capacity of tanks
- 14. Tank Rating & Support
- 15. Oil gauge
- 16. Instruction Card
- 17. Oil leaks
- 18. Adequate ventilation
- 19. Smokeproof to combustible
- 20. Thermal Control switch


12-6-74

2.6 in. hose

12-12-74

1-17-75

JK



Permit No. 74/1102
 Location 11 Bushman St.
 Owner Stewart
 Date of permit 11/27/74
 Approved

Wilson

CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. _____
 Issued _____, 19____
 Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address *Bealwin* Tel. _____
 Contractor's Name and Address *Darby Elect. Co.* Tel. _____
 Location *7 Chushman* Use of Building *Home*
 Number of Families *1* Apartments _____ Stores _____ Number of Stories _____
 Description of Wiring: *New Work* Additions _____ Alterations _____
 Pipe *Cable* Metal Molding _____ BX Cable _____ Plug Molding (No. of feet) _____
 No. Light Outlets _____ Plugs _____ Light Circuits _____ Plug Circuits _____
 FIXTURES: No. _____ Fluor. or Strip Lighting (No. feet) _____
 SERVICE: Pipe _____ Cable _____ Underground _____ No. of Wires _____ Size _____
 METERS: Relocated _____ Added _____ Total No. Meters _____
 MOTORS: Number _____ Phase _____ H. P. _____ Amps _____ Volts _____ Starter _____
 HEATING UNITS: Domestic (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Commercial (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Electric Heat (No. of Rooms) _____
 APPLIANCES: No. Ranges _____ Watts _____ Brand Feeds (Size and No.) _____
 Elec. Heaters _____ Watts _____
 Miscellaneous _____ Watts _____
 Transformers _____ Air Conditioners (No. Units) _____ Extra Cabinets or Panels _____
 Will commence _____ 19____ Ready to cover in _____ 19____ Signs (No. Units) _____
 Amount of Fee \$.. _____ Inspection _____ 19____

Signed *Carl J. Hays* *will call*

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND	5	6
VISITS: 1	2	3	4	11	12
..... 7	8	9	10		

REMARKS:

INSPECTED BY

F. H. Hays
(OVER)

LOCATION *Cushman ST 7*
 INSPECTION DATE *6/29/73*
 WORK COMPLETED *6/29/73*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	
1 to 30 Outlets	\$ 2.00
31 to 60 Outlets	3.00
Over 60 Outlets, each Outlet	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	3.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)	.75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit	1.50

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. 55852

Issued 4/2/57, 1957
 Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out -- Minimum Fee, \$1.00)

Owner's Name and Address Stewart Tel.

Contractor's Name and Address 11 Chestnut ST Tel.

Location 11 Chestnut ST Use of Building

Number of Families Apartments Stories Number of Stories

Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)

No. Light Outlets Plugs Light Circuits Plug Circuits

FIXTURES: No. Light Switches Fluor. or Strip Lighting (No. feet)

SERVICE: Pipe Cable X Underground No. of Wires 3 Size 2/3/4

METERS: Relocated Added Total No. Meters

MOTORS: Number Phase H. P. Amps Volts Starter

HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.

Commercial (Oil) No. Motors Phase H.P.

Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.) ...

Elec. Heaters Watts

Miscellaneous Watts Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Sigs (No. Units)

Will commence ... 19... Ready to cover in ... 19... Inspection ... 19...

Amount of Fee \$... ..

Signed [Signature]

DO NOT WRITE BELOW THIS LINE

SERVICE METER GROUND

VISITS: 1 2 3 4 5 6

7 8 9 10 11 12

REMARKS:

INSPECTED BY F. W. Hunter
 (OVER)

LOCATION *Cushman St. 11*
 INSPECTION DATE *6/12/67*
 WORK COMPLETED *6/12/67*
 TOTAL NO. INSPECTIONS *1*
 REMARKS:

FEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING		
1 to 30 Outlets	(including switches)	\$ 2.00
31 to 60 Outlets	(including switches)	3.00
Over 60 Outlets, each Outlet	(including switches)	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).		
SERVICES		
Single Phase		2.00
Three Phase		4.00
MOTORS		
Not exceeding 50 H.P.		3.00
Over 50 H.P.		4.00
HEATING UNITS		
Domestic (Oil)		2.00
Commercial (Oil)		4.00
Electric Heat (Each Room)		.75
APPLIANCES		
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers, etc. — Each Unit		1.50
TEMPORARY WORK (limited to 6 months from date of permit)		
Service, Single Phase		1.00
Service, Three Phase		2.00
Wiring, 150 Outlets		1.00
Wiring, each additional outlet over 50		.02
		10.00

CITY OF PORTLAND, MAINE

Application for Permit to Install Wires

Permit No. _____
 Issued
 Portland, Maine **FEB. 17**, 19**47**

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address: **CLINTON DAVIS** Tel. _____
 Contractor's Name and Address: **R. BARTO** Tel. _____
 Location: **9 CUSHMAN ST.** Use of Building: **RESIDENCE**
 Number of Families: **2** Apartments: _____ Stores: _____ Number of Stories: **2**
 Description of Wiring: **New Work** Additions: _____ Alterations: **✓**

Pipe _____ Cable _____ Metal Molding _____ BX Cable _____ Plug Molding (No. of feet) _____
 No. Light Outlets: **6** Plugs: **4** Light Circuits: **2** Plug Circuits: **1**
 FIXTURES: No. Light Switches: **2** Fluor. or Strip Lighting (No. feet) _____
 SERVICE: Pipe Cable: **✓** Underground: _____ No. of Wires: **3** Size: **#2 ALUM.**
 METERS: Relocated _____ Added _____ Total No. Meters: **2**
 MOTORS: Number _____ Phase: _____ H. P. _____ Amps _____ Volts _____ Starter _____
 HEATING UNITS: Domestic (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Commercial (Oil) _____ No. Motors _____ Phase _____ H.P. _____
 Electric Heat (No. of Rooms) _____
 APPLIANCES: No. Ranges _____ Watts _____ Brand Feeds (Size and No.) _____
 Elec. Heaters _____ Watts _____
 Miscellaneous _____ Watts _____ Extra Cabinets or Panels _____
 Transformers _____ Air Conditioners (No. Units) _____ Signs (No. Units) _____
 Will commence _____ 19 _____ Ready to cover in **2/17** 19**47** Inspection _____ 19 _____
 Amount of Fee \$ **4.00** ✓
 Signed *[Signature]*

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
1	3	5
2	4	6
3	5	7
4	6	8
5	7	9
6	8	10
7	9	11
8	10	12
9	11	
10	12	

REMARKS:

INSPECTED BY *[Signature]* (OVER)

Blue Tag
2/16/47

LOCATION *Cushman ST 9*
 INSPECTION DATE *2/27/67*
 WORK COMPLETED *2/27/67*
 TOTAL NO. INSPECTIONS *1*
 REMARKS:

FEEES FOR WIRING PERMITS EFFECTIVE JULY 31, 1968

WIRING		
1 to 30 Outlets	(including switches)	\$ 2.00
31 to 60 Outlets	(including switches)	3.00
Over 60 Outlets, each Outlet	(including switches)	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).		
SERVICES		
Single Phase		2.00
Three Phase		4.00
MOTORS		
Not exceeding 50 H.P.		3.00
Over 50 H.P.		4.00
HEATING UNITS		
Domestic (Oil)		2.00
Commercial (Oil)		4.00
Electric Heat (Each Room)		.75
APPLIANCES		
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers, etc. — Each Unit		1.50
TEMPORARY WORK (Limited to 6 months from date of permit)		
Service, Single Phase		1.00
Service, Three Phase		2.00
Wiring, 1-50 Outlets		1.00
Wiring, each additional outlet over 50		.02
Circuses, Carnivals, Fairs, etc.		10.00
MISCELLANEOUS		
Distribution Cabinet or Panel, per unit		1.00
Transformers, per unit		2.00
Air Conditioners, per unit		2.00
Signs, per unit		2.00
ADDITIONS		
5 Outlets, or less		1.00

PERMIT TO INSTALL PLUMBING

Address 9 Cushman Street

PERMIT NUMBER 17019

Installation For:

Owner of Bldg: Clinton Davis

Owner's Address: 9 Cushman Street

Date: 2/7/67

Plumber: John A. Jensen

Date Issued 2/7/67
 Portland Plumbing Inspector
 By ERNOLO R. GOODWIN

App. First Insp.
 Date 2/15/67
 By [Signature]

App. Final Insp.
 Date _____
 By ERNOLO R. GOODWIN
 Type of Bldg.
 Commercial
 Residential
 Single
 Multi Family
 New Construction
 Remodeling

NEW	REPL		INO.	FEE
		SINKS		
		LAVATORIES	1	2.00
		TOILETS	1	2.00
		BATH TUBS	1	2.00
		SHOWERS		
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		
		TANKLESS WATER HEATERS		
		GARBAGE DISPOSALS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS		
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER		
			TOTAL	3

Building and Inspection Services Dept: Plumbing Inspection

R6 RESIDENCE ZONE



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class
Portland, Maine, August 3, 1965

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 9 Cushman St. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Clinton N. Davis, 9 Cushman St. Telephone 773-6105
Lessee's name and address _____ Telephone _____
Contractor's name and address _____ owner Telephone _____
Architect _____ Specifications _____ Plans _____ No. of sheets _____
Proposed use of building Dwelling No. families 2
Last use _____ No. families 2
Material frame No. stories 2 1/2 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____ Fee \$ 2.00
Estimated cost \$ 100.00

General Description of New Work

To change out wooden steps only on front and rear of building to brick steps. (no platform).

No permit needed

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation concrete at least 12" below grade Thickness, top _____ bottom _____ cellar _____
Kind of roof 4" wide x 12" deep Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Flooring Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
Columns under girders _____ Size _____ Max. on centers _____
Wide walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Rafters: 1st floor brick, 2nd _____, 3rd _____, roof _____
Joists: 1st floor _____, 2nd _____, 3rd _____, roof _____
Max. span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairs be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? _____
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? _____

APPROVED:

CS 301

INSPECTION COPY

Signature of owner

Clinton N. Davis

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

April 24, 1963

Mr. Clinton E. Davis
9 Cushman Street

Dear Sir:

With relation to permit applied for to demolish a ~~building~~ portion of building at 9 Cushman Street it is unlawful to commence demolition work until a permit has been issued from this department.

Section 6 of the ordinance for rodent and vermin control provides: "It shall be unlawful to demolish any building or structure unless provision is made for rodent and vermin eradication. No permit for the demolition of a building or structure shall be issued by the Building Inspector until and unless provisions for rodent and vermin eradication have been carried out under supervision of a pest control operator registered with the Health Department.

The building permit for demolition cannot be issued until the provisions of this section have been satisfied. It is the obligation of owner or demolition contractor or both to take up with the Health Department the matter of complying with this section, being prepared to inform that department what registered pest control operator is to be employed.

Very truly yours,

Albert J. Sears

Albert J. Sears
Director of Building Inspection

AJS/h

Eradication of this building has been completed.

J. L. King
4-24-63

R6 RESIDENCE ZONE

APPLICATION FOR PERMIT



Class of Building or Type of Structure Third Class
Portland, Maine, April 24, 1963

RECEIVED
OFFICE

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 9 Chestnut Street Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Winton Lewis, 4 Franklin St. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address _____ Telephone _____
 Architect _____ Specifications _____ Plans _____ No. of sheets _____
 Proposed use of building Dwelling No. families _____
 Last use _____ " _____ No. families 2
 Material frame _____ Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____ Fee \$ 4.00
 Estimated cost \$ 15

General Description of New Work

To demolish existing 1-st ory frame shed on side of dwelling and finish off wall of dwelling with asphalt shingles

Crackdown Notice sent 4/24/63

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Kind of roof _____ Rise per foot _____ Roof covering _____ Kind of heat _____ fuel _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Sills _____
 Framing Lumber - Kind _____ Dressed or full size? _____ Corner posts _____
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? _____ no _____
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

O.R. 4/25/63 - ags

CS 301

INSPECTION COPY

Signature of owner

Winton M. Lewis



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, AUGUST 7, 1961

PERMIT ISSUED

00969

AUG 7 1961

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 9 Cushman St. Use of Building dwelling No. Stories 1 New Building
Existing
 Name and address of owner of appliance Clinton M. Davis, 9 Cushman St.
 Installer's name and address Ballard Oil & Equip. Co., 135 Marginal Way Telephone _____

General Description of Work

To install oil burning equipment in existing gravity hot water system (conversion)

IF HEATER, OR POWER BOILER

Location of appliance _____ Any burnable material in floor surface or beneath? _____
 If so, how protected? _____ Kind of fuel? _____
 Minimum distance to burnable material, from top of appliance or casing top of furnace _____
 From top of smoke pipe _____ From front of appliance _____ From sides or back of appliance _____
 Size of chimney flue _____ Other connections to same flue _____
 If gas fired, how vented? _____ Rated maximum demand per hour _____
 Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? _____

IF OIL BURNER

Name and type of burner Esso gun type Labeled by underwriters' laboratories? yes
 Will operator be always in attendance? _____ Does oil supply line feed from top or bottom of tank? bottom
 Type of floor beneath burner concrete Size of vent pipe 1 1/4"
 Location of oil storage basement Number and capacity of tanks 1 - 275 gal.
 Low water shut off _____ Make _____ No. _____
 Will all tanks be more than five feet from any flame? _____ How many tanks enclosed? _____
 Total capacity of any existing storage tanks for furnace burners _____

IF COOKING APPLIANCE

Location of appliance _____ Any burnable material in floor surface or beneath? _____
 If so, how protected? _____ Height of Legs, if any _____
 Skirting at bottom of appliance? _____ Distance to combustible material from top of appliance? _____
 From front of appliance _____ From sides and back _____ From top of smokepipe _____
 Size of chimney flue _____ Other connections to same flue _____
 Is hood to be provided? _____ If so, how vented? _____ Forced or gravity? _____
 If gas fired, how vented? _____ Rated maximum demand per hour _____

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Ballard Oil & Equip. Co.

Signature of Installer

CS 300

INSPECTION COPY



APPLICATION FOR PERMIT

RE RESIDENCE
Class of Building or Type of Structure Third Class
Portland, Maine, May 23, 1960

PERMIT ISSUED
MAY 25 1960 *09583*
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 9 Cushman Street Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Clinton M. Davis, 9 Cushman St. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address owner Telephone _____
 Architect _____ Specifications _____ Plans no No. of sheets _____
 Proposed use of building Dwelling No. families 2
 Last use _____ " _____ No. families 2
 Material frame No. stories 2 1/2 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____ Fee \$.50
 Estimated cost \$ _____

General Description of New Work

To demolish existing 1-story frame shed attached to rear of building.
To shingle end wall of dwelling

Evacuation letter sent 5-23-60
It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing Lumber-Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Kind and thickness of outside sheathing of exterior walls? _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:
O.K. - 5/25/60 - ajs

Signature of owner Clinton M. Davis *PK*

INSPECTION COPY

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

May 25, 1960

Mr. Clinton A. Davis
9 Cushman St.
Portland Maine

Dear Sir:

With relation to permit applied for to demolish a ~~building~~ or portion of building at 9 Cushman St. it is unlawful to commence demolition work until a permit has been issued from this department.

Section 6 of the ordinance for rodent and vermin control provides: "It shall be unlawful to demolish any building or structure unless provision is made for rodent and vermin eradication. No permit for the demolition of a building or structure shall be issued by the Building Inspector until and unless provisions for rodent and vermin eradication have been carried out under supervision of a pest control operator registered with the Health Department.

The building permit for demolition cannot be issued until the provisions of this section have been satisfied. It is the obligation of owner or demolition contractor or both to take up with the Health Department the matter of complying with this section, being prepared to inform that department what registered pest control operator is to be employed.

Very truly yours,

Albert J. Sears

Albert J. Sears
Inspector of Buildings

AJS/jg

Eradication of portion of this building has been completed.

C. K. N. H.



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, May 27, 1960

PERMIT ISSUED 00616 MAY 27 1960 CITY OF PORTLAND

To the INSPECTOR OF BUILDING PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 9 Cushman St. Use of Building Dwelling No. Stories 2 New Building Existing
Name and address of owner of appliance Clinton Davis, 9 Cushman St.
Installer's name and address Ballard Oil & Equipment Co., 135 Marginalway Telephone 2-1991

General Description of Work

To install Oil burning equipment in connection with existing steam heat.

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner E D High Pressure gun type Labeled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 gal
Low water shut off yes Make McDonnell Miller No. 67
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] 5-27-60 [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes Ballard Oil & Equipment Co.

by: [Signature]

CS 300

Signature of Installer

INSPECTION COPY

FM

CITY OF PORTLAND
HEALTH DEPARTMENT
HOUSING DIVISION



Loc. 9 CUSHMAN STREET
Loc w/i S R
Bldg 21 Fire Elec & Other
Issued April 25, 1960
Expires May 25, 1960

Mr. Clinton H. Davis
9 Cushman Street
Portland, Maine

Dear Sir:

On April 22, 1960 an examination was made of the premises located at 9 Cushman Street, Portland, Maine (1st floor apt.)

Non-compliance with the ordinances relating to housing conditions was found as detailed below.

In accordance with the provisions of the above ordinance, you are hereby ordered to correct these defects according to specifications within the time limits allowed. Failure to comply with this notice will necessitate legal action.

Some repairs or improvements required will necessitate permits which are to be obtained from the Building Inspector, Health, Fire or other City Departments. These must be obtained before the work is started.

If any additional information is desired, visit or telephone the Housing Supervisor at this Office, Spruce 4-8221, extension 226. Kindly notify this office as soon as all corrections have been completed.

Very truly yours,
Douglas H. Brown, M.D.
Health Director

By _____
Housing Supervisor

VIOLATIONS & SPECIFICATIONS

Responsibility of Owner or Agent ** Responsibility of Occupant

STRUCTURAL

Repair and put in good order all dilapidated and hazardous parts of the structure as follows:

- a. Determine the reason and remedy the condition which now causes the shed to pull away from the structure.
- b. Repair or replace the deteriorated front sill on the left side of the structure.
- c. Repair or replace the deteriorated gutter on the rear of the structure.
- d. Repair or replace the missing face board on the right side of the structure.
- e. Repair the hole in the floor under the set tub in the pantry of the 1st floor apt.
- f. Determine the reason and remedy the condition which now causes the signs of leakage on the ceiling of the bathroom in the 1st floor apt.
- g. Determine the reason and remedy the condition which now causes the door to close improperly in the front room of the 1st floor apt.
- h. Repair or replace the cracked, loose, or missing plaster on the walls of the front room, of the 1st floor apt.
- i. Repair or replace the cracked, loose, or missing plaster on the ceilings of the bathroom, and kitchen of the 1st floor apt.
- j. Patch the loose window panes, tighten the loose window sashes throughout the structure. Particular attention is directed to the front room, den, and bedroom of the 1st floor apt.
- k. Replace the missing or broken sash cords in the front room, bathroom, bedroom, and kitchen of the 1st floor apt.
- l. Replace the broken and cracked window panes in the middle room, of the 1st floor apt., and in the cellar of the structure.

ELECTRICAL EQUIPMENT

Check and have repaired all defective electric wiring and electrical equipment throughout the structure.

- a. Repair or replace the defective overhead fixtures in the front room, and den, of the 1st floor apt.
- b. Determine the reason and remedy the condition which now causes the light fixture in the cellar of the structure to work improperly.
- c. Replace the missing pull chains in the front room of the structure.

(over)

PLUMBING:

Check and have repaired all defective plumbing and plumbing fixtures throughout the structure.

- a. Replace the missing safety valve on the hot water tank in the kitchen of the 1st floor apt.

HEATING:

- a. Replace the missing flue cover in the kitchen of the 1st floor apt.
- b. Repair or replace the loose door on the furnace.

The above mentioned conditions are in violation of the City Ordinance, MINIMUM STANDARDS FOR CONSERVED OCCUPANCY, and APPLICABILITY TO VACANT BUILDINGS, and must be corrected on or before May 25, 1960.



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 2, 1955

PERMIT ISSUED 02034 NOV 2 1955 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 11 Cushman St. (2nd floor) of Building dwelling No. Stories 2 New Building Existing " Name and address of owner of appliance Mrs. Siori M. Stein, 11 Cushman St. Installer's name and address Ballard Oil, 135 Marginal Way Telephone 2-1991

General Description of Work

To install oil burning equipment in connection with existing steam boiler

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Kind of fuel? Minimum distance to burnable material, from top of appliance or casing top of furnace From top of smoke pipe From front of appliance From sides or back of appliance Size of chimney flue Other connections to same flue If gas fired, how vented? Rated maximum demand per hour Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Ballard Labelled by underwriters' laboratories? yes Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/2" Location of oil storage basement Number and capacity of tanks 1-220 gal. Low water shut off yes Make M&M No. 67 Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smokepipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] 11.2.55

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Ballard Oil & Equipment

Signature of Installer By: [Signature]

INSPECTION COPY

C17-251-1M-MARKS

NOTES

- 1 Fill Pipe
- 2 Vent Pipe
- 3 Kind of Heat
- 4 Burner Rignity & Supports
- 5 Name & Label
- 6 Stack Control
- 7 High Limit Control
- 8 Remote Control
- 9 Piping Support & Protection
- 10 Valve to Supply
- 11
- 12 Tank
- 13 Tank 14
- 14 Oil Gauge
- 15 Instructions
- 16 Low Water Switch

Permit No. 55/2034
Location 11 Cambridge St
Owner Mrs. Sicily M. Stearns
Date of permit 11/2/53
Approved _____

11/2/53
A. W.

--	--

WARREN McDONALD
INSPECTOR OF BUILDINGS

On reply refer
to file

FU

CITY OF PORTLAND, MAINE

Department of Building Inspection

Location - 9 Cushman Street

Owner - Mrs. Alice Hutchinson

Date of HD Order - July 18, 1955

Mrs. Alice Hutchinson
Peaks Island
Portland, Maine

Dear Mr. Hutchinson:

Included in order of Housing Division of Health Department concerning the above premises, are features of structural repair or improvement of outside porches, steps or outside walls or of supports of building in the cellar.

If these improvements involve important features of foundations or framing (not including such minor matters as railing and floor board repairs), a building permit from this department is required before the work is started. Application for such a permit is made at this office over the counter on forms furnished by us.

The application must be made by someone who knows about the details of construction in a general way, who can give the total estimated cost of that part of the work included in the building permit, and pay the modest fee.

With the application must be filed a plan by way of a blue print with all of the information on it printed from the original, this plan to be made by some person accustomed to the usual way of making such plans and capable of figuring out for himself the materials, size, spacing, etc. required by the Building Code.

Much as we desire to be of the greatest possible assistance to you in bringing your building up to good and safe standards, the pressure of work in this office prevents us consulting with you about the details or advising you as to how to go about making the plan. Frequently issuance of such permits is delayed because the applicant does not furnish information as above.

Very truly yours,

WMcD/H

Inspector of Buildings

CITY OF PORTLAND
HEALTH DEPARTMENT
HOUSING DIVISION



Loc. 11 Cashden Street
Loc w/i S
Bldg Fire Elec Other
Issued July 14, 1955
Expires August 14, 1955

Mrs. Miri Hale
11 Cashden Street
Portland, Maine

Dear Sir:
On July 27, 1955 an examination was made of the premises located at 11 Cashden Street, Portland, Maine.
Non-compliance with the ordinances relating to housing conditions was found as detailed below.
In accordance with the provisions of the above ordinance, you are hereby ordered to correct these defects according to specifications within the time limits allowed. Failure to comply with this notice will necessitate legal action.
Some repairs or improvements required will necessitate permits which are to be obtained from the Building Inspector, Health, Fire or other City Departments. These must be obtained before the work is started. If any additional information is desired, visit or telephone the Housing Supervisor at this Office, telephone 4-1431, extension 226. kindly notify this office as soon as all corrections have been completed.

Very truly yours,
Edward W. Colby, M.D.
Health Director

By _____
Housing Supervisor

VIOLATIONS & SPECIFICATIONS

Responsibility of Owner or Agent ** Responsibility of Occupant

- Electrical Work
Check and have repaired all defective electric wiring and electrical equipment throughout the structure.
- a) Disconnect and do not connect again the ungrounded wire, pulled into the fixture in the front bedroom on the third floor.
 - b) Install a ground wire in the down box in the hallway.
- Structural Repairs
Repair and put in good order all defective and hazardous parts of the structure as follows:
- a) Putty the loose window panes in the storm windows on the third floor.
 - b) Repair or replace the loose or missing plaster on top ceiling in the second floor front hallway.
 - c) Repair or replace the loose, torn or broken boards on the front outside stairway.
 - d) Repair or replace the loose and rotten parts of overhanging on the outside first and second floor rear porches.

The above mentioned conditions are in violation of the City Ordinance Minimum Standards for "Ordinary Tenement" and must be corrected on or before August 15, 1955.

To: Housing Division, Health Department
From _____ Date _____
This is to inform you that deficiencies of which this Department has been notified, have been corrected to our satisfaction.

Loc. _____
Loc w/i S _____
Bldg _____ Fire _____ Elec _____ Other _____
Issued _____
Expires _____

Remarks: _____

Signature _____

(Please return to Housing Division of Health Department when corrections have been COMPLETED)



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,

PERMIT ISSUED 01858 JUL 31 1947

454

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 11 Cushman St Use of Building dwelling No. Stories 2 New Building Existing "
Name and address of owner of appliance Mrs. Liri Steen Same
Installer's name and address Ballard & Egan 135 Marginal Way Phone 2-1991

General Description of Work

To install One fully automatic oil burner for existing steam heat

IF HEATER, OR POWER BOILER

Location of appliance or source of heat Type of floor beneath appliance
If wood, how protected? Kind of fuel
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace
From top of smoke pipe. From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner 1 - Steel Head B D burner tested by underwriter's laboratories?
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner Cement
Location of oil storage basement Number and capacity of tanks 1 - 275
If two 275-gallon tanks, will three-way valve be provided?
Will all tanks be more than five feet from any flame? Yes How many tanks fire proofed? none
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Kind of fuel Type of floor beneath appliance
If wood, how protected?
Minimum distance to wood or combustible material from top of appliance
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time)

APPROVED:

OK 7.30.47 [Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of Installer

[Signature of Ballard & Egan]

Permit No. 47/1858
 Location 11 Cushman St
 Owner Mrs. Lina Stein
 Date of permit 7/31 1947
 Approved 10-20-47 Pmk

70 sq. ft. volume
in hot tank
Traced to main about
the end of the 10th
hazardous liquid
in pipe about to
be filled, she is to
be removed
of volume is not
at present.

NOTES

- 1 Fill Pipe
- 2 Vent Pipe
- 3 Kind of fluid Steam
- 4 Name, Height & Support
- 5 Name & Label
- 6 Stack Control
- 7 High Limit Control
- 8 Remote Control
- 9 Piping Support & Protection
- 10 Valves in Supply Line
- 11 Capacity of Tanks
- 12 Tank Height & Support
- 13 Tank Diameter
- 14 Oil Gauge
- 15 Instruction Card
- 16

9.347, considerable
work has been
filled up annual
work, variable

Pmk



Location, Ownership and detail must be correct, complete and legible.
 with the law. Separate application required for every building.
 Plans must be filed with this application.

Application for Permit for Alterations, etc.

BEFORE COMMENCING WORK
 Failure to do so

Portland, Me., ^{Jan 2 1926} December 21/19

To the
 INSPECTOR OF BUILDINGS:

The undersigned applies for a permit to alter the following described building:—

Description of Present Bldg.

Location 9 Cushman Street Ward in fire-limits? 7
 Name of Owner or Lessee, M C Hutchinson Address 30 Cushman St
 A D Small " 24 Drake St
 " " Contractor,
 " " Architect,
 Material of Building is wood Style of Roof, pitch Material of Roofing, asphalt
 Size of Building is feet long; feet wide. No. of Stories,
 Cellar Wall is constructed of is inches wide on bottom and batters to inches on top.
 Underpinning is is inches thick; is feet in height.
 Height of Building Wall, if Brick; 1st, 2d, 3d, 4th, 5th,
 What was Building last used for? dwelling No. of Families? 2
 What will Building now be used for? dwelling 2 families

PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

Detail of Proposed Work

Build addition one story high 10x14 feet to be set on posts
 all to compl. with the building ordinance
 addition to be used for bedroom

 Estimated Cost 300.

If Extended On Any Side

Size of Extension, No. of feet long?; No. of feet wide?; No. of feet high above sidewalk?
 No. of Stories high?; Style of Roof?; Material of Roofing?
 Of what material will the Extension be built? Foundation?
 If of Brick, what will be the thickness of External Walls? inches; and Party Walls inches.
 How will the extension be occupied? How connected with Main Building?

When Moved, Raised or Built Upon

No. of Stories in height when Moved, Raised, or Built upon? Proposed Foundations?
 No. of feet high from level of ground to highest part of Roof to be?
 How many feet will the External Walls be increased in height? Party Walls

If Any Portion of the External or Party Walls Are Removed

Will an opening be made in the Party or External Walls? in Story.
 Size of the opening? How protected?
 How will the remaining portion of the wall be supported?

Signature of Owner or
 Authorized Representative

Alden D Small

Address

24 Drake St



Location, ownership and detail must be correct, complete and legible. Separate application required for every building. Plans must be filed with this application.

APPLICATION FOR PERMIT TO BUILD (3D CLASS BUILDING)

Portland Me., May 10, 1919 /19

To THE INSPECTOR OF BUILDINGS:

The undersigned hereby applies for a permit to build, according to the following Specifications:—

Plans must be submitted in duplicate, one set to be filed with the Department and the duplicate set thereof (bearing the approval of the Inspector of Buildings) shall be kept on the work and exhibited on demand.

PERMIT MUST BE RECEIVED BEFORE BEGINNING WORK.

Location 11 Cushman ST Wd. 7
 Name of owner is? V. F. Reynolds Address 11 Cushman ST
 Name of mechanic is? Owner
 Name of architect is?
 Proposed occupancy of building (purpose)? private garage
 If a dwelling or tenement house, for how many families?
 Are there to be stores in lower story? No.
 Size of lot, No. of feet front? 50ft; No. of feet rear? ; No. of feet deep? 100ft
 Size of building, No. of feet front? 15ft; No. of feet rear? ; No. of feet deep? 16ft
 No. of stories, front? 1; rear?
 No. of feet in height from the mean grade of street to the highest part of the roof? 9ft
 Distance from lot lines, front? feet, side? feet; side? feet; rear? feet
 Firestop to be used? Sides and roof to be covered with slate surface asphalt
 Will the building be erected on solid or filled land?
 Will the foundation be laid on earth, rock, or piles?
 If on piles, No. of rows? distance on centres? length of?
 Diameter, top of? diameter, bottom of?
 Size of posts?
 " girts?
 " floor timbers? 1st floor earth, 2d, 3d, 4th
 O. C. " " " " " " " "
 Span " " " " " " " "
 Braces, how put in?
 Building, how framed?
 Material of foundation? posts thickness of? laid with mortar?
 Underpinning, material of? height of? thickness of?
 Will the roof be flat, pitch, mansard, or hip? shed Material of roofing? asphalt
 Will the building be heated by steam, furnaces, stoves or grates? Will the flues be lined?
 Will the building conform to the requirements of the law? yes
 No. of brick walls? and where placed?
 Means of egress?

If the building is to be occupied as a Tenement House, give the following particulars:

What is the height of cellar or basement?
 What will be the clear height of first story? second? third?
 State what means of egress is to be provided? Scuttle and stepladder to roof?

Estimated Cost,
\$ 100.00

Signature of owner or authorized representative,

V. F. Reynolds
Address,

Plans submitted? Received by?