

136 Clark Street

NDP REHAB I

CERTIFICATE
OF
COMPLIANCE

March 1, 1971

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 Ext. 226

Ms. Sadie McAfee
136 Clark Street
Portland, Maine 04102

Re: Premises located at 136 Clark Street, Portland, Maine

Dear Ms. McAfee:

A re-inspection of the premises noted above was made on February 26, 1971
by Housing Inspector Gough, of the Health Department.

This is to certify that you have complied with our request to correct the
violations of the Municipal Code relating to housing conditions described
in our "Notice of Housing Conditions" dated September 30, 1970.

Thank you for your cooperation and your efforts to help us maintain decent,
safe and sanitary housing for all Portland residents.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

Inspector [Signature]


By [Signature]
Chief of Housing Inspections

NOTICE OF HOUSING CONDITIONS

DU _____

CITY OF PORTLAND
Health Department - Housing Division
Tel. 774-8221 - Ext. 226

Location: **136 Clark Street**
Project: **NDP #1**
Issued: **9/30/70**
Expires: **12/30/70**



Ms. Sadie McAfee
136 Clark Street
Portland, Maine 04102

Dear Ms. McAfee:

An examination was made of the premises at 136 Clark Street Portland, Maine, by Housing Inspector Spitzer. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with the provisions of the above mentioned codes, you are requested to correct these defects on or before December 30, 1970. You may contact this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,

Arthur A. Hughson, CPH MPH
Health Director

Inspector _____

By: [Signature]
Chief of Housing Inspections

- EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" -
- | | | |
|-----------------|---|-----------------|
| 2/26 | 1. Point up the foundation at the right and left front corners. | 3(a) |
| 2/26 | 2. We suggest that you replace the missing section of the gutter at the left rear side of the structure. | 3(a) |

CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207)874-8300



DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

November 15, 1990

Lucy Harrington
136 Clark Street
Portland, ME 04102

Re: 136 Clark Street

Dear Ms. Harrington:


We recently received a complaint and an inspection was made by Code Enforcement officer Marland Wing of the property owned by you at 136 Clark Street, Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:


1. Remove hay from around oil tank in basement. 114-2

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected on or before November 30, 1990.

Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely, yours,
Joseph E. Gray, Jr., Director of
Planning & Urban Development


P. Samuel Hoffses
Chief of Inspection Services


Marland Wing
Code Enforcement Officer (5)

cc: Verda Geisinger
P.O. Box 4625
Portland, ME 04112

56-6-31

~~Mark C. CARTWRIGHT~~
~~100 Clark St.~~ Letter of Defects

Lucy Harrington

~~100~~ Clark St.

136

Pfd., Me.

LOC: 136 Clark St.

to remove bay from around
oil tank in basement. 114-2

15 days

W. W. King

~~100~~

also send copy to

Verda Geisinger

P.O. Box 4625

Pfd., Me. 04112