

188-142 CLARK STREET



Full cut # 920R - Hat cut # 6202H - Thin J cut # 8203R - First cut # 0205R

CITY OF PORTLAND, MAINE
Application for Permit to Install Wires

Permit No. **5197**
 Issued **9/15/74**

Portland, Maine

To the City Electrician, Portland, Maine

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address **John KLEWIAK - Portland Tel.**

Contractor's Name and Address **ALAN RICE. Assoc. - Portland Tel.**

Location **140 CLARK ST.**

Use of Building

Number of Families **2** Apartments Stores Number of Stories
 Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
 No. Light Outlets Plugs Light Circuits Plug Circuits

FIXTURES: No. Fluor. or Strip Lighting (No. feet)

SERVICE: Pipe Cable Underground No. of Wires Size

METERS: Relocated Added Total No. Meters

MOTORS: Number Phase H. P. Amps Volts Starter

HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.

Commercial (Oil) No. Motors Phase H.P.

Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges **1** Watts **8kw** Brand Feeds (Size and No.) **6-3 #11**

Elec. Heaters Watts

Miscellaneous Watts

Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Signs (No. Units)

Will commence **19** Ready to cover **19** Inspection **19**

Amount of Fee \$

Signed by **J. Malgerae 8825**
Ralph R. Johnston 1205

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND		
VISITS: 1 9-16-74	3	4	5	6
	9	10	11	12

REMARKS:

SR

INSPECTED BY

Libby

(OVER)

PERMIT TO INSTALL PLUMBING

PERMIT NUMBER **0212**

Date Issued **4-4-73**
 Portland Plumbing Inspector
 By **ERNOLD R GOODWIN**

Address **140 Clark St.**
 Installation For:
 Owner of Bldg **Mrs. Frances Delano**
 Owner's Address **R.F.D. #3 Gorham, Maine**
 Plumber **Northern Utilities** Date **4-4-73**

App. First Insp.
 Date
 By

App. Final Insp.
 Date **4-6-73**
 By

Type of Bldg.
 Commercial
 Residential
 Single
 Multi Family
 New Construction
 Remodeling

NEW	REPL.		NO.	FEE
		SINKS		
		LAVATORIES		
		TOILETS		
		BATH TUBS		
		SHOWERS		
		DRAINS FLOOR SURFACE		
		HOT WATER TANKS		2.00
		TANKLESS WATER HEATERS		
		GARBAGE DISPOSALS		
		SEPTIC TANKS		
		HOUSE SEWERS		
		ROOF LEADERS		
		AUTOMATIC WASHERS		
		DISHWASHERS		
		OTHER		
TOTAL				2.00

Building and Inspection Services Dept: Plumbing Inspection

F. 12

FRANK M. HOGERTY, JR.
COMMISSIONER

HAROLD E. TRANEY
DEPUTY COMMISSIONER



CHARLES F. HOGAN
DIRECTOR

HARRY B. ROLLINS
ASSISTANT DIRECTOR

STATE OF MAINE

Insurance Department
DIVISION OF STATE FIRE PREVENTION
AUGUSTA, MAINE 04330

December 18, 1970

Mrs. Jeffrey McGrath
140 Clark Street
Portland, Maine

Dear Madam:

Re: Day Care Home

In accordance with Title 25, Revised Statutes of 1964, a Supervising State Fire Inspector recently inspected your property and found the following conditions in violation of the statutes governing the fire laws of this State, as indicated below:

Provide Underwriters Laboratories approved 2 1/2 lb. dry powder fire extinguisher and this to be mounted in kitchen.

C
O
P
Y

Please advise this office in writing when such violations of the fire laws have been corrected in order that this office may advise the Commissioner of the Department of Health and Welfare that your property complies with the statutory provisions relating to fire safety.

By direction of the Insurance Commissioner

Charles F. Hogan

Director

WHE:ag
cc: Health & Welfare Dept.
Chief Joseph Crero
Portland Building Inspector

ALWAYS PREVENT FIRE ALL WAYS

A



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT ISSUED 01481

SEP 2 1955

CITY OF PORTLAND

Portland, Maine, Aug. 30, 1955 Completed 9/2/55

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 140 Clark St. Use of Building 2-family dwelling No. Stories Max Building Existing " Name and address of owner of appliance Mrs. Pauline Olszewski, 140 Clark St. Installer's name and address Albion Sinnett, 687 Highland Ave., So. Port. Telephone 2-6803

General Description of Work

To install steam boiler (replacement) and oil burning equipment

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no If so, how protected? Kind of fuel? oil Minimum distance to burnable material, from top of appliance or casing top of furnace 2 1/2' From top of smoke pipe 54" From front of appliance over 4' From sides or back of appliance over 3' Size of chimney flue 8x10 Other connections to same flue none Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Arcomliner Labelled by underwriters' laboratories? yes Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom Type of floor beneath burner concrete Size of vent pipe 1 1/2' Location of oil storage basement Number and capacity of tanks 1-275 gal. Low water shut off yes Make McDonnell Miller No. 67 Will all tanks be more than five feet from any flue? Yes How many tanks enclosed? Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath? If so, how protected? Height of Legs, if any Skirting at bottom of appliance? Distance to combustible material from top of appliance? From front of appliance From sides and back From top of smoke pipe Size of chimney flue Other connections to same flue Is hood to be provided? If so, how vented? Forced or gravity? If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED: O.C. 9/2/55 - A.J.S.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Installer

Albion C. Sinnett

INSPECTION COPY

C17-214-12 MARKS


NOTES

- 1 Fill Pipe.....
- 2 Vent Pipe..... 9-19-56
- 3 Kind of Heat..... *Completed*
- 4 Burner Rigidity & Supports..... *W*
- 5 Name & Label.....
- 6 Stack (cont'd).....
- 7 High Limit (cont'd).....
- 8 Remote (cont'd).....
- 9 Piping Support & Protection.....
- 10 Valves in Supply Line.....
- 11 Capacity - Tank.....
- 12 Tank Mt. In y & Supports.....
- 13 Tank Distance.....
- 14 Oil Change.....
- 15 Instruction Card.....
- 16 Low Water Shut-off.....

Permit No. 55/1481
 Location 40 D Bank St
 Owner Mr. Carlene Plazowski
 Date of permit 9/2/55
 Approved

Handwritten notes at the bottom of the page, including the word "Approved" and other illegible scribbles.

138-142 CLARK STREET





APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date May 12, 1982
 Receipt and Permit number A 77692

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 140 Clark Street
 OWNER'S NAME: John Klewiada ADDRESS: lives there

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Flourescent _____ (not strip) TOTAL _____	
Strip Flourescent _____ ft. _____	
SERVICES:	
Overhead _____ Under ground ^{existing services} _____ Temporary _____ TOTAL amperes _____	
METERS: (number of) <u>2</u>	1.00
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels <u>2</u>	2.00
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
INSTALLATION FEE DUE: _____	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____	
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	
TOTAL AMOUNT DUE: _____	3.00

INSPECTION:
 Will be ready on _____, 19____; or Will Call XX
CONTRACTOR'S NAME: Albert Cannell
ADDRESS: East Baldwin, Maine
TEL.: 25-8407
MASTER LICENSE NO.: 04584 **SIGNATURE OF CONTRACTOR:** Albert Cannell
LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
 OFFICE COPY — CANARY
 CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS —

Permit Number 77692
Location 140 Clark St.
Owner J. Klewiada
Date of Permit 5-12-82
Final Inspection 6-21-82
By Inspector Libby
Permit Application Register Page No. 117

INSPECTIONS: Service by Libby

Service called in 6-21-82

Closing in _____ by _____

PROGRESS INSPECTIONS: 6-19-82 NOT

6-14-82 PM

CODE COMPLIANCE COMPLETED
DATE 6-21-82

DATE: _____ REMARKS:

6-19-82 Alum. wire in copper lugs. Change

OK