


116 Clark Street

NDP-REVIEW II





Loc. 116 Clark Street
Proj: NDP 2
Block 57C

Issued: September 28, 1971 Expires: Oct. 28, 1971

Mr. Patrick Foley
116 Clark Street
Portland, Maine

ROOM 315, CITY HALL
PORTLAND, MAINE 04111
774 8221

Board of Commissioners
PAUL M. FOLAN, Chairman
HORACE M. BUDD, Vice Chairman
JOHN H. MALCONIAN
THE REVEREND HAROLD A. McELWAIN
CHARLES W. REDMAN, JR.
THOMAS F. VALLEAU, Executive Director

Dear Mr. Foley:

An examination was made on September 24, 1971 of the premises located at 116 Clark Street, Portland, Maine by Rehabilitation Specialist Max Furrer. Violations of Municipal Codes relating to housing conditions were found as described below.

In accordance with the provisions of the above named codes you are required to correct these defects. Some repairs or improvements will require permits which are obtained from the Building, Health, Fire or other City Departments.

Financial assistance and construction advice are available from the federal government, by contacting the Neighborhood Development Program office at 247 Danforth Street, 774-3611. Please call us to discuss these before beginning work on your property.

Very truly yours,

Joseph E. Stuy, Jr. (per X'C)
Project Director

BY: *Reuben E. Furrer*
Chief, Rehabilitation Services

VIOLATIONS

HOUSING CODE REFERENCE

Exterior

1. Repair or replace deteriorated or missing trim.
2. Repair or replace the defective mortar on building walls.

3. Determine the reason that causes the front steps to sag.
4. Repair or replace the defective brick and mortar on chimney (3) above roofline. 3E
5. Repair or replace the deteriorated stucco on window arches.