

246 Danforth Street

NDI-REHAB II




SHAW-WALKER  
#8503-1R

# REQUEST FOR SERVICE

PORTLAND HEALTH DEPARTMENT

|                      |                                                                       |                                                    |         |          |   |
|----------------------|-----------------------------------------------------------------------|----------------------------------------------------|---------|----------|---|
| DATE RECEIVED        | 1.17.33                                                               | BY                                                 | JES     | DISTRICT | I |
| REQUEST BY           | NAME                                                                  | Joe Gray, Jr.                                      |         |          |   |
|                      | ADDRESS                                                               |                                                    |         |          |   |
| OWNER                | NAME                                                                  |                                                    |         |          |   |
|                      | ADDRESS                                                               |                                                    |         |          |   |
| CONDITIONS           | ADDRESS                                                               | Vacant lot next to (Tom's Mkt) (Don't know)        |         |          |   |
|                      |                                                                       | Also Tate-Tyng - <del>street</del> - junk vehicle. |         |          |   |
|                      |                                                                       | Accumulation of vehicles, again -                  |         |          |   |
| COMMENTS             | <p><i>Corrected order</i></p> <p><i>the car have been removed</i></p> |                                                    |         |          |   |
| SPECIAL INSTRUCTIONS | <p><i>I inspected the lot on 1/19/33</i></p>                          |                                                    |         |          |   |
| DIVISION             | SANITATION                                                            | HOUSING                                            | NURSING |          |   |
| PRIORITY             | ROUTINE                                                               | SPECIAL                                            |         |          |   |
|                      | URGENT                                                                | REPORT TO                                          |         |          |   |
|                      |                                                                       | BY                                                 | JES     |          |   |
|                      |                                                                       | DATE                                               | 1/17/33 |          |   |



ROOM 515, CITY HALL  
PORTLAND, MAINE 04111  
775-5451

Board of Commissioners  
PAUL M. FOLAN, Chairman  
HORACE M. BUDD, Vice Chairman  
JOHN H. MALCONIAN  
THE REVEREND HAROLD A. McELWAIN  
CHARLES W. REDMAN, JR.  
THOMAS F. VALLEAU, Executive Director

Loc. 246 Danforth Street  
Proj: NDP 2

Block 246 57C

Issued: Feb. 10, 1972 Expires: March 10, 1972

Mr. Hugh M. Hicks  
246 Danforth Street  
Portland, Maine

Dear Mr. Hicks:

An examination was made on February 7, 1972 of the premises located at 246 Danforth Street, Portland, Maine by Rehabilitation Specialist Max Furrer. Violations of Municipal Codes relating to housing conditions were found as described below.

In accordance with the provisions of the above named codes you are required to correct these defects. Some repairs or improvements will require permits which are obtained from the Building, Health, Fire or other City Departments.

Financial assistance and construction advice are available from the federal government, by contacting the Neighborhood Development Program office at 247 Danforth Street, 774-3611. Please call us to discuss these before beginning work on your property.

Very truly yours,

Joseph E. Gorman, Jr. (RCA)

Project Director

BY: *Edward E. Gorman*  
Chief, Rehabilitation Services

HOUSING CODE REFERENCE

VIOLATIONS

Exterior

1. Repair or replace loose or missing floor covering.
2. Repair or replace the leaking waterline in basement.
3. Repair or replace the defective hot air furnace.
4. Raise the girder in rear of basement to support the floor joists.

