

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

JULY 12, 1996

CITY OF PORTLAND

BROWN J B & SONS
PO BOX 207
PORTLAND ME 04112

Re: 203 VAUGHAN ST
CBL: 063- C-009
DU: 12

Dear Sir:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVE' ALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Amv Powers

Amv Powers
Code Enforcement Officer

Tammy Munson

Tammy Munson
Code Enfc. Offc./ Field Supv.

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

JULY 12, 1996

CITY OF PORTLAND

BROWN J B & SONS
PO BOX 207
PORTLAND ME 04112

Re: 203 VAUGHAN ST
CBL: 063- C-009
DU: 12

Dear Sir:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

1. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT.

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Amy Powers
Code Enforcement Officer

Tammy Munsor
Code Enfc. Offc./ Field Supv.