

HOUSING INSPECTION REPORT

Location: 28 A St
Housing Conditions Date: January 09, 1995
Expiration Date: March 10, 1995

Items listed below are in violation of Article V of the Municipal Codes, "Housing Codes", and must be corrected before the expiration date:

- | | | |
|----|---|--------|
| 1. | INT - 2ND FLR - HALLWAY
ADD LIGHT, OR CAP WIRES AT FIXTURE | 113.50 |
| 2. | EXT - FIRE ESCAPE -
PROVIDE BALUSTERS @ 4" O.C. - BOTH SIDES | 108.40 |
| 3. | EXT - FIRE ESCAPE -
PROVIDE HANDRAIL - LEFT SIDE | 108.40 |
| 4. | INT - 2ND FLR; APT #4 - KITCHEN
CAP THE WIRES AT THE STOVE | 113.50 |