

3-9 BURNHAM STREET

1



CITY OF PORTLAND

JOSEPH E GRAY, JR
DIRECTOR OF PLANNING
AND URBAN DEVELOPMENT

July 12, 1983

Mr. Robert & Rosalind Morrill
39 Burnham St.
Portland, ME 04106

Dear Mr. and Mrs. Morrill:

Your application for a building permit to repair your foundation at 39 Burnham St. has been reviewed and a building permit is herewith issued subject to the following.

Your plan shows that you are using "8" block. The code requires "12", but due to the fact it is a repair job and I have looked at this job and explained to you what the code requirements are and the type of structure involved, I will allow the use of "8" block.

Sincerely,

P. Samuel Hoffses,
Chief of Insp. Services

10

APPLICATION FOR PERMIT

PERMIT ISSUED

JUL 14 1983

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION 0.0695

ZONING LOCATION PORTLAND, MAINE July 8, 1983

CITY of PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 39 Burnham Street Fire District #1 #2
1. Owner's name and address Robert & Rosalind Morrill - same Telephone 774-3866
2. Lessee's name and address Telephone
3. Contractor's name and address Owners Telephone

Proposed use of building dwelling with foundation repair No. of sheets 1
Last use No. families
Material No stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 750.00

FIELD INSPECTOR—Mr. @ 775-5451
Appeal Fees \$
Base Fee 15.00
Late Fee 13.00
TOTAL \$

To repair foundation on dwelling, as per plans.
1 sheet of plans.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DO DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span. 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE
BUILDING INSPECTION—PLAN EXAMINER
ZONING:
BUILDING CODE:
Fire Dept.:
Health Dept.:
Others:

MISCELLANEOUS DO
Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant [Signature] Phone # same
Type Name of above Robert & Rosalind Morrill 2 3 4
Other
and Address

8


39 Bunkana St
Portland, Me 04101
July 7, 1983

Dear Mr. Hoffer;

This is to request a waiver on code number 1312.2.2. This code requires hollow masonry foundations to be constructed with 12 in concrete blocks. We have already purchased 800-8 in. blocks to do our foundation and are requesting that we be allowed to use them. Our house is an 18 by 36 foot wooden cape cod and 8 in blocks should be more than sufficient. We are replacing a rotten wooden foundation and need to get this done as quickly as possible. Thanking you in advance for your help.

Sincerely;

Robert + Geraldine Morrill





CITY OF PORTLAND

JOSEPH E. GRAY, JR.
DIRECTOR OF PLANNING
AND URBAN DEVELOPMENT

July 12, 1983

Mr. Robert & Rosalind Morrill
39 Burnham St.
Portland, ME 04106

Dear Mr. and Mrs. Morrill:

Your application for a building permit to repair your foundation at 39 Burnham St. has been reviewed and a building permit is herewith issued subject to the following.

Your plan shows that you are using "8" block. The code requires 12", but due to the fact it is a repair job and I have looked at this job and explained to you what the code requirements are and the type of structure involved, I will allow the use of "8" block.

Sincerely,

P. Samuel Hoffses,
Chief of Insp. Services

APPLICATION FOR PERMIT

PERMIT ISSUED

JUL 14 1983

B.O.C.A. USE GROUP

00595

B.O.C.A. TYPE OF CONSTRUCTION

PORTLAND, MAINE .. July 8, 1983.

ZONING LOCATION

CITY OF PORTLAND

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 39 Burnham Street
1. Owner's name and address Robert & Rosalind Morrill - same
2. Lessee's name and address Owners
3. Contractor's name and address Owners

Fire District #1 , #2
Telephone 774-3866
Telephone

Telephone

No. of sheets 1

No. families

No. families

Roofing

Appeal Fees \$

Base Fee 15.00

Late Fee 15.00

TOTAL \$

Proposed use of building dwelling with foundation repair

Last use

Material

Other buildings on same lot

Estimated contractual cost \$ 750.00

FIELD INSPECTOR—Mr. @ 775-5451

To repair foundation on dwelling, as per plans.
1 sheet of plans.

Stamp of Special Conditions

PERMIT ISSUED WITH LETTER

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? no
Is any electrical work involved in this work? no
Is connection to be made to public sewer?

Has septic tank notice been sent?

Height average grade to top of plat

Size, front

Material of foundation

Kind of roof

No. of chimneys

Framing Lumber—Kind

Size Girder

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor

On centers: 1st floor

Maximum span: 1st floor

If one story building with masonry walls, thickness of walls?

IF A GARAGE

No. cars now accommodated on same lot

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

MISCELLANEOUS

Will work require disturbing of any tree on a public street?

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

APPROVALS BY: DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING:

BUILDING CODE:

Fire Dept.:

Health Dept.:

Others:

Signature of Applicant

Type Name of above

[Handwritten Signature]

Robert & Rosalind Morrill

Phone # same

Other

PERMIT ISSUED WITH LETTER

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

8 MA. 190we

Permit No. 83/695
Location 22 Burnham St.
Owner Robert Merrill
Date of permit 7-8-83
Approved 7-14-83
Dwelling - Repair Foundation
Garage _____
Alteration _____

NOTES

7/18/83 Bldg min. Tech. Permit.
No work has yet
12/21/83
11/1/83 ~~_____~~ o.k.

