

14-18 CHADWICK STREET

SHAW-WALKER

Full cut # 920R - Half cut # 9203R - Thin # 9203R - Fifth cut # 9203D



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, February 6, 1963

PERMIT ISSUED FEB 6 1963 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 16 Chadwick St. Use of Building Dwelling No. Stories 20525 New Building Existing "
Name and address of owner of appliance Kenneth Burr, 16 Chadwick St.
Installer's name and address Ballard Oil & Equipment Co. 135 Marginal Way Telephone 2-1991

General Description of Work

To install Forced warm air heating system and oil burner (replacements) Williamson #535-25.

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3'
From top of smoke pipe 2' From front of appliance 8' From sides or back of appliance 4'
Size of chimney flue 12x12 Other connections to same flue stove
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Williamson-guntypo Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/4" existing
Location of oil storage existing Number and capacity of tanks 275 existing
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burner

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED: [Signature] 2-6-63

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Ballard Oil & Equipment Company

Signature of Installer

[Signature]

CS 300

INSPECTION COPY

7/14

7-11-3-18

Permit No. 63/11.3

Location 160 Alameda St.

Owner Samuel Barr

Date of permit 2/6/63

Approved

NOTES


|                           |  |
|---------------------------|--|
| City                      |  |
| County                    |  |
| State of Calif.           |  |
| Number Utility & Segments |  |
| Name of Utility           |  |
| Street Name               |  |
| High Voltage (kV)         |  |
| Number of Poles           |  |
| Number of Wires           |  |
| Number of Transformers    |  |
| Number of Meters          |  |
| Number of Service Drops   |  |
| Number of Connections     |  |
| Number of Splices         |  |
| Number of Joints          |  |
| Number of Crossings       |  |
| Number of Obstructions    |  |
| Number of Other           |  |
| Remarks                   |  |
| Inspection                |  |
| Inspection Date           |  |
| Inspection Status         |  |

2-19-63 1/2 hr. work

3-19-63 Closed

3-22-63 Completed

04  
G.P.





FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

Permit No. 1074  
NOV 10 1936

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. Portland, Maine, November 12, 1936

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 14-18 Chadwick Street Use of Building dwelling house  
Name and address of owner Kenneth T. Burr, 14 Orland St. Ward 7  
Contractor's name and address The Boyd Corporation 176 Middle St. Telephone 5-7858

General Description of Work

To install air conditioning system with Oil Burner

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel Oil  
Material of supports of heater or equipment (concrete floor or what kind) concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 2'  
from top of smoke pipe 2', from front of heater 4' from sides or back of heater 4'  
Size of chimney flue 12" X 12" Other connections to same flue none

IF OIL BURNER

Name and type of burner Dalco Labeled and approved by Underwriters' Laboratories? yes  
Will operator be always in attendance? \_\_\_\_\_ Type of oil feed (gravity or pressure) pressure  
Location of storage basement No. and capacity of tanks 1 - 275 gal.  
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? \_\_\_\_\_

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

ATTENTION COPY

Signature of contractor By F. Carney

6256B

Ward 7 Permit No. 36 1974  
Location 14-18 Chalkwick St  
Owner Gen. with J. Burr  
Date of permit 11/12/36.

Post Card sent \_\_\_\_\_

Notif. for insp. \_\_\_\_\_

Approval Tag issued 2/2/37

Oil Burner Check Lt. (date) 2/2/37

1. Kind of heat Hot Air

2. Label

3. Anti-siphon

4. Oil storage

5. Tank distance

6. Vent pipe

7. Fill pipe

8. Gauge

9. Rigidity

10. Feed safety

11. Pipe sizes and material


12. Control valve

13. Ash pit vent

14. Temp. or pressure safety

15. Instruction card

NOTES



File: Rept. No. 7897B-1

Sept. 16, 1936

Brown & Berry, Inc.,  
22 Monument Square,  
Portland, Me.

Gentlemen:

Enclosed is the building permit covering construction of a dwelling house at 14-1B Chadwick St. for Kenneth T. Barr.

The following minor details are called to your attention, and a copy of this letter is being sent to Wadsworth & Boston, architects:

The curb or threshold at the doorway leading from the garage to the cellar stairs is shown on the plans as four inches high. The Code calls for this height to six inches above the level of the garage floor.

Where the studs are doubled around window and door openings, the inside studs are shown running by the headers over the openings up to the girt or plate as the case may be. The intent of the Code and the usual practice seem to be to stop these inside studs at the under side of the headers, extending the headers to the outside studs, thus affording definite support beneath each end of each header. I realize that this arrangement is not strictly necessary at the openings in the first story because the girt is larger than usual.

Please be governed accordingly.

Very truly yours,

9/14/36

House for Kenneth Burr at 14-16 Chadwick Street

1. - 4" curb shown in doorway from garage to cellar stairway should be at least 6" high.

2. Jack studs should be cut beneath 4x4 headers, at least in second story.

3. Statement of design needed. - Man from Waplington Boston's office has been in + talked out details of design.

4. Can vent from basement toilet and vent from kitchen, go into same chimney flue? Vent from kitchen has exhaust fan and evidently vents room and not closed compartment of range - A.G.D. - Electric Range.

5. - 15" B.I. @ 38.5¢ in 23' span is good for 31,000#

$$\frac{15+8}{2} \times 23 \times 50 =$$

$$13,225 \#$$

$$\frac{15+8}{2} \times 23 \times 55 =$$

$$14,548 \#$$

$$[(23 \times 9) - (4 \times 7)] 20 = 179 \times 20 = 3,580$$

$$[(16 \times 7.5) - (3 \times 7)] 20 = 99 \times 20 = 1,980$$

$$33,333$$

?

6" I @ 125¢ on 23' span is good for 10,900#

$$2(12+5 \times 8 \times 55) = 8,800 \#$$





15) SINGLE RESIDENCE ZONE  
APPLICATION FOR PERMIT

PERMIT ISSUED  
1455

Class of Building or Type of Structure Third Class SEP 15 1938

Portland, Maine, September 12, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter-install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 14-18 Chadwick Street Ward 7 Within Fire Limits? YES Dist. No. 8

Owner's or Lessee's name and address Kenneth T. Burr, 14 Orland Street Telephone \_\_\_\_\_

Contractor's name and address Brown & Berry, Inc. 22 Monument Sq. Telephone 8-2482

Architect's name and address F Adsworth & Boston, 108 Middle St.

Proposed use of building dwelling house with 2 car garage attached No. families 1

Other buildings on same lot \_\_\_\_\_

Plans filed as part of this application? yes No. of sheets \_\_\_\_\_

Estimated cost \$ 15,000.

Gas 28  
Fee \$ 5.78  
Car. 50  
44.00

Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ St. le of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_

General Description of New Work

To erect two story brick veneer dwelling with two car brick garage attached  
(brick wall between house and garage)

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front 39' depth 68' No. stories 2 Height average grade to top of plate \_\_\_\_\_

To be erected on solid or filled land? solid earth or rock? earth Height average grade to highest point of roof 28' 6"

Material of foundation concrete Thickness, top 12" bottom 18"

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of Roof pitch Rise per foot 6" Roof covering Slate

No. of chimneys 2 (outside) Material of chimneys brick of lining tile

Kind of heat air condition Type of fuel Oil Is gas fitting involved? yes

Corner posts 4x6 Sills 4x8 Girt or ledger board? girt Size 4x8

Material columns under girders iron columns Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor \_\_\_\_\_, 2nd concrete floor in garage, 3rd \_\_\_\_\_, roof \_\_\_\_\_

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot none, to be accommodated 2

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? none

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY Oliver T. Dubois Signature of owner By Kenneth T. Burr  
Edward C. Berry, Inc.  
CHIEF OF FIRE DEPT. 76803

Ward 7 Permit No. 36/1/56  
 Location 14-18 Chadwick St  
 Owner Kenneth T. Buss  
 Date of permit 9/15/36  
 Notif. closing-in  
 Inspn. closing-in  
 Final Inspn. 2/2/37  
 Cert. of Occupancy issued 2/3/37

NOTES

9/14/36 Location O.K.  
 9/15/36 O.K.  
 9/25/36 Pouring  
 foundation  
 10/2/36 Foundation  
 is all poured and  
 stripped. Ceiling  
 boards over garage  
 foundation  
 10/11/36 First floor  
 10/12/36 First floor  
 10/20/36 Framing up  
 11/1/36 Work not  
 under started

10/26/36 - Work progres-  
 sing  
 10/29/36 - Same - A.G.S.  
 11/2/36 - Same - A.G.S.  
 11/9/36 - Scaffolding  
 put on without in-  
 spection. A.G.S. per-  
 mission to close in  
 2nd story only (on  
 red tag).  
 11/10/36 - Gave gas tag  
 to close in remainder  
 of building. No permit  
 for heat. Boyd Corp.  
 making installation  
 of boiler in job  
 to notify of fire to  
 A.G.S. The permit - A.G.S.  
 11/13/36 - Mrs. Berry  
 agreed over phone  
 to take care of matter  
 of seeing that no  
 woodwork is put in  
 partitions closer than  
 2" above heads of hot  
 air ducts - gas for pipe  
 A.G.S. Mr. Stumm  
 will maintain in regard  
 to this same 11/4/36.  
 11/27/36 - Plastering - A.G.S.  
 11/29/37 - House occupied.  
 Unable to make in-  
 spection on account

of newly painted  
 basement floor - A.G.S.  
 2/2/37 - O.K. for gas  
 tag - A.G.S.  
 2/2/37 - Mr. Thompson  
 of Gas Company  
 says he will install  
 in gas tag - A.G.S.