

● **魚**

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

December 5, 1991

RE: 1199 Congress Street

Morris Silver
1199 Congress St.
Portland, ME 04102


Dear Sir:

Your application to install 2 above ground tanks, 1-275 gallon and 1-500 gallon, has been reviewed and a permit is herewith issued subject to the following requirements:

1. Proposed 775 gallon total, proposed storage exceeds that allowed within 10' of property line. Either storage volume must be reduced or installation moved to a point where 15' clearance of property may be met. Revised plans must be submitted.
2. Piping must be protected from mechanical damage through use of barriers to deny access to area of piping or bollards; to deny vehicle access.
3. Installation shall be in accordance with N.F.P.A. #30.
4. Area of tanks and piping shall be kept clear of vegetation and combustible debris or storage.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


P. Samuel Hoffses
Chief of Inspection Services

/el

cc: LT. Wallace Garroway, Fire Prevention Bureau

500 gln = \$35
 275 gln 25
 \$60 fee

MASS AVE

OPH-ISCAND

STORE

TANK FOR HEAT. FOR BLOC

275 Gk
 500 Gk
 1-1-TANK

2000 gal
 DIKE
 1000 gal present

RE-INSTALL EXISTING
 DIKE AND TANKS.
 INSTALLED + PIPED BY
 LES WILSON + SONS. - TANK + PIPE INSTALLERS.
 1199 CONGRESS ST
 MARSE LAURE