

10-12 CATHERINE STREET

100-443887-1000



APPLICATION FOR PERMIT  
DEPARTMENT OF BUILDING INSPECTIONS SERVICES  
ELECTRICAL INSTALLATIONS

Date 11-10, 19 77  
Receipt and Permit number A03396

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications.

LOCATION OF WORK: 12 Catherine St.

OWNER'S NAME: Stuart Infantino ADDRESS: Same

OUTLETS: (number of)

Lights \_\_\_\_\_  
Receptacles \_\_\_\_\_  
Switches \_\_\_\_\_  
Plugmold \_\_\_\_\_ (number of feet)

FEES

TOTAL \_\_\_\_\_

FIXTURES: (number of)

Incandescent \_\_\_\_\_  
Fluorescent \_\_\_\_\_ (Do not include strip fluorescent)

TOTAL \_\_\_\_\_

Strip Fluorescent, in feet \_\_\_\_\_

SERVICES:

Permanent, total amperes \_\_\_\_\_  
Temporary \_\_\_\_\_

METERS (number of) \_\_\_\_\_

MOTORS (number of) \_\_\_\_\_

Fractional \_\_\_\_\_

1 HP or over \_\_\_\_\_

RESIDENTIAL HEATING:

Oil or Gas (number of units) \_\_\_\_\_

Electric (number of rooms) \_\_\_\_\_

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler) \_\_\_\_\_

Oil or Gas (by separate units) \_\_\_\_\_

Electric (total number of kws) \_\_\_\_\_

APPLIANCES: (number of)

Ranges \_\_\_\_\_

Cook Tops \_\_\_\_\_

Wall Ovens \_\_\_\_\_

Dryers \_\_\_\_\_

Fans \_\_\_\_\_

Water Heaters \_\_\_\_\_

Disposals \_\_\_\_\_

Dishwashers \_\_\_\_\_

Compactors \_\_\_\_\_

Others (denote) \_\_\_\_\_

TOTAL \_\_\_\_\_

MISCELLANEOUS: (number of)

Branch Panels \_\_\_\_\_

Transformers \_\_\_\_\_

Air Conditioners \_\_\_\_\_

Signs \_\_\_\_\_

Fire/Burglar Alarms \_\_\_\_\_

Circus, Fairs, etc. \_\_\_\_\_

Alterations to wires X \_\_\_\_\_

Repairs after fire \_\_\_\_\_

Heavy Duty, 220v outlets \_\_\_\_\_

Emergency Lights, battery \_\_\_\_\_

Emergency Generators \_\_\_\_\_

3.00

INSTALLATION FEE DUE: \_\_\_\_\_

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT \_\_\_\_\_

DOUBLE FEE DUE: \_\_\_\_\_

FOR REMOVAL OF A "STOP ORDER" (304-16.b) \_\_\_\_\_

FOR PERFORMING WORK WITHOUT A PERMIT (304-9) \_\_\_\_\_

TOTAL AMOUNT DUE: \_\_\_\_\_

3.00

INSPECTION:

Will be ready on \_\_\_\_\_, 19\_\_\_\_, or Will Call X

CONTRACTOR'S NAME: L & M Elec. Co.

ADDRESS: 12 Clifton St.

TEL.: 774-4137

MASTER LICENSE NO.: 826

LIMITED LICENSE NO.: \_\_\_\_\_

SIGNATURE OF CONTRACTOR:

V. Beckford

INSPECTOR'S COPY



# CITY OF PORTLAND, MAINE

## Application for Permit to Install Wires

Permit No. **55011**

Issued

Portland, Maine

**July 13, 1966**

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address **Mrs. Angeles** Tel. **7750422**  
 Contractor's Name and Address **Anthony Mancini**  
 Location **12 Catharine St** Use of Building **R**

Number of Families **1** Apartments **1** Stores **1** Number of Stories **1**  
 Description of Wiring: New Work Additions Alterations

Pipe ☒ Cable ☐ Metal Molding ☐ BX Cable ☐ Plug Molding (No. of feet) ☐  
 No. Light Outlets ☐ Plugs ☐ Light Circuits ☐ Plug Circuits ☐  
 FIXTURES: No. ☐ Light Switches ☐ Fluor. or Strip Lighting (No. feet) ☐  
 SERVICE: Pipe ☐ Cable ☒ Underground ☐ No. of Wires ☐ Size ☐  
 METERS: Relocated ☐ Added ☐ Total No. Meters ☐  
 MOTORS: Number ☐ Phase ☐ H. P. ☐ Amps ☐ Volts ☐ Starter ☐  
 HEATING UNITS: Domestic (Oil) ☐ No. Motors ☐ Phase ☐ H.P. ☐  
 Commercial (Oil) ☐ No. Motors ☐ Phase ☐ H.P. ☐  
 Electric Heat (No. of Rooms) ☐

APPLIANCES: No. Ranges ☐ Watts ☐ Brand Feeds (Size and No.) ☐  
 Elec. Heaters ☐ Watts ☐  
 Miscellaneous ☐ Watts ☐

Transformers ☐ Air Conditioners (No. Units) ☐ Extra Cabinets or Panels ☐  
 Will commence **19** Ready to cover in ☐ Signs (No. Units) ☐  
 Amount of Fee \$ ☐ Inspection **13** 19 **66(PMC)**

Signed **Anthony Mancini**

DO NOT WRITE BELOW THIS LINE

SERVICE ☒  
 VISITS: 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5 ☐ 6 ☐  
 REMARKS: 7 ☐ 8 ☐ 9 ☐ 10 ☐ 11 ☐ 12 ☐

INSPECTED BY **FW Hubert**  
 (OVER)

**CITY OF PORTLAND, MAINE**  
**Application for Permit to Install Wires**

Permit No. **54943**

Issued  
 Portland, Maine **June 16**, 19**66**

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address **Magee 12 Catharine** Tel. **774-0785**  
 Contractor's Name and Address **Morrison 142 Pleasant** Tel. **772-2975**

Location **12 Catharine St** Use of Building **Home**  
 Number of Families **1** Apartments **0** Stores **0** Number of Stories **2**

Description of Wiring: New Work **Aluminum Cabling** Additions **0** Alterations **0**

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)

No. Light Outlets Plugs Light Circuits Plug Circuits

FIXTURES: No. Light Switches Fluor. or Strip Lighting (No. feet)

SERVICE: Pipe Cable Underground No. of Wires Size

METERS: Relocated Added Total No. Meters

MOTORS: Number Phase H. P. Amps Volts Starter

HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.

Commercial (Oil) No. Motors Phase H.P.

Electric Heat (No. of Rooms)

APPLIANCES: No Ranges Watts Brand Feeds (Size and No.)

Elec Heaters Watts

Miscellaneous Watts Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Signs (No. Units)

Will commence **19** Ready to cover in **19** Inspection **23 June 1966**

Amount of Fee \$ **1.** Signed **Joseph D. Morrison**

DO NOT WRITE BELOW THIS LINE

SERVICE METER GROUND

VISITS: 1 2 3 4 5 6

7 8 9 10 11 12

REMARKS: **Aluminum Cabling**

INSPECTED BY **F.W. Hubert** (OVER)

**Work Done By Mancini**





PERMIT  
NUMBER 2822

Date Issued 12/10/55

PORTLAND PLUMBING  
INSPECTOR

By J. P. Welch

APPROVED FIRST INSPECTION

Date 12-10-55

By J. P. Welch

APPROVED FINAL INSPECTION

Date 12-10-55

By J. P. Welch

TYPE OF BUILDING

☐ COMMERCIAL

☐ RESIDENTIAL

☐ SINGLE

☐ MULTI FAMILY

☐ NEW CONSTRUCTION

☐ REMODELING

Address: 12 Katherin St

Installation For:

Owner of Bldg. Mrs. Geo. Magalis

Owner's Address: 12 Katherin St

Plumber: Geo. J. Boyle

Date: 12/10/55

NEW

REPAIR

PROPOSED INSTALLATIONS

SINKS

LAVATORIES

TOILETS

BATH TUBS

SHOWERS

DRAINS

HOT WATER TANKS

TANKLESS WATER HEATERS

GARBAGE GRINDERS

SEPTIC TANKS

HOUSE SEWERS

ROOF LEADERS (conn. to house drain)

NUMBER

FEE

1

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

1.00

SM 12-33

PORTLAND HEALTH DEPT.

PLUMBING INSPECTION

Total 1.00



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, July 13, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ alter ~~renew~~ ~~demolish~~ ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 12 Catherine Street Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's name and address George Magellis, 12 Catherine Street Telephone \_\_\_\_\_  
Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
Contractor's name and address Sidney Hamilton, 111 Alha Street Telephone 3-6756  
Architect \_\_\_\_\_ Specifications \_\_\_\_\_ Plans yes No. of sheets 1  
Proposed use of building Dwelling No. families 1  
Last use \_\_\_\_\_ No. families 1  
Material FRAME No. stories 2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Other buildings on same lot \_\_\_\_\_  
Estimated cost \$ 125. Fee \$ 1.00

## General Description of New Work

To glass-in existing front entrance porch - existing with roof over same prior to December 5, 1938.  
More than half of the area of the vertical enclosing walls will consist of window sash or glass area of doors

CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Details of New Work

Is any plumbing work involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_  
Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_  
Framing lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ size \_\_\_\_\_  
Girders \_\_\_\_\_ Size \_\_\_\_\_ Columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-10" O. C. Bridging in every floor and flat roof span over 8 feet.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

APPROVED:

## Miscellaneous

Will work require disturbing of any tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

George Magellis

Signature of owner

Sidney M. Hamilton

INSPECTION COPY



Permit No 45/ 751

Location 12 Catherine St.

Owner George Magellan

Date of permit 7/16/45

Notif. closing-in

Inspn. closing-in

Final Notif

Final Inspn. 10-22-45 1700

Cert. of Occupancy issued

NOTES

7/21/45 Project started

4-25-45 no change

1700



FILL IN COMPLETELY AND SIGN WITH INK

RECEIVED

PERMIT ISSUED

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

DEPT. OF BLDG. LSP.

CITY OF PORTLAND

Maine

9/11/33

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.  
The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 12 Catherine St. Use of Building Res.  
Name and address of owner Geo. Magalos P.C. Int 9/11/33 Ward 7  
Contractor's name and address Cut & Cut Telephone 2-4957

General Description of Work

NOTIFICATION BEFORE LATENESS OR CLOSING IN IS WAIVED.

To install oil Burner

IF HEATER, POWER BOILER OR COOKING DEVICE CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED.

Is heater or source of heat to be in cellar? Yes If not, which story \_\_\_\_\_ Kind of Fuel \_\_\_\_\_  
Material of supports of heater or equipment (concrete floor or what kind) Concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, \_\_\_\_\_  
from top of smoke pipe \_\_\_\_\_, from front of heater \_\_\_\_\_, from sides or back of heater \_\_\_\_\_

IF OIL BURNER

Name and type of burner Wallbrun Labeled and approved by Underwriters' Laboratories? yes  
Will operator be always in attendance? \_\_\_\_\_ Type of oil feed (gravity or pressure) gravity  
Location oil storage Basement No. and capacity of tanks 1 - 275 gal.  
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? \_\_\_\_\_  
Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor

SA Cath

60005

Ward 7 Permit No. 33/1289  
 Location Q2 Catherine St  
 Owner San Angeles  
 Date of permit 9/11/33  
 Notif. closing-in \_\_\_\_\_  
 Inspn. closing-in \_\_\_\_\_  
 Final Notif. 9/13/33-4PM  
 Final Inspn. 9/15/33-O.T.  
 Cert. of Occupancy issued None

NOTES

1. Kind of heat Steam
2. Label ✓
3. Siphon ✓
4. Oil storage ✓
5. Tank distance ✓
6. Vent pipe ✓
7. Fill pipe ✓
8. Gauge ✓
9. Rigidity ✓
10. Feed safety ✓
11. Pipe sizes & material ✓
12. Control valve ✓
13. Ash pit vent ✓
14. Temp. or pressure safety ✓
15. Instruction card ✓
16. \_\_\_\_\_

9/14/33 - This burner  
 thru faulty operation  
 of stack switch overflowed

and caused oil to  
 run over flow. New  
 stack switch put on  
 and burner appears  
 to run ok - A. J. G.

FILL IN COMPLETELY AND SIGN WITH INK.



Permit No. \_\_\_\_\_

JAN 11 1920

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Jan 14 1920

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Catherine St. Use of Building Dwelling House  
Name and address of owner Edward T. Carignan Milton St. Ward 7  
Contractor's name and address Jay ## Cohen & Laurie 116 Middle St. Telephone 7-3641

## General Description of Work

To install Steam Heating System

### IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of floor concrete  
Material of supports of heater or equipment (concrete floor or what kind) concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, \_\_\_\_\_  
from top of smoke pipe 3'-0" from front of heater 4'-0" from sides or back of heater 4'-0"

### IF OIL BURNER

Name and type of burner \_\_\_\_\_ Approved by Underwriters' Laboratories? \_\_\_\_\_  
Location oil storage \_\_\_\_\_ No. and capacity of tanks \_\_\_\_\_  
Will all tanks be more than seven feet from any flame? \_\_\_\_\_ How many tanks fireproofed? \_\_\_\_\_

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor

Cohen & Laurie  
M. Cohen

INSPECTION COPY

NOTIFICATION BEFORE LATHING  
OR CLOSING IN IS WAIVED


CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAIVED

4030A

Ward 7 Permit No 3/45  
Location 8 Catherine St.  
Owner E. T. Carignan  
Date of permit 1/14/31  
Notif. closing-in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. 3/13/31  
Cert. of Occupancy issued None

NOTES

3/13/31 - Installation  
O.K. - A. J. S.



6262

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for 2 car frame garage  
at 6-B Catharine Street

Date 7/24/30

1. In whose name is the title of the property now recorded? *Edw. Baugman*
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? *Yes*
3. Is the outline of the proposed work now staked out upon the ground? *yes* If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? *10'*
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? *yes*
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? *yes*
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? *yes*

*Edw. Baugman*



(S) RESIDENCE ZONE

## APPLICATION FOR PERMIT

Class of Building or Type of Structure Third ClassPortland, Maine, July 24, 1930PERMIT ISSUED  
Permit No. 1589  
JUL 28 1930

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~also install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 5-8 Catherine Street Ward 7 Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's or Lessee's name and address E. T. Carigan, 40 Milton St. Telephone 7 3877 M  
Contractor's name and address Owner Telephone \_\_\_\_\_  
Architect's name and address \_\_\_\_\_  
Proposed use of building 2 car garage No. families \_\_\_\_\_  
Other buildings on same lot 1 family dwelling house

## Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_

## General Description of New Work

To erect 2 car frame garage

## Details of New Work

Size, front 18' depth 20' No. stories 1 Height average grade to top of plate 8'  
Height average grade to highest point of roof 16'  
To be erected on solid or filled land? solid earth or rock? earth  
Material of foundation concrete slab Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof hip 8" to foot Roof covering asphalt roofing Class C Und. Lab.  
No. of chimneys no Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Kind of heat no Type of fuel \_\_\_\_\_ Distance, heater to chimney \_\_\_\_\_  
If oil burner, name and model \_\_\_\_\_  
Capacity and location of oil tanks \_\_\_\_\_  
Is gas fitting involved? \_\_\_\_\_ Size of service \_\_\_\_\_  
Corner posts 4x4 Sills 4x4 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor concrete, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x4  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 24"  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot none, to be accommodated 2  
Total number commercial cars to be accommodated none  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Plans filed as part of this application? yes No. sheets 1  
Estimated cost \$ 400. Fee \$ 75  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Oliver T. Garbhorn

CHIEF OF FIRE DEPT.

3514A



Ward 7 Permit No. 30/1539

Location 6-8 Catherine St.

Owner C. T. Carignan

Date of permit 7/26/30

Notif. closing-in


Final Notif.

Final Inspn.

Cert. of Occupancy issued

NOTES

7/24/30 - Staking out  
O.R. & G.S.  
8/7/30 - Framing  
completed. A.G.S.





FILL IN COMPLETELY AND SIGN WITH INK

Permit No. 1156

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, July 19, 1930

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 6-B Catherine Street Use of Building dwelling house  
Name and address of owner E. T. Carignan Carignan, 40 Milton St. Ward 7  
Contractor's name and address A. E. Moody, 471 Auburn St. Telephone P 1156

## General Description of Work

To install steam heating system

### IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel coal  
Material of supports of heater or equipment (concrete floor or what kind) concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 30"  
from top of smoke pipe 30", from front of heater 5' from sides or back of heater 5'

### IF OIL BURNER

Name and type of burner \_\_\_\_\_ Approved by Underwriters' Laboratories? \_\_\_\_\_  
Location oil storage \_\_\_\_\_ No. and capacity of tanks \_\_\_\_\_  
Will all tanks be more than seven feet from any flame? \_\_\_\_\_ How many tanks fireproofed? \_\_\_\_\_  
Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor A. E. Moody

INSPECTION COPY


NOTIFICATION REQUIRED  
OR CLOSING IN


22514

Yard 7 Permit No. 30/1489  
Location 6-8 Catharine St.  
Owner E.T. Corrigan  
Date of permit 7/21/30  
Notif. closing-in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. 2/16/31  
Cert. of Occupancy issued None.

NOTES

2/16/31 - No heat in-  
stalled under this  
permit. A J S  
See permit # 31/45





STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for one family frame dwelling house  
at 6-8 Catherine Street

Date 5/2/30

1. In whose name is the title of the property now recorded? *Thomas A. London*
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? *yes*
3. Is the outline of the proposed work now staked out upon the ground? *yes* If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? *12"*
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? *yes*
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? *yes*
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? *yes*

*Edw. B. Morgan*



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, May 2, 1930

Permit No. 0763

PERMIT ISSUED

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building structure ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 6-8 Catherine Street Ward 7 Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's or Lessee's name and address H. A. Gargison, 40 Milton St. Telephone 8877  
Contractor's name and address Owner Telephone \_\_\_\_\_  
Architect's name and address \_\_\_\_\_  
Proposed use of building dwelling house No. families 1  
Other buildings on same lot \_\_\_\_\_

## Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_

## General Description of New Work

To erect one family frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor

## Details of New Work

Size, front 40' depth 24' No. stories 2 1/2 Height average grade to highest point of roof 30'  
To be erected on solid or filled land? solid earth or rock? earth  
Material of foundation concrete Thickness, top 10" bottom 12"  
Material of underpinning brick Height 20" Thickness 8"  
Kind of roof pitch 10" 8" to foot Roof covering Asphalt shingles Class O Und. Lab.  
No. of chimneys two Material of chimneys brick of lining flue  
Kind of heat steam Type of fuel \_\_\_\_\_ Distance, heater to chimney \_\_\_\_\_  
If oil burner, name and model \_\_\_\_\_  
Capacity and location of oil tanks \_\_\_\_\_  
Is gas fitting involved? yes Size of service \_\_\_\_\_  
Corner posts 4x6 Sills 4x8 Girt or ledger board? girt Size 2x6  
Material columns under girders iron pipe Size 4" Max. on centers 3'  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor 2x8 2nd 2x8 3rd 2x6 unf roof 2x6  
On centers: 1st floor 16" 2nd 16" 3rd 24" roof 24"  
Maximum span: 1st floor 14' 2nd 14' 3rd 14' roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Plans filed as part of this application? yes No. sheets 1  
Estimated cost \$ 6000. for \$ 21.25 per sq. ft.  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of owner H. A. Gargison

INSPECTION COPY

1596A

Ward 7 Permit No. 30/263  
 Owner E. T. Casagrande  
 Date permit 5/13/30  
 Notif. closing-in  
 Insp. closing-in 7/14/30 12:30  
 Final Notif.  
 Final Insp. 11/17/32 O.T.  
 Cert. of Occupancy issued 11/18/32

NOTES:

5/2/30 - Staking out  
 5/7/30 - Excavation  
 started - A.G.S.  
 5/13/30 - Excavating  
 5/20/30 - Excavation com-  
 pleted - A.G.S.  
 5/26/30 - Foundation  
 poured - A.G.S.  
 6/2/30 - Laying under  
 pinning - A.G.S.  
 6/9/30 - Laying pinning  
 partly laid - A.G.S.  
 6/16/30 - Framing first  
 story - A.G.S.  
 6/20/30 - 8x10 header  
 used in 10 openings in  
 front wall. Watch  
 framing around  
 girders near

fireplace A.G.S.  
 6/28/30 - Working on  
 sun porch - A.G.S.  
 7/3/30 - Working on  
 inside wall - A.G.S.  
 7/11/30 - Ready for closing  
 in inspection as soon  
 as plumbing is done -  
 A.G.S.  
 7/14/30 - 11:15 for chimney  
 not cut in place chimney  
 mortar to be used in  
 place of shingles where  
 chimney is shingled  
 back in place. Inspected  
 chimney - A.G.S.  
 7/14/30 - First floor  
 and stairs at first  
 second floors & ceiling  
 finished at second floor level  
 in bath room. Chimney  
 built to install on attic  
 floor level - A.G.S.  
 7/14/30 - Mortar joints  
 in chimney not properly  
 filled. First floor all  
 plate levels are  
 outside. Chimney is  
 not carried to 1st floor  
 proper bearing in  
 carrying partition first  
 floor where studs are

cut to short RT #3028  
 7/15/30 - Ratters taken  
 care of. Watch smoke  
 opening in collar  
 height of chimney  
 above roof on final.  
 Given to given A.G.S.  
 7/2/30 - Chimney does  
 not look as if it were  
 3 feet above highest  
 point where it cuts  
 roof. Told man  
 working at 11 Catherine  
 street that this should  
 be raised to legal  
 distance - A.G.S.  
 1/31/36 - No one working  
 here. Unable to get in  
 A.G.S.  
 3/10/31 - Heating instal-  
 lation O.K. Chimney  
 not yet topped out -  
 A.G.S.  
 Owner: -  
 Mr. George Magiles,  
 8 Catherine Street  
 11/17/32 - Gas tag picked  
 up - A.G.S.