

14-18 CATHERINE STREET

SHAW-WALKER

Full cut # 820R • Half cut # 8202R • Third cut # 8203R • Full cut # 8204R

# CITY OF PORTLAND, MAINE

## Application for Permit to Install Wires

Permit No. 324889  
 Issued  
 Portland, Maine May 31, 1966

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out -- Minimum Fee, \$1.00)

Owner's Name and Address George Siegman Tel.  
 Contractor's Name and Address Curran Electric Tel.  
 Location 16 Catherine St. Use of Building  
 Number of Families \_\_\_\_\_ Apartments \_\_\_\_\_ Stores \_\_\_\_\_ Number of Stories \_\_\_\_\_  
 Description of Wiring: New Work \_\_\_\_\_ Additions \_\_\_\_\_ Alterations \_\_\_\_\_  
Alarm siding job. (Services replacement)  
 Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)  
 No. Light Outlets \_\_\_\_\_ Plugs \_\_\_\_\_ Light Circuits \_\_\_\_\_ Plug Circuits \_\_\_\_\_  
 FIXTURES: No. \_\_\_\_\_ Light Switches \_\_\_\_\_ Fluor. or Strip Lighting (No. feet) \_\_\_\_\_  
 SERVICE: Pipe \_\_\_\_\_ Cable \_\_\_\_\_ Underground \_\_\_\_\_ No. of Wires \_\_\_\_\_ Size \_\_\_\_\_  
 METERS: Relocated \_\_\_\_\_ Added \_\_\_\_\_ Total No. Meters \_\_\_\_\_  
 MOTORS: Number \_\_\_\_\_ Phase \_\_\_\_\_ H. P. \_\_\_\_\_ Amps \_\_\_\_\_ Volts \_\_\_\_\_ Starter \_\_\_\_\_  
 HEATING UNITS: Domestic (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ H.P. \_\_\_\_\_  
 Commercial (Oil) \_\_\_\_\_ No. Motors \_\_\_\_\_ Phase \_\_\_\_\_ H.P. \_\_\_\_\_  
 Electric Heat (No. of Rooms) \_\_\_\_\_  
 APPLIANCES: No. Ranges \_\_\_\_\_ Watts \_\_\_\_\_ Brand Feeds (Size and No.) \_\_\_\_\_  
 Elec. Heaters \_\_\_\_\_ Watts \_\_\_\_\_  
 Miscellaneous \_\_\_\_\_ Watts \_\_\_\_\_ Extra Cabinets or Panels \_\_\_\_\_  
 Transformers \_\_\_\_\_ Air Conditioners (No. Units) \_\_\_\_\_ Signs (No. Units) \_\_\_\_\_  
 Will commence 5-31-66 Ready to cover in June 1 1966 Inspection 19  
 Amount of Fee \$ 1.00 Signed Curran Electric (SEE)

DO NOT WRITE BELOW THIS LINE

SERVICE	METER	GROUND
VISITS: 1 <u>5/31/66</u> 2	3	5
7	8	11
	9	12
	10	

REMARKS:

INSPECTED BY T. C. [Signature] (OVER)

CS 203

5/31/66  
ready



CITY OF NORFOLK  
DEPARTMENT OF PUBLIC WORKS  
CITY ENGINEER  
[Illegible text and signatures follow]

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for Single family dwelling house & 2-car garage  
at Lot #101 Catherine St. Date 8/26/30

1. In whose name is the title of the property now recorded? Edith L. Crocker
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Wood stakes
3. Is the outline of the proposed work now staked out upon the ground? yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? 12" (Planned by E.L.C. 8/26/30)
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

MP1622

Edith L. Crocker



# APPLICATION FOR PERMIT

Permit No. 1832

Class of Building or Type of Structure Third Class

Portland, Maine, August 26, 1930

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 101 Catherine Street (14-18) Ward 7 Within Fire Limits? no Dist. No. \_\_\_\_\_

Owner's or Lessee's name and address Mrs. Edith L. Crooker 67 Brackett St. Westbrook, Me. #504 Telephone \_\_\_\_\_

Contractor's name and address owner Telephone \_\_\_\_\_

Architect's name and address \_\_\_\_\_

Proposed use of building dwelling house No. families 1

Other buildings on same lot \_\_\_\_\_

Plans filed as part of this application? yes No. of sheets 1

Estimated cost \$ 19,000 Fee \$ 2.50

## Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Last use \_\_\_\_\_ No. families \_\_\_\_\_

## General Description of New Work

To erect one family frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Details of New Work

Size, front 50' depth 25' No. stories 2 Height average grade to top of plate \_\_\_\_\_

To be erected on solid or filled land? solid earth or rock? earth Height average grade to highest point of roof 25'

Material of foundation concrete Thickness, top 12" bottom 14"

Material of underpinning brick Height 2' Thickness 8"

Kind of Roof Pitch Rise per foot 8" Roof covering asphalt shingles Class C Und Lab.

No. of chimneys 1 Material of chimneys brick of lining flue

Kind of heat steam Type of fuel coal Is gas fitting involved? yes

Corner posts 4x6 Sills 4x6 Girders or ledger board? girt Size 2-2x6

Material columns under girders 4" iron pipe Size \_\_\_\_\_ Max. on centers 8'

Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger Bridging in every floor and flat roof

span over 8 feet. Sills and corner posts all one piece in cross section attic unf.

Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd 2x8, roof 2x8

On centers: 1st floor 16", 2nd 16", 3rd 24", roof 24"

Maximum span: 1st floor 14', 2nd 14', 3rd 14', roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_

Total number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner Edith L. Crooker

2844-A



Ward 7 Permit No. 30/1232  
 Location 101 Catherine St.  
 Owner Mrs. Edith L. Crocker  
 Date of permit 8/26/30  
 Notif. closing-in 10/8/30-11:25 P.M.  
 Inspn. closing-in 10/9/30-10 A.M.-9:15  
 Final Notif. 6/8/31-10:10 A.M.  
 Final Inspn. 11/5/31-W.R.R.  
 Cert. of Occupancy issued 1/19/31

NOTES:  
 8/26/30 - Stake out  
 8/30/30 - Excavating  
 9/11/30 - Laying in drain  
 9/15/30 - Walls laid up  
 9/18/30 - First floor  
 9/24/30 - Boarding up  
 10/2/30 - Putting up in  
 side partitions. Another  
 2x8 needed under parti-  
 tion section floor. A.G.B.  
 10/8/30 - No smoke pipe  
 permit. Found gas  
 in cellar - not allowed  
 metal at ceiling and  
 side of metal and

around sal stock and  
 glass. + w/ front story  
 Chime lag from 17.  
 11/5/31 - Attic floor to be  
 made tight at eaves.  
 No more gravel needed  
 around chimney in  
 attic. One piece of  
 flooring to be cut out  
 from chimney. Open-  
 ing around smoke pipe  
 in cellar to be made  
 tight. Heat O.K. - No gas  
 connection yet. A.G.B.  
 6/8/31 - Only attic floor  
 taking care of. Told  
 Mrs. Crocker about  
 other matters. A.G.  
 6/10/31 - Not yet in  
 11/9/31 - Gas tag obtained  
 from Charles Allen  
 A.G.



Permit No.

## APPLICATION FOR PERMIT

Class of Building or Type of Structure Third ClassPortland, Maine, August 26, 1930

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot #101 Catherine Street Ward 7 Within Fire Limits? no Dist. No. 1944Owner's or Lessee's name and address Mrs. Edith L. Crooker 67 Brackett St. Westbrook Telephone 11-504Contractor's name and address owner Telephone \_\_\_\_\_

Architect's name and address \_\_\_\_\_

Proposed use of building 2-car garage No. families \_\_\_\_\_Other buildings on same lot dwelling house (1 family) proposed

## Description of Present Building to be Altered

Material \_\_\_\_\_ No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Last use \_\_\_\_\_ No. families \_\_\_\_\_

## General Description of New Work

To erect 2-car frame garage

## Details of New Work

Size, front 18' depth 20' No. stories 1 Height average grade to top of plate 8'9"  
Height average grade to highest point of roof 15'To be erected on solid or filled land? solid earth or rock? earthMaterial of foundation concrete slab Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of roof pitch 10° to foot Roof covering asphalt shingles Class C Und LabNo. of chimneys no Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_Kind of heat no Type of fuel \_\_\_\_\_ Distance, heater to chimney \_\_\_\_\_

If oil burner, name and model \_\_\_\_\_

Capacity and location of oil tanks \_\_\_\_\_

Is gas fitting involved? \_\_\_\_\_ Size of service \_\_\_\_\_

Corner post: 4x4 Sills 4x4 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_

Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.Joists and rafters. 1st floor concrete 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof 2x6On centers: 1st floor \_\_\_\_\_ 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof 24"

Maximum span: 1st floor \_\_\_\_\_ 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot none to be accommodated 2Total number commercial cars to be accommodated noneWill automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? noPlans filed as part of this application? yes (see 2844-A) No. sheets 1Estimated cost \$ 450 Fee \$ 75Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yesSignature 'owner' Edith L. Crooker

INSPECTION COPY



Ward 7 Permit No. 30/1944  
Lr Lot #101 Catherine St.  
Owner Mrs. Edith L. Crooker  
Date of permit 8/9/30  
Inspn. closing-in  
Final Notif.  
Final Inspn.  
Cert. of Occupancy issued

NOTES

staked out 9/8/30.  
9/8/30. Location as staked O.K.  
9/13/30 - Work at out comp.  
pleted except for wq.  
11/26/35 Completed

FILL IN COMPLETELY AND SIGN WITH INK

Permit No. \_\_\_\_\_



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Oct. 1 1930

To the INSPECTOR OF BUILDINGS, Portland, Me.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 101 Catherine St. Use of Building Dwelling

Name and address of owner Edith L. Crooker 69 Brackett St. Westbrook

Contractor's name and address J. K. Kidder & Co. Telephone P2651

General Description of Work

To install Steam Heat

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? Yes If not, which story ----- Kind of Fuel Solid

Material of supports of heater or equipment (concrete floor or what kind) Concrete Floor

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 3ft

from top of smoke pipe 2ft, from front of heater 4ft from sides or back of heater 4ft

IF OIL BURNER

Name and type of burner

Approved by Underwriters' Laboratories? -----

Location oil storage

No. and capacity of tanks -----

Will all tanks be more than seven feet from any flame?

How many tanks fireproofed? -----

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc. 50 cents additional for each additional heater, etc. in same building at same time)

Signature of contractor

J. K. Kidder & Co.

By J. H. Kidder

3217A



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED  
Permit No. 32174  
City Portland  
Year 1930

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

October 1, 1930

Portland, Maine,

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Lot 101 Catherine Street

Use of Building dwelling house

Name and address of owner Edith L. Crooker, 69 Brackett St. Westbrook Ward 7

Contractor's name and address J. V. Kidder & Co., 355 Maine Ave. Telephone 2651

General Description of Work

steam heating system

To install

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes Kind of Fuel solid  
Material of supports of heater or equipment (concrete floor or what kind) concrete  
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 3'  
from top of smoke pipe 2', from front of heater 4' from sides or back of heater 4'

IF OIL BURNER

Name and type of burner \_\_\_\_\_ Approved by Underwriters' Laboratories? \_\_\_\_\_  
Location oil storage \_\_\_\_\_ No. and capacity of tanks \_\_\_\_\_  
Will all tanks be more than seven feet from any flame? \_\_\_\_\_ How many tanks fireproofed? \_\_\_\_\_  
Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)  
Signature of contractor \_\_\_\_\_


INSPECTION COPY

32174

Ward 7 Permit No. 30/2183  
Det 10 Catherine St  
Owner Edith L Crocker  
Date of permit 10/1/30  
Notif. closing-in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. 1/15/31  
Cert. of Occupancy issued None

NOTES

1/15/31: Installation OK.  
a. j.





FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED  
Permit No. 1346  
SEP 18 1933

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, September 18, 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 12 Catherine Street Use of Building Dwelling

Name and address of owner Mrs. R. A. McClain, 12 Catherine Street Ward \_\_\_\_\_

Contractor's name and address Automatic Oil Heating Co., 454 Fore Telephone 2-6311

General Description of Work

To install oil burner

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story \_\_\_\_\_ Kind of Fuel \_\_\_\_\_

Material of supports of heater or equipment (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, \_\_\_\_\_

from top of smoke pipe \_\_\_\_\_, from front of heater \_\_\_\_\_ from sides or back of heater \_\_\_\_\_

IF OIL BURNER

Name and type of burner Pressure Labeled and approved by Underwriters' Laboratories? yes

Will operator be always in attendance? no Type of oil feed (gravity or pressure) pressure

Location oil storage basement No. and capacity of tanks One 275-gallon

Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? \_\_\_\_\_

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc. 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor Automatic Oil Heating Co.

[Signature]

NOTIFICATION BEFORE  
OR CLOSING IN IS WAITING  
CERTIFICATE OF OCCUPANCY  
REQUIREMENT IS WAITING

PC 9/11/33



# APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure

1975  
NOV 15 1937

Portland, Maine.

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ alter ~~install~~ the following building ~~etc.~~ ~~no equipment in accordance~~ with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 16 Catherine Street Ward 7 Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's or ~~Lessee's~~ name and address Mrs. Carrie A. McOlain, 16 Catherine St. Telephone \_\_\_\_\_  
Contractor's name and address E. F. Ginn, 67 Pitt Street Telephone 2-0701  
Architect \_\_\_\_\_ Plans filed \_\_\_\_\_ No. of sheets \_\_\_\_\_  
Proposed use of building dwelling house No. families 1  
Other buildings on same lot \_\_\_\_\_  
Estimated cost \$ 75. Fee \$ .50

## Description of Present Building to be Altered

Material wood No. stories \_\_\_\_\_ Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use dwelling house No. families 1

## General Description of New Work

To close in rear portion of front entrance porch with glass (8'x 6') at least 20' to street line

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Details of New Work

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Mrs. Carrie McOlain

Signature of owner

By

INSPECTION COPY





## APPLICATION FOR PERMIT

ZONE - A PERMIT 020310

Class of Building or Type of Structure

APR 18 1933

Portland, Maine, April

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect/alter/install the following building structure/equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 16 Catherine Street Within Fire Limits? no Dist. No. \_\_\_\_\_  
Owner's or Lessee's name and address Mrs. Carrie A. McQuinn, 16 Catherine St. Telephone \_\_\_\_\_  
Contractor's name and address P. A. Nashland, 239 Munsey St. So. Portland Telephone 4-31313  
Architect \_\_\_\_\_ Plans filed yes No. of sheets 1  
Proposed use of building dwelling house No. families 1  
Other buildings on same lot garage  
Estimated cost \$ 350. Fee \$ .75  
Description of Present Building to be Altered  
Material wood No. stories 2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use dwelling house No. families 1

## General Description of New Work

To finish of room app. 9' x 14' at one end, third floor, 2x3 studs 16" OC, celotex  
To build one story frame addition 3' x 15' on existing one story sun parlor, removing  
present roof and provide new roof (hipped)

## CERTIFICATE OF OCCUPANCY

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

## Details of New Work

no Height average grade to top of plate yes  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation concrete piers Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of Roof flat (hipped) Rise per foot 3" Roof covering Asphalt roofing Class C Und. Lab.  
No. of chimneys 22 Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
Framing Lumber—Kind hemlock Dressed or Full Size? dressed  
Corner posts 4x6 Sills 4x6 Girt or ledger board? \_\_\_\_\_ Size 1/2" x 8"  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor 2x6 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof 2x6  
On centers: 1st floor 16" 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof 16"  
Maximum span: 1st floor 3' 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof 12'  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

## If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

## Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Mrs. Carrie A. McQuinn  
P. A. Nashland

1109C

Permit No. 39/403  
 Location 16 Catherine St  
 Owner Mr. Corrie O. McLean  
 Date of permit 4/18/39  
 Notif. closing-in 4/21/39 5/11/39  
 Insp 7-in 5/11/39 37  
 Final Notif.  
 Final Inspn. 5/17/39  
 Cert. of Occupancy issued None

NOTES

4/18/39 - Attic was floored  
 over at time like was  
 built. Plombers  
 ran 2x6 - 3 ft. There is  
 very little headroom  
 in the attic. The ceiling  
 barely 7' at the ridge.  
 The room as proposed  
 will be only 9' wide,  
 thus making only 4 1/2'  
 on either side of convey-  
 ing partition that will  
 be used in room. There  
 is also a closet partition  
 running parallel to  
 bedroom partition under  
 this area. I think that  
 conditions are probably

O.K. without added  
 plombers.  
 The new roof will  
 be rather flat. I should  
 say less than 3 in the  
 foot. The common  
 rafters will be on average  
 a 16' span so 2x6 should  
 be O.K. However I think  
 2x8 hip should be  
 used.

4/24/39 - No work done in  
 porch - fine  
 5/2/39 - Work started  
 on porch - fine  
 5/6/39 - Framing roof -  
 O.K.