

20-22 CATHERINE STREET



SHAY'S WALKER

Full cut # 920R - Half cut # 2921 - Third cut # 9203R - Fifth cut # 9210R

6290

CITY OF PORTLAND, MAINE Application for Permit to Install Wires

Permit No. 1003
Issued
Portland, Maine 3 Nov , 1922

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out — Minimum Fee, \$1.00)

Owner's Name and Address *Stephen Ferris* Tel.

Contractor's Name and Address *Philip Welch* Tel.

Location *Scrub 20 Catherine St* Use of Building *Home*

Number of Families *1* Apartments Stores Number of Stories

Description of Wiring: New Work Additions Alterations
up Scrub from 70-100 Amp Add Range and 2 wire outlets

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)

No. Light Outlets Plugs Light Circuits Plug Circuits

FIXTURES: No. Fluor. or Strip Lighting (No. feet)

SERVICE: Pipe Cable Underground No. of Wires Size

METERS: Relocated Added Total No. Meters

MOTORS: Number Phase H. P. Amps Volts Starter

HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
Commercial (Oil) No. Motors Phase H.P.
Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges *1* Watts Brand Feeds (Size and No.)
 Elec. Heaters *2* Watts
Miscellaneous Watts Extra Cabinets or Panels

Transformers Air Conditioners (No. Units) Signs (No. Units)

Will commence *4 Nov 1922* Ready to cover in *will* 19 Inspection 19

Amount of Fee \$ *5.00* Signed *Philip Welch*

DO NOT WRITE BELOW THIS LINE

| SERVICE | METER | | | GROUND | | |
|-----------|-------|---|----|--------|----|--|
| VISITS: 1 | 2 | 3 | 4 | 5 | 6 | |
| 7 | 8 | 9 | 10 | 11 | 12 | |

REMARKS:

INSPECTED BY *Frank A. ...* (OVER)



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
1888

Permit No. 2 1892

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Oct. 31, 1932

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location lot 101 Catherine St., City Use of Building residence
Name and address of owner Mrs. Edith L. Crooker Ward 7
472 Brighton Ave., City
Contractor's name and address Ballard Oil & Equip. Co. of Me. Telephone: E-622

General Description of Work

To install Oil Burning Equipment

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel _____
Material of supports of heater or equipment (concrete floor or what kind) concrete
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____
from top of smoke pipe _____, from front of heater _____ from sides or back of heater _____

IF OIL BURNER

Name and type of burner Baby Grand Burner Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? no Type of oil feed (gravity or pressure) pressure
Location oil storage basement No. and capacity of tanks 1-275 gal. tank
Will all tanks be more than seven feet from any flame? 7 How many tanks fireproofed? none

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor Ballard Oil & Equip. Co. of Me.
by R.A. Stanton 8/15/32

NOTIFICATION BEFORE LEAVING
OR OCCUPANCY IS WAIVED.
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.
P.C. 2/11/32

Ward 7 Permit No. 32/1888
 Location Art 101 Catherine St.
 Owner Edith L. Corker
 Date of permit 7/1/32.
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. 11/16/32 - O.T.
 Cert. of Occupancy issued None

Heat O.K.
 Holes in firestop for electric
 wires west side. Hole cut
 over girder for electric
 wire. Holes in firestop
 east side. Do not to
 be connected.

- NOTES
1. Kind of heat: Steam
 2. Label:
 3. Anti-siphon:
 4. Oil storage:
 5. Tank distance:
 6. Vent pipe:
 7. Fill pipe:
 8. Gauge:
 9. Rigidity:
 10. Fuel safety:
 11. Pipe sizes & material:
 12. Control valve:
 13. Ash pit vent:
 14. Temp. or pressure safety:
 15. Instruction card:
 16. _____

THE CITY OF NEW YORK
 DEPARTMENT OF HEALTH
 BUREAU OF BUILDINGS
 OFFICE OF THE SUPERVISOR OF BUILDINGS
 120 NASSAU ST. N.Y.C. 10038
 TELEPHONE 674-2100
 1932



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

Permit No.

1750

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, Oct. 14 1939

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location: 1st 104 Catherine St. (20-22) Use of Building Dwelling

Name and address of owner F. I. Crooker Ward 7

Contractor's name and address J. V. Kidder & Co. 55 Maine Ave Telephone 1-1111

General Description of Work:

To install Steam heating plant

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? Yes If not, which story ----- Kind of solid

Material of supports of heater or equipment (concrete floor or what kind) Concrete floor

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 2ft.

from top of smoke pipe 2ft., from front of heater 4ft. from sides or back of heater 4ft.

IF OIL BURNER

Name and type of burner ----- Approved by Underwriters' Laboratories? -----

Location oil storage ----- No. and capacity of tanks -----

Will all tanks be more than seven feet from any flame? ----- How many tanks fireproofed? -----

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor J. V. Kidder & Co

INSPECTION COPY

by J. W. Adams

NOTIFICATION BEFORE PLACING
OR CLOSING-IN IS WAIVED


CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

824

Ward 7 Permit No. 32/1750
Location: Lot 10 Catherine St
Owner E. L. Crocker
Date of permit 10/14/32
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 11/16/32 - O.T.
Cert. of Occupancy issued None

NOTES

11/16/32 - Installation
O.R. - A.J.S.



STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for 2-car garage

at Lot 101 Catherine Street

Date 10/24/32

1. In whose name is the title of the property now recorded? Edith L. Crooker
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? Stake
3. Is the outline of the proposed work now staked out upon the ground? Yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced? Yes
4. What is to be maximum projection or overhang of eaves or drip? 15"
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches and other projections? Yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? Yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? Yes

Edith L. Crooker



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, October 14, 1932

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 121 Catherine Street (20-22) Ward 7 Within Fire Limits? no Dist. No. _____

Owner's or Lessee's name and address Mrs. Edith L. Crocker 472 Erington Ave. Telephone P 4234

Contractor's name and address Owner Telephone _____

Architect's name and address _____

Proposed use of building 2-car garage No. families _____

Other buildings on same lot one family dwelling house

Plans filed as part of this application? yes No. of sheets 1

Estimated cost \$ 350.00 Fee \$.75
50¢ pd. Rec. 7751

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

To erect 2-car frame garage 18' x 20'

NOTIFICATION BEFORE LAYING
OR CLOSING-IN IS WAIVED.

It is understood that this permit does not include installation of heating apparatus which is to be taken out of the name of the heating contractor.

CERTIFICATE OF OCCUPANCY
REQUIREMENTS AS AND IN THE NAME OF

Details of New Work

Size, front 18' depth 20' No. stories 1 Height average grade to top of plate 8'
Height average grade to highest point of roof 14' x 14'

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation concrete slab Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof hip Rise per foot 7 1/2" Roof covering Lg. bolt shingles Class C Und. Lab.

No. of chimneys no Material of chimneys _____ of lining _____

Kind of heat no Type of fuel _____ Is gas fitting involved? _____

Corner posts 4x4 Sills 2x4 Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor concrete, 2nd _____, 3rd _____, roof 2x4

On centers: 1st floor _____, 2nd _____, 3rd _____, roof 24"

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls _____ height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 2

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Edith L. Crocker

INSPECTION COPY

Walter T. Sanborn


CHIEF OF FIRE DEPT.


Ward 7 Permit No. 32/1836
Location Lot 101 Catherine St.
Owner Edith L. Cypher
Date of permit 10/25/32
Notif. closing-in _____
I sing-in _____
Final Notif. _____
Final Inspn. 11/1/32
Cert. of Occupancy issued None

NOTES

10/24/32 - Location is O.K.
Garage is nearly com-
pleted - A. J. S.

See card in violation
file with regard to
this garage. HJC







APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, July 1, 1932
Supersedes application of 7/1/32

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter-install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 107 Catherine Street (No 22) Ward 7 Within Fire Limits? no Dist. No. _____
 Owner's or Lessee's name and address Edith L. Crooker, 472 Brighton Ave. Telephone P 4254
 Contractor's name and address Owner (D. W. Kincaid, Foreman) Telephone _____
 Architect's name and address _____
 Proposed use of building dwelling house No. families 1
 Other buildings on same lot none (garage later)
 Plans filed as part of this application? yes No. of sheets 1
 Estimated cost \$ 7500. Fee \$2.75

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Last use _____ No. families _____

General Description of New Work

To erect one family frame dwelling house

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
 Size, front 38' depth 27'6" No. stories 2 1/2 Height average grade to highest point of roof 27'
 To be erected on solid or filled land? solid earth or rock? earth
 Material of foundation concrete Thickness, top 12" bottom 14"
 Material of underpinning brick Height 18" Thickness 8"
 Kind of Roof hip Rise per foot 7" Roof covering Asphalt shingles Class C Und. Lab.
 No. of chimneys one Material of chimneys brick of lining tile
 Kind of heat steam Type of fuel coal Is gas fitting involved? yes
 Corner posts 4x8 Sills 4x8 Girt or ledger board? girt Size 4x4
 Material columns under girders iron columns Size 4" Max. on centers 9'
 Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor 2x8, 2nd 2x8, 3rd 2x6 unfr, roof 2x6
 On centers: 1st floor 16", 2nd 16", 3rd 20", roof 20"
 Maximum span: 1st floor 15', 2nd 18', 3rd 15', roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
 Total number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Edith L. Crooker

INSPECTION COPY

77519

Ward _____ Permit No _____
 Location _____
 Owner _____
 Date of permit _____
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif _____
 Final Inspn. _____
 Cert. of Occupancy issued _____

NOTES

7/25/32 - Location O.K.
 A.G.B.

1932
 1933
 1934
 1935
 1936
 1937
 1938
 1939
 1940
 1941
 1942
 1943
 1944
 1945
 1946
 1947
 1948
 1949
 1950
 1951
 1952
 1953
 1954
 1955
 1956
 1957
 1958
 1959
 1960
 1961
 1962
 1963
 1964
 1965
 1966
 1967
 1968
 1969
 1970
 1971
 1972
 1973
 1974
 1975
 1976
 1977
 1978
 1979
 1980
 1981
 1982
 1983
 1984
 1985
 1986
 1987
 1988
 1989
 1990
 1991
 1992
 1993
 1994
 1995
 1996
 1997
 1998
 1999
 2000
 2001
 2002
 2003
 2004
 2005
 2006
 2007
 2008
 2009
 2010
 2011
 2012
 2013
 2014
 2015
 2016
 2017
 2018
 2019
 2020
 2021
 2022
 2023
 2024
 2025
 2026
 2027
 2028
 2029
 2030
 2031
 2032
 2033
 2034
 2035
 2036
 2037
 2038
 2039
 2040
 2041
 2042
 2043
 2044
 2045
 2046
 2047
 2048
 2049
 2050

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT
for one family dwelling house with one car garage attached
at Lot 101 Catherine Street Date 7/1/32

1. In whose name in the title of the property now recorded? E. L. Crocker
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? by stakes
3. Is the outline of the proposed work now staked out upon the ground? yes If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? 12'
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches, and other projections? yes
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? yes
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? yes

Steve Kunk



Permit No. 10248

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, July 1, 1935

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter-install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Lot 101 Catherine Street Ward 7 Within Fire Limits? no Dist. No. _____

Owner's or-Lessee's name and address E. L. Crocker, 472 Brighton Avenue Telephone P 4254

Contractor's name and address Owner (D. E. Kincaid, Foreman) Telephone _____

Architect's name and address _____

Proposed use of building dwelling house with one car garage attached No. families 1

Other buildings on same lot _____

Plans filed as part of this application? yes No. of sheets 1

Estimated cost \$ 8950. Gen 25 Fee \$ 2.50 Garage .50 \$5.85

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

To erect one family frame dwelling house with one car garage attached (roof over garage) dormer on either of roof over side addition)

The inside of the garage will be covered, where required by law, with metal lath and cement plaster

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front 30' depth 30' No. stories 2 1/2 Height average grade to top of plate _____
Height average grade to highest point of roof 27'

To be erected on solid or filled land? solid earth or rock? earth

Material of foundation concrete Thickness, top 3 1/2" bottom 14"

Material of underpinning brick Height 2' Thickness 8"

Kind of Roof pitch Rise per foot 6" Roof covering asphalt roofing Class C Und. Lab.

No. of chimneys 1 (all outside - corbelled thru) Material of chimneys brick of lining tile

Kind of heat steam Type of fuel coal Is gas fitting involved? yes

Corner posts 4x6 Sills 4x6 Girt or ledger board? girt Size 4x6

Material columns under girders iron column Size 4" Max. on centers 6'

Studs (outside walls and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2x8 concrete floor in garage 2nd 2x8 3rd 2x8 unfl. roof 2x8

On centers: 1st floor 16" 2nd 16" 3rd 20" roof 20"

Maxim. span: 1st floor 12' 2nd 14' 3rd 18' roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 1

Total number commercial cars to be accommodated none

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner E. L. Crocker

INSPECTION COPY

Ward 7 Permit No. 32/1048
 Location Lot 101 Catharine St
 Owner S. Crocker
 Date of permit 7/25/32
 Not f. closing-in 9/13/32 - 1145311
 Inspn. closing-in 11/13/32 - GT
 Final Notif. None given
 Final Inspn. 5/5/33
 Cert. of Occupancy issued 5/5/33

NOTES:
~~8/5/32 - strappings
 found in ground
 wall. A.G.E.
 8/13/32 - underpinning
 on S. side
 8/19/32 - at S. frame
 A.G.E.
 8/28/32 - strapping
 roof - A.G.E.
 8/27/32 - A.G.E.
 9/13/32 - A.G.E.
 12/12/32 - A.G.E.
 10/13/32 - A.G.E.
 No permit~~

11/16/32 - Orig. not inspec-
 tion found following
 matter to be taken care
 of -
 In west wall of basement
 holes in firestop for electric
 light wires should be
 made tight, hole over
 girder made by electrician
 should be made tight,
 holes in firestop on
 side should be made
 tight. Gas is not to
 be used for display
 at this time, altho
 house is to be furnished
 and used for display.
 A.G.E.
 2/6/33 House being
 used for display
 4/25/33 Picked up gas
 tag. Hole over girder
 not stopped up - A.G.E.
 5/5/33 - Mrs Crocker found
 she will take care of
 hole over girder A.G.E.