FILL IN AND SIGN WITH INK

00374

PERMIT ISSUED
APR 8 1986
City Of Portland

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, April 4, 1986

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Peaks Island Island Ave. 84-AA-3 Use of Building Sing. FAm. No. Stories New Building Existing X

Name and address of owner of appliance James Brown Island Ave. 84-AA-3

Installer's name and address Terrence Mulkern Island Ave. Telephone 766-2508

General Description of Work

To install Replace Forced Hot water Heating System

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? No

If so, how protected? Kind of fuel? No 2 Fuel Oil

Minimum distance to burnable material, from top of appliance or casing top of furnace 18"

From top of smoke pipe 18" From front of appliance n/a From sides or back of appliance n/a

Size of chimney flue 7" Other connections to same flue None

If gas fired, how vented? Rated maximum demand per hour 137,000BTU

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes

IF OIL BURNER

Name and type of burner Carlin - Burnham Labelled by underwriters' laboratories? Yes

Will operator be always in attendance? n/a Does oil supply line feed from top or bottom of tank? bottom

Type of floor beneath burner concre Size of vent pipe 1 1/4"

Location of oil storage basement Number and capacity of tanks 1 275 gal.

Low water shut off Yes Make No.

Will all tanks be more than five feet from any flame? Yes How many tanks enclosed?

Total capacity of any existing storage tanks for furnace burners 275 gal

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?

If so, how protected? Height of Legs, if any

Skirting at bottom of appliance? Distance to combustible material from top of appliance?

From front of appliance From sides and back From top of smokepipe

Size of chimney flue Other connections to same flue

Is hood to be provided? If so, how vented? Forced or gravity?

If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount enclosed? 25.00 Est. Cost: $ 2[illegible].00

#02435 MASTER NC

APPROVED

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of Installer

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

Permit No. 86/374 [illegible]

Location 24-A -3 [illegible]

Owner James Brown

Date of permit 4/8/86

Approved

NOTES

4-4-86 @ 19 @ a