

10000 AVE., WINDY ISLAND 64-2-2

CITY OF PORTLAND, MAINE  
DEPARTMENT OF BUILDING INSPECTION

January 3, 1968

Mrs. Leslie MacVane  
Brackett Ave.  
Peaks Island Me. (contractor-owner)

Dear Madam:

(2-story frame storage bldg.)

With relation to permit applied for to demolish a building or portion of building at Island Ave. Peaks Island it is unlawful to commence demolition work until a permit has been issued from this department.

Section 6 of the Ordinance for rodent and vermin control provides: "It shall be unlawful to demolish any building or structure unless provision is made for rodent and vermin eradication. No permit for the demolition of a building or structure shall be issued by the Building Inspection Department until and unless provisions for rodent and vermin eradication have been carried out under supervision of a pest control operator registered with the Health Department.

The building permit for demolition cannot be issued until the provisions of this section have been satisfied. It is the obligation of owner or demolition contractor or both to take up with the Health Department the matter of complying with this section, being prepared to inform that department what registered pest control operator is to be employed.

Very truly yours,

*Gerald E. Mayberry*


Gerald E. Mayberry  
Director of Building & Inspection

h

Eradication of this building has been completed.

5 January 1968

*Paul Mathieu*  
Paul Mathieu, HD





# APPLICATION FOR PERMIT

Third Class

Class of Building or Type of Structure \_\_\_\_\_  
Portland, Maine, January 3, 1968

PERMIT ISSUED  
JAN 5 1968  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Island Ave. Peaks Island (Lot 237) B4 P-2 Within Fire Limits? \_\_\_\_\_ Dist. No. \_\_\_\_\_

Owner's name and address Mrs. Leslie MacVane, 1 Rackett Ave. Peaks Island Telephone \_\_\_\_\_

Lessee's name and address \_\_\_\_\_ Telephone \_\_\_\_\_

Contractor's name and address \_\_\_\_\_ Specifications \_\_\_\_\_ Plans no No. of sheets \_\_\_\_\_

Architect \_\_\_\_\_ No. families \_\_\_\_\_

Proposed use of building Store & Storage bldg. for Contractor's Equip. No. families \_\_\_\_\_

Last use \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Material frame No. stories 2 Heat \_\_\_\_\_

Other buildings on same lot \_\_\_\_\_ Fee \$ 5.00

Estimated cost \$ \_\_\_\_\_

### General Description of New Work

To demolish existing 2-story frame storage building.

Do you agree to tightly and permanently close all sewers or public drains connecting with public or private sewers from this building or structure to be demolished, under the supervision and to the approval of the Dept. of Public Works of the City of Portland? Yes.

Land to remain vacant for the present.

Sent to Health Dept. 1/3/68  
Rec'd. from Health Dept. 1/5/68

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

### Details of New Work

Is any plumbing involved in this work? \_\_\_\_\_ Is any electrical work involved in this work? \_\_\_\_\_

Is connection to be made to public sewer? \_\_\_\_\_ If not, what is proposed for sewage? \_\_\_\_\_

Has septic tank notice been sent? \_\_\_\_\_ Form notice sent? \_\_\_\_\_

Height average grade to top of plate \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_

Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_

Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ Kind of heat \_\_\_\_\_ fuel \_\_\_\_\_

No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_ Corner posts \_\_\_\_\_ Sills \_\_\_\_\_

Framing Lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Size Girder \_\_\_\_\_ Columns under girders \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_ to be accommodated \_\_\_\_\_ number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

APPROVED:

Y. E. M.

Mrs. Leslie MacVane

Signature of owner by: Mrs. Leslie MacVane  
By Lois P. Wilson

CS 301

INSPECTION COPY

NOTES

3-28-68 Phoned in  
all down *(initials)*

*X*

Permit No. *68/8*

Location *Westview Park St*

Owner *Mr. & Mrs. MacNamee*

Date of permit *1/5/68*

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

Staking Out Notice

Form Check Notice



CITY OF PORTLAND, MAINE  
 DEPARTMENT OF BUILDING INSPECTION  
**COMPLAINT**

Location:  
Island Ave., Peaks Isl.  
64-P-2


INSPECTION COPY

COMPLAINT NO. 64/16 Date Received March 5, 1964

Assessors 64-P-2  
 Location Island Ave., Peaks Island Use of Building \_\_\_\_\_  
 Owner's name and address Irene S. MacVane, Brackett Ave., Peaks Island Telephone \_\_\_\_\_  
 Tenant's name and address \_\_\_\_\_ Telephone \_\_\_\_\_  
 Complainant's name and address \_\_\_\_\_ Telephone \_\_\_\_\_

Description: A pane of glass is loose in second story window facing over the sidewalk.

NOTES: Reported complaint to Mrs. MacVane who said she would take care of it. GEN



December 9, 1957

AP - Island Ave., Peaks Island - Assessors' Lot Nos. 84-P-2

Mrs. Irene MacVane  
Island Avenue  
Peaks Island, Maine

Dear Mrs. MacVane:

Before a permit can be issued for demolishing porch on rear of building at the above named location and for closing up two doorways in rear wall, (one door in each story), it is necessary that information be furnished as to whether or not the door in first story must be counted as an emergency means of egress from the store area in first story. If it does, we are unable to issue a permit for closing up this doorway.

Will you please let us know what the situation is so that decision can be made as to application of the Building Code?

Very truly yours,

Albert J. Sears  
Deputy Inspector of Buildings

AJS:M



# APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class  
Portland, Maine, Dec. 4, 1957

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~repair~~ ~~demolish~~ ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Island Ave. Peaks Island Maine (84-122) Within Five Limits? no Dist. No. ....

Owner's name and address Mrs. Irene MacVane, Island Ave. Peaks Island Me. Telephone .....

Lessee's name and address ..... Telephone .....

Contractor's name and address owner Telephone .....

Architect ..... Specifications ..... Plans ..... No. of sheets .....

Proposed use of building ..... No. families .....

Last use 2-story frame porch No. families .....

Material ..... No. stories ..... Heat ..... Style of roof ..... Roofing .....

Other building on same lot ..... Fee: \$ ~~100.00~~ .....

Estimated cost \$ 50.00 ..... 121x60 ..... 50 .....

### General Description of New Work

To demolish 2-story frame porch (1st floor enclosed, second floor open) located on side facing the water; closing up (2) doors on first and second floor (one on each floor)

*11/6/59 - no further information received re permit not issued - ag*

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately, by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** owner

### Details of New Work

Is any plumbing involved in this work? ..... Is any electrical work involved in this work? .....

Is connection to be made to public sewer? ..... If not, what is proposed for sewage? .....

Has septic tank notice been sent? ..... Form notice sent? .....

Height average grade to top of plate ..... Height average grade to highest point of roof .....

Size, front ..... depth ..... No. stories ..... solid or filled land? ..... earth or rock? .....

Material of foundation ..... Thickness, top ..... bottom ..... cellar .....

Material of underpinning ..... Height ..... Thickness .....

Kind of roof ..... Rise per foot ..... Roof covering ..... Kind of heat ..... fuel .....

No. of chimneys ..... Material of chimneys ..... of lining ..... Kind of heat ..... fuel .....

Framing Lumber—Kind ..... Dressed or full size? ..... Corner posts ..... Sills .....

Size Girder ..... Columns under girders ..... Size ..... Max. on centers .....

Kind and thickness of outside sheathing of exterior walls? .....

Studs (outside walls and carrying partitions) 2x4-16" C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor ..... 2nd ..... 3rd ..... roof .....

On centers: 1st floor ..... 2nd ..... 3rd ..... roof .....

Maximum span: 1st floor ..... 2nd ..... 3rd ..... roof ..... height? .....

If one story building with masonry walls, thickness of walls? .....

### If a Garage

No. cars now accommodated on same lot, to be accommodated ..... number commercial cars to be accommodated .....

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? .....

### Miscellaneous

Will work require disturbing of any tree on a public street? no .....

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes .....

Mrs. Irene MacVane.

APPROVED: .....

by: *Irene MacVane*

Signature of owner

INSPECTION COPY

F.M.

Permit No. 571  
Location Island of the Pecks Is. m.  
Owner Mrs. Irene MacVane  
Date of permit 12/1/57  
Notif. closing-in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. \_\_\_\_\_  
Cert. of Occupancy issued \_\_\_\_\_  
Staling Out Notice \_\_\_\_\_  
Form Check Notice \_\_\_\_\_

NOTES







AP Island Avenue, Peaks Island  
(A no. 84-P-2)

December 3, 1949

Captain Leslie MacVane  
Peaks Island, Maine  
Mr. George Keening  
Peaks Island, Maine

Subject: Building permit for moving building from  
Central Avenue to Island Avenue, Peaks Island  
(A no. 84-P-2) and construction of outside chimney,  
the building to be used for shed or storehouse for  
fishermen's gear

Gentlemen:

Captain MacVane has applied for this belated permit to move the building from  
Central Avenue, so we incorporated that operation in the same application as Mr.  
Keening's for construction of the outside chimney.

The permit for moving and construction of the chimney is issued to Captain  
MacVane at his direction, but subject to the following:

Without prior inspection it is understood from the owner that the building  
is in sound and stout condition, but that the foundations or supports of the build-  
ing rest upon the top of the ground. The foundations of the outside chimney must,  
of course be carried to a depth no less than 4' below the surface of the ground or  
to ledge if ledge is encountered at a less depth. Thus the chimney should not be  
subject to frost action, but the building is likely to. Under these circumstances  
care will have to be exercised where the brickwork of the chimney is corbelled  
through the outside wall, as required by law, to leave "play" enough so that should  
the building move or heave with the frost the chimney will not likely be damaged.

Under the Zoning Law the permit to locate the building on the property is  
issued because the stated use that of a storehouse for fishermen's gear is an allow-  
able use in the zone where the property is located if the shed is within 200' of  
mean high water, which, I understand from Captain MacVane, this shed is. Also the  
permit is issued based on the information that the shed is at least 10' from the  
side property line which is the least distance that a building of such use can be  
placed from the side property line under the Zoning Ordinance.

Very truly yours,

Warren McDonald  
Inspector of Buildings

WMD/G

1.71 x 1.38 x 2.75  
SURFACE



at 40'

RECEIVED  
DEC 2 1949  
DEPT. OF BLD'G. INSP.  
CITY OF PORTLAND



# APPLICATION FOR PERMIT

PERMIT ISSUED  
Permit No. 10712

Class of Building or Type of Structure Third Class

Portland, Maine, July 26, 1944

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Rear Island Avenue Within Fire Limits? no Dist. No. \_\_\_\_\_  
 Owner's or Lessee's name and address T. M. Johnstone Estate Telephone \_\_\_\_\_  
 Contractor's name and address W. R. Springer, Sterling St. Praxs Telephone 228  
 Architect \_\_\_\_\_ Plans filed \_\_\_\_\_ No. of sheets \_\_\_\_\_  
 Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
 Other buildings on same lot \_\_\_\_\_  
 Estimated cost \$ \_\_\_\_\_ Fee \$ .50

### Description of Present Building to be Altered

Material wood No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
 Last use Fish market No. families \_\_\_\_\_

### General Description of New Work

To demolish building app. 25' x 25' no sewer connection

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

### Details of New Work

Is any plumbing work involved in this work? \_\_\_\_\_  
 Is any electrical work involved in this work? \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_  
 Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_  
 To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
 Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
 Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
 Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_  
 No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_  
 Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
 Framing: lumber—Kind \_\_\_\_\_ Dressed or full size? \_\_\_\_\_  
 Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_  
 Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_  
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 3x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.  
 Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_  
 If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_ to be accommodated \_\_\_\_\_  
 Total number commercial cars to be accommodated \_\_\_\_\_  
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no  
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES  
 Signature of owner T. M. Johnstone Estate  
W. R. Springer

Permit No. 44/1734

Location Off. Bldg. 100 Parks

Owner T. G. Johnson Est.

Date of permit 8/26/44

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 3/29/45 C O G

Cert. of Occupancy issued None

NOTES

~~WORKER FOR INDUSTRY  
INDUSTRY FOR WORKER~~

Director of Public Works  
City of Chicago  
100 North Dearborn Street  
Chicago, Illinois



(B) LIMITED BUSINESS ZONE

# APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure 2nd Class

Permit No. 1150  
NOV 5 1913

Portland, Maine, November 2, 1913

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter ~~in~~ the following building ~~structure~~ equipment in accordance with the Laws of the State of Me., the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Island Avenue, Peaks Island Within Fire Limits? no Dist. No. \_\_\_\_\_

Owner's or Lessee's name and address T. A. Johnstone Heirs Telephone \_\_\_\_\_

Contractor's name and address Nabel Bredbury, Sanford, Meina Telephone 157-2

Architect \_\_\_\_\_ Plans filed yes No. of sheets 1

Proposed use of building Stores and tenements No. families \_\_\_\_\_

Other buildings on same lot \_\_\_\_\_

Estimated cost \$ 700. Fee \$ 2.00

### Description of Present Building to be Altered

Material wood No. stories 2 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Last use Stores and tenements No. families \_\_\_\_\_

### General Description of New Work

To rebuild existing two story (n; roof) rear piazza on building as per plan

The corner posts and intermediate posts are to be no less than 4x6 nominal dimensions, or equivalent, and these posts are each to be made one continuous length or to be spliced at the floor levels. All splices are to be lapped splices at least eight inches long and in no case will a post be set on top of the floor below it. Where the piazza is fastened to the building the weather boarding will be removed and the timbers of the piazza fastened directly to the frame of the building

*O.K. 11/5/13, 000.*

INSPECTION BEFORE LAID

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately and paid for the amount of the heating contractor.

### Details of New Work

CERTIFICATE OF COMPLIANCE  
REQUIREMENTS MET

Is any plumbing work involved in this work? \_\_\_\_\_

Is any electrical work involved in this work? \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to highest point of roof \_\_\_\_\_

To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_

Material of foundation existing concrete piers thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of roof no Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_

No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_

Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_

Framing lumber—Kind spruce Dressed or full size? full size

Corner posts \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_

Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 2 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

On centers: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

Maximum span: 1st floor \_\_\_\_\_, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

### If a Garage

No. cars now accommodated on same lot \_\_\_\_\_ to be accommodated \_\_\_\_\_

Total number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

### Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes Signature of owner T. A. Johnstone Heirs

INSPECTION COPY

*Henry S. Hoagland*







PERMIT ISSUED

APPLICATION FOR PERMIT

Permit No. 0463  
MAY 28 1913

Class of Building or Type of Structure  
Portland, Maine May 28, 1913

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.  
The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Island Avenue, Peaks Island Within Fire Limits? no Dist. No. \_\_\_\_\_  
Telephone \_\_\_\_\_  
Owner's or Lessee's name and address Mabel Brachury Penford Telephone \_\_\_\_\_  
Contractor's name and address Geo. A. Keating, Willow St. Peaks Telephone \_\_\_\_\_  
Architect \_\_\_\_\_ Plans filed \_\_\_\_\_ No. of sheets \_\_\_\_\_  
Proposed use of building \_\_\_\_\_ No. families \_\_\_\_\_  
Other buildings on same lot \_\_\_\_\_ Fee \$ 50

Estimated cost \$ \_\_\_\_\_ Description of Present Building to be Altered  
Material wood No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_  
Last use \_\_\_\_\_ No. families \_\_\_\_\_

General Description of New Work  
To demolish building 10' x 20'  
fish market

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? \_\_\_\_\_  
Is any electrical work involved in this work? \_\_\_\_\_  
Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_  
To be erected on solid or filled land? \_\_\_\_\_ earth or rock? \_\_\_\_\_  
Material of foundation \_\_\_\_\_ Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_ cellar \_\_\_\_\_  
Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_  
Kind of roof \_\_\_\_\_ Rise per foot \_\_\_\_\_ Roof covering \_\_\_\_\_ of riving \_\_\_\_\_  
No. of chimneys \_\_\_\_\_ Material of chimneys \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_  
Kind of heat \_\_\_\_\_ Dressed or full size? \_\_\_\_\_ Size \_\_\_\_\_  
Framing, lumber - Kind \_\_\_\_\_ Sills \_\_\_\_\_ Girt or ledger board? \_\_\_\_\_ Max. on centers \_\_\_\_\_  
Material columns under girders \_\_\_\_\_ Size \_\_\_\_\_ Bridging in every floor and flat roof \_\_\_\_\_  
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. \_\_\_\_\_  
span over 8 feet. Sills and corner posts all one piece in cross section.  
Joists and rafters: 1st floor \_\_\_\_\_ 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof \_\_\_\_\_  
On centers: 1st floor \_\_\_\_\_ 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ roof \_\_\_\_\_  
Maximum span: 1st floor \_\_\_\_\_ 2nd \_\_\_\_\_ 3rd \_\_\_\_\_ height? \_\_\_\_\_  
If one story building with masonry walls, thickness of walls? \_\_\_\_\_  
If a Garage \_\_\_\_\_ to be accommodated \_\_\_\_\_

No. cars now accommodated on same lot \_\_\_\_\_  
Total number commercial cars to be accommodated \_\_\_\_\_  
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? \_\_\_\_\_

Miscellaneous  
Will any work require removal or disturbing of any shade tree on a public street? no  
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes  
Signature of owner Mabel Brachury  
Geo. A. Keating

INSPECTION COPY

35122

