



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 6, 1987

PERMIT ISSUED

AUG 11 1987

City of Portland

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location New Island Ave. Peaks Island Use of Building single family No. Stories 2  New Building  Existing

Name and address of owner of appliance Warren Melors same

Installer's name and address Coleman Milkern Island Avenue, P.I. 04108 Telephone 766-2508

### General Description of Work

To install boiler replacement

### IF HEATER, OR POWER BOILER

Location of appliance basement  Any burnable material in floor surface or beneath?  no

If so, how protected?  Kind of fuel? No. 2

Minimum distance to burnable material, from top of appliance or casing top of furnace 36"

From top of smoke pipe 24" From front of appliance 8" From sides or back of appliance 8"

Size of chimney flue 7" Other connections to same flue  no

If gas fired, how vented?  Rated maximum demand per hour 0

Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?  yes

### BURNER

Name and type of burner Burnham E16  Labelled by underwriters' laboratories?  Yes  No

Will operator be always in attendance?  Does oil supply line feed from top or bottom of tank? bottom

Type of floor beneath burner concrete Size of vent pipe 1 1/2"

Location of oil storage basement Number and capacity of tanks 1, 275 gals

Low water shut off  Make McDonald Miller No. 101

Will all tanks be more than five feet from any flame?  yes How many tanks enclosed? 0

Total capacity of any existing storage tanks for furnace burners 0

### IF COOKING APPLIANCE

Location of appliance  Any burnable material in floor surface or beneath?  Height of Legs, if any

If so, how protected?  Distance to combustible material from top of appliance?

Skirting at bottom of appliance?  From sides and back  From top of smokepipe

From front of appliance  Other connections to same flue

Size of chimney flue  Is so, how vented?  Forced or gravity?

Is hood to be provided?  Rated maximum demand per hour

If gas fired, how vented?

### MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? \$15.00

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?  yes

INSPECTION FILE

ASSASSINATOR'S COPY

Signature of Installer

*Coleman Milkern*

*W. M. Addis*

lic # 02634