


VETERAN STREET PEAKS ISLAND  
85-E-1

1952  
MAY 10 1952





APARTMENT HOUSE ZONE  
APPLICATION FOR PERMIT

PERMIT ISSUED

SEP 7 1933

Class of Building or Type of Structure Third Class

Portland, Maine, September 7, 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Cor. Veterans & Meridian Sts. Peaks Ward 121.2 Within Fire Limit? NO Dist. No. \_\_\_\_\_

Owner's or lessor's name and address J. A. Riley, Central Ave. Peaks Telephone 296-2

Contractor's name and address Owner Telephone \_\_\_\_\_

Architect's name and address \_\_\_\_\_ No families \_\_\_\_\_

Proposed use of building Cottage

Other buildings on same lot \_\_\_\_\_ No. of sheets 1

Plans filed as part of this application? YES Fee \$ 2.00

Estimated cost \$ 50.

Description of Present Building to be Altered

Material wood No. stories 1 Heat \_\_\_\_\_ Style of roof \_\_\_\_\_ Roofing \_\_\_\_\_

Last use \_\_\_\_\_ Cottage No. families \_\_\_\_\_

General Description of New Work

To erect one story open piazza on front of cottage 6' x 20'

NOTIFICATION BEFORE LATHING OR CLOSING IN IS WAIVED.  
CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front \_\_\_\_\_ depth \_\_\_\_\_ No. stories \_\_\_\_\_ Height average grade to top of plate \_\_\_\_\_

To be erected on solid or fill land? solid earth or rock? ledge

Material of foundation stones Thickness, top \_\_\_\_\_ bottom \_\_\_\_\_

Material of underpinning \_\_\_\_\_ Height \_\_\_\_\_ Thickness \_\_\_\_\_

Kind of Roof pitch (roof of cottage to be carried out over new piazza - gable end) Rise per foot 3/4 Roof covering as built - roofing Class C Ord. 1-3

No. of chimneys no Material of chimneys \_\_\_\_\_ of lining \_\_\_\_\_

Kind of heat \_\_\_\_\_ Type of fuel \_\_\_\_\_ Is gas fitting involved? \_\_\_\_\_

Corner posts 4" dia. Sills 4x4 Girt or ledger board? \_\_\_\_\_ Size \_\_\_\_\_ Max. on centers \_\_\_\_\_

Material columns under girders \_\_\_\_\_

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2x4, 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 2x4

On centers: 1st floor 2', 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof 16"

Maximum span: 1st floor 4', 2nd \_\_\_\_\_, 3rd \_\_\_\_\_, roof \_\_\_\_\_

If one story building with masonry walls, thickness of walls? \_\_\_\_\_ height? \_\_\_\_\_

If a Garage

No. cars now accommodated on same lot \_\_\_\_\_, to be accommodated \_\_\_\_\_

Total number commercial cars to be accommodated \_\_\_\_\_

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed build. \_\_\_\_\_?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? NO

Will there be in charge of the above work a person competent to see that the State and City requirement pertaining thereto are observed? YES

Signature of owner J. A. Riley



INSPECTION COPY

579B

Ward 24.2 Permit No 33/1275 <sup>Pls</sup>  
Location Con. Velian + Meridian  
Owner J. A. Wiley  
Date of permit 9/7/33  
Notif ca in \_\_\_\_\_  
Inspn. closing-in \_\_\_\_\_  
Final Notif. \_\_\_\_\_  
Final Inspn. 10/19/33  
Cert of Occupancy issued None

NOTES

10/19/33 - work done  
A. G. S.



# PLUMBING APPLICATION

Department of Human Services  
Division of Health Engineering  
(207) 289-3826

**PROPERTY ADDRESS**

Town or Plantation: PEARS ISLAND  
Street Subdivision Lot #: 85 E 1 WHERAM ST

**PROPERTY OWNERS NAME**

Last: RASTALIS First: JANE  
Applicant Name: DALE L. RASTALIS  
Mailing Address of Owner/Applicant (if different): LIZABETH ST. PEARS ISLAND

PORTLAND PERMIT # 940 TOWN COPY

123,485 \$

Local Plumbing Inspector Signature: [Signature]

Local Plumbing Inspector License # L.P.I. #

**Owner/Applicant Statement**

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: [Signature] Date: 3-7-85

**Caution: Inspection Required**

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature: AA Date Approved: APR 2 - 1985

**PERMIT INFORMATION**

<b>This Application is for:</b>	<b>Type Of Structure To Be Served:</b>	<b>Plumbing To Be Installed By:</b>
1 <input checked="" type="checkbox"/> NEW PLUMBING 2 <input type="checkbox"/> RELOCATED PLUMBING	1 <input checked="" type="checkbox"/> SINGLE FAMILY DWELLING 2 <input type="checkbox"/> MODULAR OR MOBILE HOME 3 <input type="checkbox"/> MULTIPLE FAMILY DWELLING 4 <input type="checkbox"/> OTHER - SPECIFY: _____	1 <input checked="" type="checkbox"/> MASTER PLUMBER 2 <input type="checkbox"/> OIL BURNERMAN 3 <input type="checkbox"/> MFG D. HOUSING DEALER/MECHANIC 4 <input type="checkbox"/> PUBLIC UTILITY EMPLOYEE 5 <input type="checkbox"/> PROPERTY OWNER LICENSE # 162337

Number	Hook-Ups And Piping Relocation	Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District		Hosebibb / Sillcock		Bathtub (and Shower)
			Floor Drain		Shower (Separate)
			Urinal		Sink
	HOOK-UP: to an existing subsurface wastewater disposal system.		Drinking Fountain		Wash Basin
			Indirect Waste		Water Closet (Toilet)
			Water Treatment Softener, Filter, etc		Clothes Washer
	PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.		Grease/Oil Separator		Dish Washer
			Dental Cuspidor		Garbage Disposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other: _____		Water heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2		Fixtures (Subtotal) Column 1
					Fixtures (Subtotal) Column 2
					Total Fixtures
				\$ 6.	Fixture Fee
				\$	Hook-Up Fee
				\$ 6.	Permit fee (Total)

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE

TOWN COPY

**City of Portland, Maine - Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Veteran St - Poona Island		Owner: Ja Anastallis	Phone:	Permit No: <b>050486</b>
Owner Address: Kathy La - Sutton, MA 0152		Lease/Buyer's Name:	Phone:	Business Name:
Contractor Name: Fred Carlson		Address: 37 Pleasant St - Newbury, MA		Phone: 1255 (203) 763-4015
Past Use: 1-fam dwg		Proposed Use: 1-fam w new roof	COST OF WORK: \$ 7500	PERMIT FEE: \$ 50
Proposed Project Description: construct new roof		FIRE DEPT.: <input type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group 93 Type 5B Signature: <i>[Signature]</i>	
		Signature:		Signature: <i>[Signature]</i>
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Signature: <i>[Signature]</i>
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Date:

**PERMIT ISSUED**

Permit Issued:  
**MAY 19 1995**

**CITY OF PORTLAND**

Zone: CBL: *IR-2*

Zoning Approval: *6/17/95*

Special Zones or Reviews:  
 Shoreland  
 Wetland  
 Flood Zone  
 Subdivision  
 Site Plan map  minor  major

Permit Taken By: *L. Chase* Date Applied For: *5/12/95*

- 1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
- 2. Building permits do not include plumbing, septic or electrical work.
- 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

**PERMIT ISSUED WITH LETTER**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record, and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representatives shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

*[Signature]* *5/12/95*  
 SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.V. Pink-Public File Ivory Card-Inspector

Zoning Appeal:

Variance  
 Miscellaneous  
 Conditional Use  
 Interpretation  
 Approved  
 Denied

Historic Preservation:  
 Not in District or Landmark  
 Does Not Require Review  
 Requires Review

Action:  
 Approved  
 Approved with Conditions  
 Denied

Date: *5/15/95*

*[Signature]*

CEO DISTRICT *[Signature]*

COMMENTS

6/19/96

Completed.

*[Signature]*

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

Inspection Services  
P. Samuel Hoffses  
Chief



Planning and Urban Development  
Joseph E. Gray Jr.  
Director

## CITY OF PORTLAND

May 18, 1995

Fred Carlson  
35 Pleasant St  
Newbury, NH 03255

Re: Veteran St, Peaks Island  
085-E-001

Dear Sir,

Your applications to construct a new roof has been reviewed and a permit is herewith issued subject to the following requirements: This permit does not excuse the applicant from meeting applicable state and Federal laws.

1. Roof decking and sheathing 5/8" board, wood structural panel of the thickness specified in Section 2307.3 particle board and section 2308.4.
2. Roof and roof coverings shall be secured in place to the building or structure to withstand the wind loads. Section 1611.0 of the City's building code/BOCA 1993.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

  
P. Samuel Hoffses  
Chief of Inspection Services