


WIPED BY: 2015 ISL

2015



AP-Ryefield Street, Peaks Island
(Assessor's 85-N-12)

June 24, 1958

Mr. Earl Hutchins
New Island Avenue
Peaks Island, Maine

cc to: Mrs. Francis Russell
Ryefield Street
Peaks Island, Maine

Dear Mr. Hutchins:

Building permit to remove side wall (gable end) between living room and sun porch and replace with 4x12 header and to provide ceiling for existing sun porch at the above location is issued herewith but subject to the following conditions:

1. Unsupported length of 4x12 header is not to exceed 14 feet.
2. New 4x6 carrying beam approximately 6 feet long is to be provided under porch floor framing where presently omitted in line with existing 4x6 girder under main house parallel to Seashore Avenue.

Very truly yours,


Theodore T. Rand
Deputy Inspector of Buildings

TTR/jg

Peaks Island

Portland ME

Mrs. Francis Russell




3/4" wire mesh
 2x4 joists
 2x3' board
 2x2" in 5' plate
 5'-6"

Porch

RECEIVED
 JUN 23 1958
 DEPT. OF BLD'G. INSPECTION
 CITY OF PORTLAND

1st Floor

Mrs. Francis Russell
 Peaks Island



RECEIVED

JUN 23 1958

DEPT. OF BLDG. INSP.
CITY OF PORTLAND



R3 RESIDENCE ZONE
APPLICATION FOR PERMIT
 Class of Building or Type of Structure Third Class
 Portland, Maine, June 23, 1958

PERMIT ISSUED
 00773
 JUN 25 1958
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ alter repair ~~demolish~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Rye Field St, Peaks Island Within Fire Limits? no Dist. No.
 Owner's name and address Mrs. Francis Russell, Rye Field St, Peaks Island Me Telephone
 Lessee's name and address Telephone
 Contractor's name and address Earl Hutchins, New Island Ave, Peaks Island Telephone no phone
 Architect Specifications Plans yes No. of sheets 2
 Proposed use of building Dwelling No. families 1
 Last use No. families 1
 Material frame No. stories 1 1/2 Heat Style of roof Roofing
 Other building on same lot
 Estimated cost \$ 400.00 Fee \$ 2.00

General Description of New Work

- To remove front outside wall (gable end).
- To provide header 4x12 in place of partition.
- To provide new ceiling for existing porch, with sheetrock-2x8 ceiling timbers 24" o.c. porch has flat roof.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? no
 Is connection to be made to public sewer? If not, what is proposed for sewage?
 Has septic tank notice been sent? Form notice sent?
 Height average grade to top of plate Height average grade to highest point of roof
 Size, front depth No. stories solid or filled land? earth or rock?
 Material of foundation Thickness, top bottom cellar
 Material of underpinning Height Thickness
 Kind of roof Rise per foot Roof covering
 No. of chimneys Material of chimneys of lining Kind of heat fuel
 Framing Lumber—Kind fir Dressed or full size? Corner posts Sills
 Size Girder Columns under girders Size Max. on centers
 Kind and thickness of outside sheathing of exterior wall?
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor, 2nd, 3rd, roof
 On centers: 1st floor, 2nd, 3rd, roof
 Maximum span: 1st floor, 2nd, 3rd, roof
 If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

Work letter 6-24-58

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
 Mrs. Francis Russell
 Earl Hutchins.

INSPECTION COPY Signature of owner by: Earl Hutchins

F.M.

AP Ryeffield Street,
Peaks Island-I
(Assessors Lot No. 85-N-12)

October 2, 1950

Mr. Paul Kelly
Ryeffield Street
Peaks Island, Maine

Dear Mr. Kelly:

We were unable to get very far with the plan and information which you gave us with application for permit to replace foundations and make alterations in the building on Ryeffield Street, Peaks Island (Assessors Lot No. 85-N-12), as far as the required checking against Building Code requirements is concerned; so our inspector Hamilton tried to reach you by phone without success, and then finally went down to the Island only to find that he was unable to get into or beneath the building and that you had gone away for a time.

Under these circumstances we are unable to check the application against the Building Code, and will have to await your return to get the necessary information.

Very truly yours,

Warren McDonald
Inspector of Buildings

WMCD/G

P. S. Our inspector reports considerable lumber piled on the property which he thinks may be somewhat of a fire hazard. If it should turn out that you do not mean to go ahead with the work this fall, it would be well to make some disposition of the combustible material so that any fire hazard would be eliminated.



(A) APARTMENT HOUSE ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, September 11, 1950

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ alter ~~rebuild~~ ~~reconstruct~~ the following building ~~structure~~ ~~work~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications: 85-N-17

Location Eighth Maine Avenue, Peaks Island Within Fire Limits? no Dist. No. 2783

Owner's name and address Paul Kelly, Eighth Main Ave., Peaks Island Telephone 6-1758

Lessee's name and address 1343 Grand Ave 17/1/50 Telephone 4-0522

Contractor's name and address owner Telephone _____

Architect _____ Specifications _____ Plans yes No. of sheets 3

Proposed use of building dwelling house No. families 1

Last use _____ " " _____ No. families 1

Material wood No. stories 2 Style of roof _____ Roofing _____

Other buildings on same lot _____

Estimated cost \$ 500. Fee \$ 2.00

Refused 5/27/51

General Description of New Work

- To replace existing cedar posts foundation and provide additional posts, all posts to have concrete footings, and posts to be at least 4' below grade or to ledge.
- To excavate under portion of dwelling 7' x 30' and provide rock and concrete wall approximately 2' high to retain earth and water running beneath dwelling, 18" thick.
- To provide concrete foundation for existing chimney, providing 12" thick concrete wall around existing loose stone foundation and fill loose stones in with concrete.
- To provide wallboard on interior walls of entire dwelling and provide wallboard on all ceilings. Existing 2x4 studs, 24" on centers. 2x6 ceiling, 24" on centers, existing.
- To repair foundation of chimney and displace (bring) inside walls + partition in practically correct - none on ceilings.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO owner**
Would be issued from Mr Kelly that he propose no further

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? _____

Height average grade to top of plate _____ Height average grade to highest point of roof _____

Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____

Framing lumber—Kind _____ Dressed or full size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED: _____

Miscellaneous

Will work require disturbing of any tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Paul P. Kelly

Permit No. 501
Location Eighth Maine Ave. P.D.
Owner Paul Kelly
Date of permit 1/56
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. _____
Cert. of Occupancy issued _____

NOTES

THIS IS NOT A PERMIT TO CONSTRUCT OR REPAIR OR ALTER OR ADD TO OR REMOVE OR CHANGE THE USE OF ANY BUILDING OR STRUCTURE OR TO OCCUPY ANY BUILDING OR STRUCTURE UNLESS THE PERMITTEE OBTAINS A PERMIT FROM THE BOARD OF SUPERVISORS.

APPROVED FOR THE BOARD OF SUPERVISORS

DATE

BY

SEAL

OFFICE

STREET

CITY

STATE



ZONING

PERMIT NO.

ISSUED

EXPIRES

REMARKS



9-20-50.

Application alterations Paul Kelley, ^{Eighth Maine Ave.} Wyfield St. Peaks 55-11-12

Mr. Kelley receives previous from Govt. address could be obtained from Veterans Administration, Exchange St.

Note on mail ^{no date} said he had gone to Hartford for a while and to hold mail at office. Understand he has room on Quincy St.

All window shades drawn and window paint sheathed in construction could not be seen.

Considerable lumber stored around house. Although not on fire it thus appears to be a fire hazard as it is close to ^{power} and not far from the large Eighth Maine Bldg.

12-73-50. Chimney under house about 4' x 4' and 4' high all concrete.

First floor 2x6 Dressed to nailed to sill 2x4 @ 12' Sp. Perimeter girdle in center

Some present posts on edge stone on dist

Second floor 6⁷/₈ x 13-24" o.c. Mitchell Board

Attic wall 2x6" o.c. studs

Driv. pitch 2x4-32" o.c.

AP Ryefield Street,
Peaks Island-I
(Lot 85-M-12)--Mr. Paul Kelly

December 18, 1950

Mr. Paul Kelly
1343 Forest Avenue
Portland, Maine

Dear Mr. Kelly:

With relation to your application for a building permit to strengthen and alter our former cottage on Ryefield Street, Peaks Island (Assessors Lot No. 85-M-12), Inspector Hamilton has returned with rather detailed notes as to the present conditions of foundations and framing of the former cottage, and the task of working out what is necessary to make the building sound and reasonably secure on the basis of finishing off walls and ceilings and using as a year-round dwelling, is a most formidable one, and one that we can ill afford to take time to do.

Perhaps I ought to tell you to go out and employ someone to work out these details, but I doubt very much if you could find anyone with patience enough to work out a reasonable solution.

We will undertake to help you, but it is going to take considerable time amid the other extensive duties which we have.


Because of the time of year and the approaching freezing of the ground, I am particularly sorry for this but we cannot help it, and I am inclined to wonder if you will be able to do anything constructively on the foundations and the timbers needed to support the building until better weather comes in the spring.

I suggest that you talk the entire situation over again with the Veterans Administration Officials to see what they would advise under the circumstances. If you should decide to abandon the entire project please notify us promptly as we must not put in the amount of time that this will take on a job which will not go ahead.


Very truly yours,

Warren McDonald
Inspector of Buildings

WMD/G



UNDER SIDE OF HOOSE



1st floor stringers 2' apart
these are 2x6's

2nd floor stringers are 2' apart


These are 2x6 1/2's
Also 2x6 1/2 (two) lengthwise
one 1 1/2' from wall. other
one is 5' from wall

Rafter in roof are 2 1/2' apart


these are 2x4 3/4's

Studs are 2' apart

These are 2x3 3/4's



HERE I
WISH TO LOWER
CELLAR - MAY
GET DOWN FROM
1' TO 2' BELOW
OUTSIDE GROUND
LEVEL - PUT RETAINING WALL OF ROCK + CEMENT TO H



Foundation Under Porch	50
POSTS under House	150
Cellar Excavation plus wall to hold Earth from washing away	150
Insulation + Wallboard	<u>150</u>
Total Cost of all items under this application for Permit	<u>500 500</u>

Grinder through center reducing apart 6'

Sills 4x6 Set Med 19.1 x 11.52 = 21010

27898 x 8.2840 = 23040 # good for 5' apart

21000 x 8 = 168000
 168000 / 400 = 420
 420 x 4 = 1680
 1680 x 8 = 13440
 13440 + 23040 = 36480

D.L.

F1 2x5x6 = 90

Wall 8x5x8 = 600

F1 6x3x6 = 180

Wall 1.5x5x5 = 40

Port 12x5x25 = 1570

2410 #

John M...
 Frank...
 Paul...


L.L.

F1 3x3x40 = 600

6x5x10 = 300

900

Present Sill




Second floor 6³ x 17³ = 1075 x 6.75 = 7256

14520 x 8 = 116160
 116160 / 21 = 55314
 55314 / 2 x 11 = 24919

Member
 (A) At first floor ceiling is 2-1
 cavity 2nd floor, outside wall
 figure out. If some support
 it reduced this space as
 work out, the above load
 otherwise the the floor
 increased not speed p

2x6'

FRONT SILL



$$22 \times 11.00 = 242.00 \times 5.3 = 2854$$

$$\frac{32264 \times 8}{400} = 80.6 \times 64.00$$


Second Floor $6 \frac{3}{4} \times 17 \frac{3}{4} = 117.5 \times 6.75 = 13.2 \times 11.00 = 14520$

$$\frac{14520 \times 8}{21} = 690 \quad \frac{2 \times 14}{2 \times 14} = 24 \text{ #10}$$

Member
 (A) At first floor ceiling is 2-1 1/2" x 6 3/4" on about 13' span. casis 2nd floor outside wall and roof. This does not figure out. If some support can be introduced or reduced this span or this member will work out. The above load of 24 #10 can be accepted otherwise the the floor joist span will be increased or it should permissible loading.

PAUL KELLY'S HOUSE

Floor Timbers 2x6s 2' apart



Mrs. Steining called these "parts" "Jack Posts"

AP Eighth Maine Avenue,
Peaks Island-I
(Mr. Paul Kelly)

September 7, 1950

Mr. Paul Kelly
Eighth Maine Avenue
Peaks Island, Maine

Dear Mr. Kelly:

Since our conversation about finishing off the inside of your building on Eighth Maine Avenue, Peaks Island, a number of things have happened which led me to believe that it would be well to write this letter in an effort to avoid difficulties for you with the Building Law and with this department.

You did not complete your application for a permit relating to applying wall-board to the inside of the building, but Mr. George Keening came in on August 28 and applied for a permit in your name to change out the cedar posts under the entire building to iron posts--3" in diameter. There was insufficient information anyway to allow us to issue the permit, but before we could notify anyone about it, Mr. Keening notified us that he was not going ahead with the work, returned the receipt for the fee paid and requested a refund. That has been done. So, there is no application for a permit on file in this office for any work at all on your building.


The iron posts 3" in diameter are not allowable for foundations under this building anyway, and before issuing any such permit we would have to have more detail as to the framing, construction and supports of the building. As I explained to you we have a great many buildings on the Islands which were built too lightly in the first place. Many of them have been converted to year round dwellings and others have similar plans. A permit is required to make such a conversion, and we must have full information as to the safety of the building before issuing such permits.

Amid the pressure of work coming into this department regularly, the Building Law requires and it is necessary for the owner to provide this full information to show whether or not any proposed work will comply with Building Code requirements.


Very truly yours,

Warren McDonald
Inspector of Buildings

WHCD/O



First Floor



Scale $\frac{1}{8}'' = 1'-0''$

Paul Miller
 344 North 1st St
 Portland, Ore

Handwritten notes at top: *Hand mg*, *unpaired*, *columns*, *minimum*

Handwritten notes at bottom: *min 10' dia*, *min 12' dia*, *min 14' dia*

walls


Bedrock

Roof

Se

Shaded area, crawl space or
 practically an ledge, mostly inaccessible.
 — Board Partition by Mr. Kelley

SHORE SIDE



1st Floor
 81 1/2 MAINE AVE

SHORE SIDE

side

Sill
2-2x6

mid + 30 15 15
2x7 di.
2x4 G.C.

CLOS.

CLOS
Under

2-1 1/2 x 6
diagonal

1/2 x 6
2x4 G.C.

UP

DOWN
1/2 x 6

G.C.

Sill
2x6

5'

14'

1st Floor

8th MAINE AVE

BI FORM 96



APARTMENT HOUSE ZONE
APPLICATION FOR PERMIT

Permit No. 12380
PERMIT ISSUED

Class of Building or Type of Structure Third class

Portland, Maine, August 28, 1938
AUG 26 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location: 8th Maine Avenue, Peaks Island Within Fire Limits? No Dist. No. _____

Owner's or Lessee's name and address: Harry T. Sawyer, 110 Coyle Street Telephone _____

Contractor's name and address: George Jordan, Peaks Island Telephone _____

Architect _____ Plans filed _____ No. of sheets _____

Proposed use of building: Summer cottage No. families _____

Other buildings on same lot: None

Estimated cost \$ 50.00 Fee \$ 1.50

Description of Present Building to be Altered

Material: Wood No. stories: 1 1/2 Heat _____ Style of roof: Fitch Roofing: _____

Last use: Summer Cottage No. families: 1

General Description of New Work
To glass in piazza on rear of cottage (facing ocean) existing with roof over same prior to Dec. 6, 1926. At least 50' to rear lot line.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately in the name of the heating contractor.

Details of New Work

REQUIREMENT OF OCEANIC OR CLOSING IN IS WAIVED

Size: front _____ depth _____ No. stories _____ Height average grade to top of plate _____

To be erected on solid or filled land? _____ earth or rock? _____ Height average grade to highest point _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Framing Lumber—Kind _____ Dressed or Full Size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner-posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? _____

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of owner: Harry T. Sawyer
By Alice M. Sawyer

INSPECTION COPY

61105

Permit No. 38/1330

Location 8th, ^{3rd floor of} ~~W. Main~~ Ave, Parks

Owner Harry J. Sawyer

Date of permit 8/26/38

Notif. closing-in

Inspn. closing-in


Final Notif.

Final Inspn. 10/5/38


Cert. of Occupancy issued None

NOTES

10/5/38 - Work done - ^{85-N-12} OK



(A) APARTMENT HOUSE ZONE



Handwritten text inside a dashed rectangle, possibly indicating a specific area or feature.

8th Street
(121)



(A) APARTMENT HOUSE ZONE

Permit No. 0829
PERMIT ISSUED

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class MAY 10 1928
Portland, Maine, May 10, 1928

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect alter install~~ the following building structure ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Eight Maine Avenue, Peaks Island Ward 1 Within Fire Limits? No Dist. No. _____
Owner's or Lessee's name and address W. T. Sawyer, 10 Backliff St. Telephone PP 791-B
Contractor's name and address not lot Telephone _____
Architect's name and address _____
Proposed use of building Cottage No. families 1
Other buildings on same lot none

Description of Present Building to be Altered

Material Wood No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____
Last use Cottage No. families _____

General Description of New Work

To enclose one side of piazza 14x5

**CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED
NOTIFICATION REFUSE LAPPING
BY CLOSED BY 11:30**

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation present foundations posts thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Distance, heater to chimney _____
If oil burner, name and model _____
Capacity and location of oil tanks _____
Is gas fitting involved? _____ Size of service _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

above work require removal or disturbing of any shade tree on a public street? no
filed as part of this application? yes No. sheets 1
estimated cost \$ 102. Fee \$.50
I hereby certify that I am in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Signature of owner W. T. Sawyer

1 COPY

6423

Permit No. 38/629
Location Highway 7, Mt. Pine Plains
Owner W. T. Sawyer
Date of permit 5/10/28
Notif. closing-in _____
Final closing-in _____
Final Notif. _____
Final Inspn 4/29/28
Cert. of Occupancy issued 8/5

NOTES

