

PLEASANT Cove. PEAKS ISLAND 87-A-1



FIL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT NO. 10531  
MAY 12 1964  
CITY OF PORTLAND

Portland, Maine, May 12, 1964

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Pleasant Ave. Peaks Use of Building 1 fam. dwelling No. Stories 1 1/2 New Building Existing  
Name and address of owner of appliance Charles W. Walth, Pleasant Ave. Peaks Island Telephone 774-4554  
Installer's name and address Randall & McAllister, 84 Commercial St.

### General Description of Work

To install forced hot water heating system and oil burning equipment in place of hot air (coal heat)

### IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no  
If so, how protected? Kind of fuel? oil  
Minimum distance to burnable material, from top of appliance or casing top of furnace 19"  
From top of smoke pipe 19" From front of appliance over 4"  
Size of chimney flue Other connections to same flue From sides or back of appliance over 4"  
If gas fired, how vented? Rated maximum demand per hour  
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

### IF OIL BURNER

Name and type of burner Iron Fireman gun type Labelled by underwriters' laboratories? yes  
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom  
Type of floor beneath burner cement Size of vent pipe 1 1/2"  
Location of oil storage basement Number and capacity of tanks 2, 275 gal.  
Low water shut off Make No  
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?  
Total capacity of any existing storage tanks for furnace burners

### IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?  
If so, how protected? Height of Legs, if any  
Skirting at bottom of appliance? Distance to combustible material from top of appliance?  
From front of appliance From sides and back From top of smokepipe  
Size of chimney flue Other connections to same flue  
Is hood to be provided? If so, how vented? Forced or gravity?  
If gas fired, how vented? Rated maximum demand per hour

### MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

(Old Leighton homestead)

Amount enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building as one.)

APPROVED:

*ok. E. S. B. 5/12/64*

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? YES  
Randall & McAllister

Signature of Installer: *W. McAllister*

C. 300

INSPECTION COPY

Permit # 54/500

Location Lebanon - One Republic

Operator William Walker

Date of permit 5/12/64

Approved \_\_\_\_\_

NOTES

1	Fill Pipe	_____
2	Vent Pipe	_____
3	Kid of Head	_____
4	Burner Rigidity & Supports	_____
5	Frame & Lateral	_____
6	Stack (or)	_____
7	High Line	_____
8	Remot. Control	_____
9	Pipes (or) Vent & Stack	_____
10	Valves & Appurtenances	_____
11	Capacity of Tanks	_____
12	Th. Capacity & Supports	_____
13	1" W. Jacket	_____
14	Oil Gauge	_____
15	Instruction Card	_____
16	Low Water Shut-off	_____

5/31/65 - No pump

*[Handwritten signature]*

*[Large handwritten X mark]*