

CENTRAL AVENUE PEAKS ISLAND
87-F-3

STATE OF CALIFORNIA
COUNTY OF SAN DIEGO



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Sept. 6, 1974

PERMIT ISSUED

SEP 6 1974

0821 CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

87-F-3

Location Central Ave, Peaks Island Use of Building No. Stories 2 New Building Existing "
Name and address of owner of appliance George Spofford, Hear Estate, same
Installer's name and address Jackson-Casey, Peaks Island Telephone 766-2817

General Description of Work

To install Steam boiler and burner in existing system

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe 21 8" From front of appliance 10" From sides or back of appliance 6"
Size of chimney flue 8x8 Other connections to same flue no
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner American Standard Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner dirt Size of vent pipe
Location of oil storage Number and capacity of tanks 1 1/2"
Low water shut off yes Make McDonnell Miller No. 65
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners one 275 gal.

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 5.00

APPROVED:

OK 9-6-74-NRC

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

CS 300

INSPECTION COPY

Signature of Installer

Jackson Casey
Ralph Jackson #273



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
Permit No. 1254

SEP 28 1945

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, September 28, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Central Ave., Peaks Island Use of Building Dwelling No. Stories 2 Existing New Building

Name and address of owner of appliance Isabella Devine, Central Ave., Peaks Island Telephone 2-2157

Installer's name and address Montgomery and Trites, 66 Coyle Street **NOTIFICATION BEFORE LATHING OR CLOSING IS WAIVED**

To install Oil burning equipment in connection with existing gravity hot water **CERTIFICATE OF OCCUPANCY REQUIREMENT IS WAIVED**

IF HEATER, POWER BOILER OR COOKING DEVICE Kind of Fuel oil

Is appliance or source of heat to be in cellar? Yes If not, which story _____

Material of supports of appliance (concrete or what kind) concrete

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, from top of smoke pipe _____

Size of chimney flue _____ Other connections to same flue _____ from sides or back of appliance _____

Name and type of burner Eastern oil IF OIL BURNER Labeled and approved by Underwriters' Laboratories? Yes

Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) gravity pressure

Location oil storage basement No. and capacity of tanks 1-275 gal.

Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc.; 50 cents additional for each additional heater, building at same time.)

Signature of Installer By: Montgomery & Trites

ORIGINAL

Permit No. 4571254

Location Central Ave, Peabody, Mass

Owner DeLella, Dennis

Date of Permit 9/29/45

Post Card sent

Notif. for insp.

Approval Tag issued 8-11-47

Oil Burner Check List (date) 87-1-53

1. Kind of heat Gas

2. Label

3. Anti-riphon

4. Oil storage

5. Tank Distance

6. Vent Pipe

7. Fill Pipe

8. Gauge

9. Rigidity

10. Feed safety

11. Pipe sizes and material

12. Control valve

13. Ash pit vent

14. Temp. or pressure safety

15. Instruction card

16.

NOTES

A-9.6


20 ft

A-9.6

Proposed Garage
11 x 18

20 ft

Central Ave



Memorandum from Department of Building Inspection, Portland, Maine
Central Ave., Peaks Island---Addition for Garage by and for Mr. Henry S. Hoar---12/4/42

To Owner:

The information you gave on the application and plan is incomplete in a number of particulars as to the relative location or level of the garage floor and the cellar floor, as to whether or not there is to be a door connecting the garage and dwelling, that I am unable to tell what I would like to about compliance with the Code, before the permit is issued.

I have decided to issue the card, however, drawing your attention to the provisions of Sections 302-b-2 and 302-c-4, and 302-c-1.2. I presume you will bear in mind that the cedar posts for foundation are to extend at least four feet below the grade of the ground or to ledge rock, because the garage is attached to a dwelling.

(Signed) Warren McDonald
Inspector of Buildings



APPLICATION FOR PERMIT

PERMIT ISSUED

Permit No. 1437
DEC 31 1942

Class of Building or Type of Structure _____

Portland, Maine, December 2, 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Central Avenue, Peaks Island Within Fire Limits? no Dist. No. _____
 Owner's or Lessee's name and address Henry S. Hoar, Peaks Island Telephone 1572
 Contractor's name and address Owner Telephone _____
 Architect _____ Plans filed yes No. of sheets 1
 Proposed use of building dwelling house with 1 car garage attached No families 2
 Other buildings on same lot none
 Estimated cost \$ 200 Fee \$ 1.00

Description of Present Building to be Altered

Material wood No. stories 1 1/2 Heat hot water Style of roof _____ Roofing _____
 Last use dwelling house No. families 2

General Description of New Work

To build one story frame addition 11' x 10' in front jog of building for one car garage
 The inside of the garage will be covered where required by law, with metal lath and plaster

O.K. 12/24/42. 970.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by, and in the name of, the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____
 Is any electrical work involved in this work? _____ Height average grade to top of plate _____
 Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof 8'
 To be erected on solid or filled land? solid earth or rock? earth
 Material of foundation: 2x4 cedar posts Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof flat Rise per foot 3" Roof covering Asphalt roofing Class C Ind. Lab.
 No. of chimneys 00 Material of chimneys _____ of lining _____
 Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
 Framing (lumber)—Kind hemlock Dressed or full size? dressed
 Corner posts 4x4 Sills 6x6 Girt or ledger board? _____ Size _____
 Material columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
 Joists and rafters: 1st floor concrete, 2nd _____, 3rd _____, roof 2x10
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof 16"
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof 11'
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot none to be accommodated _____
 Total number commercial cars to be accommodated none
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner

Henry S. Hoar

INSPECTION COPY

260020

Permit No 42/1437

Location Central Ave Peaks

Owner Henry S. Hoar

Date of permit 7/31/42

Notif. closing-in

Inspn. closing-in 87

Final Notif. 3

Final Inspn. **INSPECTION NOT COMPLETED**

Cert. of occupancy issued

NOTES

12/7/42 W.P.B. letter card

Peak Pit

Problems shown over matter
noted on attached memo

with Mr. Hoar, etc.

DISCUSSION OF PERMITS

15 PERMITS

Rept. 1687D-I

June 2, 1942

Mr. Henry F. Hoar,
Central Avenue,
Peaks Island, Maine

Subject: Building permit for relocation
of garage and conversion to dwelling house

Dear Sir:

I understand that when this building has been relocated and finished it will have no garage use whatever but will be used entirely as a one family dwelling house, thus making two single family dwelling houses on your property.

There is not enough information either on plan or application to tell me whether or not the work when finished will comply with Building Code requirements for a dwelling house. I am issuing the permit but it is legally required that you secure from this office a certificate of occupancy before this building is used as a dwelling house, and as usual it is required that you notify this office for readiness of closing in the framing and receive a certificate to authorize such closing in before proceeding with it. Irrespective of the fact that you are now receiving a building permit to cover this work, you are bound by law to comply with the Building Code, and of course any changes discovered necessary at time of either closing-in inspection or final inspection will have to be accomplished at your inconvenience and expense.

Apparently we have no information showing the framing of the present roof, side walls or present floor of the building; neither do we have information as to how the roof of the new structure is to be supported against the present building in its new location. The 2x4 roof joists of the addition over a span of six feet and 20 inches from center to center will work out a little shy of the strength required to support the roof load alone. If they are also expected to support any other loads such as ceiling loads they will not be adequate. The sills all around would have to be at least six inches above the grade of the ground around the outside, and the cedar posts are required to extend at least four feet into the ground or to ledge if ledge is encountered at a less depth.

It seems to me it would be far better for you to make a complete framing plan of the entire finished building and get it checked here before committing yourself to the job by going ahead and buying material, etc.

There is one remote question under the Zoning Law. You have indicated that the front of the proposed dwelling will be 26 feet from the street line of Central Avenue. If there were on that side on the adjoining lot a cottage or a dwelling house within 100 feet of the proposed dwelling house and having the front wall of such cottage or dwelling house more than 20 feet from the street line of Central Avenue, then your location as to front yard distance would be illegal under the Zoning Law. If such should be the case, it would be best for you to return the permit and see what steps, if any, can be taken to adjust the matter.

Very truly yours,

WMAH/H


Inspector of Buildings

Mr. Henry F. Hear_____?

June 2, 1942

P.S. I do not understand what this clause in the application means: "To make eight foot opening in existing side wall, putting in 4" header under existing plate.", but presume this must be some type of mullion window. If this should mean garage door opening, of course legal fire protection would be required between the garage and the balance of the building.

Central Ave.



RECEIVED
JUN 1 - 1942
DEPT. OF BLDG. INSP.
CITY OF PORTLAND

Garage
27
26

Proposed work. Change present
location of garage 16 x 22
add 6 ft on side & rear
for small apartment

22.4 x 20" oc. balustrade 4.35
6 x 1.65 x 4.5 11.67
3.35
4.50



APARTMENT HOUSE ZONE PERMIT ISS APPLICATION FOR PERMIT

Permit No. 078

Class of Building or Type of Structure Third Class JUN 2 1942

Portland, Maine, June 1, 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Central Avenue, Parks Island Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Henry S. Hoar, Central Avenue, Parks Island Telephone 157-2
Contractor's name and address _____ Telephone _____
Architect _____ Plans filed yes No of sheets 1
Proposed use of building dwelling house No. families 1
Other buildings on same lot dwelling house 1 family
Estimated cost \$ 400. Fee \$ 1.00

Description of Present Building to be Altered

Material wood No. stories 1 Heat no Style of roof pitch Roofing asphalt
Last use 1 car garage No. families _____

General Description of New Work

To move one story building 15' x 22' to new location as shown on plan and change use of same to dwelling house
To provide cedar post foundation
To build one story addition 6' x 22' on westerly side of building, with one story open rear piazza 6' x 16'
Studding will be made 2x4 16" OC - existing sills 4x6
To build one inside brick chimney with tile lining
To put in new partitions to make three rooms and bath, 2x4 studs 16" OC sheet rock
To make 8' opening in existing side wall, putting in 4x6 header under existing plate
To cut in new front entrance door, and five new windows - existing garage entrance door to be studded up and closed in

87-F-3 178' from Boulder Road 1400 ft from Jeld Ave.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____
Is any electrical work involved in this work? _____ Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation cedar posts Thickness, top _____ bottom _____ cellar _____ no
Material of underpinning _____ Height _____ Thickness _____
Kind of roof flat Rise per foot 1/4" Roof covering Asphalt roofing Class C Und. Lab
No. of chimneys 1 Material of chimneys brick of lining tile
Kind of heat stove Type of fuel _____ Is gas fitting involved? _____
Laming lumber - Kind penlock Dressed or full size? _____
Corner posts 4x4 Sills 4x6 Girt or ledger board? _____ Size _____
Material columns under girders cedar post Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor 2x6, 2nd _____, 3rd _____, roof 2x4
On centers: 1st floor 12", 2nd _____, 3rd _____, roof 20"
Maximum span: 1st floor 6', 2nd _____, 3rd _____, roof 6'
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Signature of owner Henry S. Hoar

INSPECTION COPY

Permit No. 42/598

Location Central Ave. Peak

Owner Lenny S. Hoas

Date of permit 6/8 1/42

Notif. closing-in

Inspn. closing-in

Final Notif. 8/24/42

Final Inspn. 11/9/42. 636

✓ Cert. of Occupancy issued 11/9/42.

NOTES

~~THIS IS NOT A PERMIT FOR...
CONTINUED...
...
...~~

87
F
3

10/11/42



FILL IN COMPLETELY AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT No. 13047
ISSUED

NOV 20 1939

Portland, Maine, November 20, 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location: Central Avenue, Peaks Island of Building dwelling No. Stories 1 1/2 New Building

Name and address of owner of appliance R. S. Hoar, City Point Road, Peaks Existing

Installer's name and address Owner

Telephone 163-4

General Description of Work

To install hot water heating system in main building (gravity)

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel coal

Material of supports of appliance (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, 2'
from top of smoke pipe 30" from front of appliance over 4' from sides or back of appliance 8'

Size of chimney flue 8x8 Other connections to same flue stove

IF OIL BURNER

Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____

Will operator be always in attendance? _____ Type of oil-feed (gravity or pressure) _____

Location oil storage _____ No. and capacity of tanks _____

Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of Installer Henry S Hoar

6044C



Original Permit No. 33/1718
 Amendment No. PERMIT ISSUED

AMENDMENT TO APPLICATION FOR PERMIT

Portland, Maine, November 6, 1939 NOV 7 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 33/1718 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location Central Avenue, Paska Ward Isl. 2 Within Fire Limits? no Dist. No. 163-1
 Owner's or Lessee's name and address Harry S. Hear, City Point Rd., Paska
 Contractor's name and address Owner
 Plans filed as part of this Amendment _____ No. of Sheets _____
 Increased cost of work _____ Additional fee 25

Description of Proposed Work

To close up two existing outside entrance doors (leaving two more) and put small window in place of one of them - all of building
 To interchange the existing windows and doors in main building, providing new plate glass 36" x 4" cedar post foundation, 4 no. sills, 11/2" or 1 1/2" x 10" - 18" OC
 In new bath room in main building instead of cutting in new window, to open up former skylight at least three square feet in area

Approved: _____
 Chief of Fire Department

 Commissioner of Public Works.

Signature of Owner Henry S. Hear

Approved: 11/7/39

 Inspector of Buildings

INSPECTION COPY



(A) APARTMENT HOUSE ZONE
APPLICATION FOR PERMIT

Permit **PERMIT ISSUED**

Class of Building or Type of Structure Third Class 1718

Portland, Maine, October 3, 1933 OCT 3 1933

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect/alter/install the following building structure/equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Central Avenue, Pearl Island Within Fire Limits? NO Dist. No. _____
Owner's or Lessee's name and address Henry S. Hoar, City Point B1, Pearl Telephone 163-4
Contractor's name and address _____ Owner Telephone _____
Architect _____ Plans filed 10 No. of sheets _____
Proposed use of building dwelling house No. families 2
Other buildings on same lot _____
Estimated cost \$ 200 Fee \$ 75

Description of Present Building to be Altered

Material wood No. stories 2 1/2 Heat stove Style of roof pitch Roofing asphalt
Last use dwelling house (Shaw) No. families 1

General Description of New Work

- To cover front piazza roof and bay window
- To Change Use of building to two family dwelling - one family in ell and one in main building, closing up an existing door on first floor between the two parts
- To use an existing room, second floor, main house, for new bath room, cutting in window at least three square feet in area for ventilation.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? yes
Is any electrical work involved in this work? yes Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering Asphalt roofing, Glass U Und. Lub.
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing Lumber - Kind _____ Dressed or Full Size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Cirders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner

Henry S. Hoar

Perm No. 39/1718

Location: Central Ave. Peaks

City: N.S. Hoar

Date of permit: 10/3/39

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn: 9/19/40

Cert. of Occupancy issued: 1/10/40

Heat 3/10/40

NOTES

12/7/39. Work started

6/2/40. No work done

7/2/40. This work being done

Work on this work on 4/10/40

Work on

DATE	DESCRIPTION	BY	REMARKS
10/3/39	Permit issued		
12/7/39	Work started		
6/2/40	No work done		
7/2/40	Work being done		
4/10/40	Work on this work		
9/19/40	Final inspection		
1/10/40	Cert. of Occupancy issued		
3/10/40	Heat installed		



Complaint No. C-82-5

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

COMPLAINT

Rec'd 12/29/51

Location Central Avenue, Peaks Is. Ward 1

Owner's name and address Deerick L. 1203 Portland Ave. 343 Forest Ave Telephone _____

Tenant's name and address George Lassell, Central Ave., Peaks Is. Telephone _____

Use of building _____

General Description

Additions have been made to poultry house without permit.

Complainant's name and address Bldg. Insp. Dept. - AJS Telephone _____

Date of examination and conditions found _____

Action taken _____

INSPECTION COPY

Ward 1 Complaint No. 17-32-3

Location Central Ave, Oakes Ca

Date Received 12/29/31

Date Disposed of 4/11/32

87-F 3-1 NOTES

12/29/31 - A lean-to consisting of one side and end with one side open has been built on end of poultry house. There is no plate, rafters resting directly on studs. Rafters are 2x8's 2x4's spliced miscellaneous and about 3' o.c. with 2x4 flatways for girders in center, supported on 2 posts and spliced between posts. Roof is covered with tar paper. Structure is 8' x 6'-6" post. Studs are rough poles, miscellaneous pieces of lumber. An 8' x 14' addition between two poultry houses with one side

open has also been built. Rafters are 2x4 on about 8' span and 3' o.c. Roof is covered with tar paper. Header across open side is inadequate bracing miscellaneous pieces of lumber about 3' o.c. Flat roof - O. O. S.
12/30/31 - Mr. Russell was in Mr. McDonald's told him structure would have to be removed, but that he could be built for wood bracing for which no permit is necessary. A. J. S.